



Calc. For Control Room Infiltration Study	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 1	of

Client Commonwealth Edison Company	
Project Zion	
Proj. No. 7805-11	Equip. No.

Prepared by <i>R. A. Huber</i>	Date
Reviewed by	Date
Approved by	Date

TABLE OF CONTENTS

	<u>Page</u>
Calculation Revision Summary Sheet	A1
TABLE OF CONTENTS	1
LIST OF TABLES	4
1. PURPOSE	7
2. ASSUMPTIONS AND DATA	7
2.1 Assumptions	7
2.2 Data	8
3. METHODS	10
4. SPRAY REMOVAL ANALYSES	11
4.1 Spray Description	11
4.2 SPIRT Calculations	12
4.2.1 Data and Preliminary Calculations	12
4.2.2 SPIRT Input	13
4.2.3 SPIRT Output	14
4.3 Elemental Iodine Spray Removal Rate	15
4.3.1 Spray Flow Rate of 5230 gpm (Two Pumps)	15
4.3.2 Spray Flow Rate of 2615 gpm (One Pump)	16
4.3.3 Elemental Iodine Spray Removal Summary	17
4.4 Elemental Iodine Spray Decontamination Factor	18
4.5 Elemental Iodine Wall Deposition Rate	19

Form GO-3 08.1 Rev. 2 SL-F647 10-85 KPS

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 2 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

TABLE OF CONTENTS, Cont'd

	<u>Page</u>
4.6 Calculation of Elemental Iodine Spray Time (Effective)	23
4.7 Particulate Iodine Spray Removal Rate	27
4.7.1 Spray Flow Rate of 5230 Gpm (Two Pumps)	27
4.7.2 Spray Flow Rate of 2615 Gpm (One Pump)	28
4.7.3 Particulate Iodine Spray Removal Summary	28
4.7.4 Calculation of Particulate Iodine Spray Time (Effective)	29
4.7.5 POSTDBA Effective Spray Removal Rate for Particulate Iodine	32
 5. CONTROL ROOM FINITE CLOUD CORRECTION FACTORS	 35
5.1 Data	35
5.2 POSTDBA Input	35
5.3 POSTDBA Output	38
 6. CONTROL ROOM DOSE CALCULATIONS	 39
6.1 Preliminary Calculations	39
6.1.1 Calculation of POSTDBA Effective Windspeeds	39
6.1.1.1 Plan View Separation Distance	41
6.1.1.2 Circuitous Path Separation Distance	42
6.1.2 ECCS Leakage	43
6.1.2.1 ECCS Leak Rate (POSTDBA Purge Rate)	43
6.1.2.2 Effective POSTDBA Purge Filter Efficiency	44
6.1.3 Nuclide Data	45
6.1.3.1 Initial Airborne Activity in Primary Containment	45
6.1.3.2 Nuclide Data Adjustments	45



Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 3	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

TABLE OF CONTENTS, Cont'd

	<u>Page</u>
6.2 POSTDBA Calculations	49
6.2.1 Description	49
6.2.2 POSTDBA Input	54
6.2.3 POSTDBA Output	67
7. IODINE PROTECTION FACTOR METHODOLOGY	68
8. CONTROL ROOM DOSE RESULTS	70
9. SUMMARY	87
10. REFERENCES	88
11. ATTACHMENTS	92
11.1 Microfiche A	92
11.2 Microfiche B	93
11.3 Microfiche C	94
11.4 Microfiche D	95
REVIEW METHOD SHEET	96



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 4	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

LIST OF TABLES

	<u>Page</u>
1. Elemental Iodine Spray Removal Rates	17
2. Particulate Iodine Spray Removal Rates	28
3. Control Room Finite Cloud Correction Factors (Dose Ratios)	38
4. POSTDBA Effective Windspeeds for Plan View Separation Distance	41
5. POSTDBA Effective Windspeeds for Circuitous Path Separation Distance	42
6. Calculation of Initial Airborne Activity in Primary Containment	46
7. Nuclide Data Adjustments for Reference 21 Thyroid Dose Conversion Factors	47
8. Nuclide Data Adjustments for Reference 22 Thyroid Dose Conversion Factors	48
9. POSTDBA Cases	50
10. POSTDBA 30 Day Control Room Doses Using Core Inventory; Plan View (\dot{V}/Q'); R.G. 1.109 Thyroid Dose Conversion Factors	71

Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 5 of

Client
Project
Proj. No. 7805-11
Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

LIST OF TABLES, Con't

	<u>Page</u>
11. POSTDBA 30 Day Control Room Doses Using Core Inventory; Circuitous Path ($\frac{1}{2}$); R.G. 1.109 Thyroid Dose Conversion Factors	72
12. POSTDBA 30 Day Control Room Doses Using Gap Inventory; Circuitous Path ($\frac{1}{2}$); R.G. 1.109 Thyroid Dose Conversion Factors	73
13. POSTDBA 30 Day Control Room Doses Using Gap Inventory; Plan View ($\frac{1}{2}$); R.G. 1.109 Thyroid Dose Conversion Factors	74
14. POSTDBA 30 Day Control Room Doses Using Core Inventory; Plan View ($\frac{1}{2}$); ICRP-30 Thyroid Dose Conversion Factors	75
15. POSTDBA 30 Day Control Room Doses Using Core Inventory; Circuitous Path ($\frac{1}{2}$); ICRP-30 Thyroid Dose Conversion Factors	76
16. POSTDBA 30 Day Control Room Doses Using Gap Inventory; Circuitous Path ($\frac{1}{2}$); ICRP-30 Thyroid Dose Conversion Factors	77
17. POSTDBA 30 Day Control Room Doses Using Gap Inventory; Plan View ($\frac{1}{2}$); ICRP-30 Thyroid Dose Conversion Factors	78



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 6	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

LIST OF TABLES, Cont'd

	<u>Page</u>
18. Control Room Dose Summary Using Ref. 21 Thyroid Dose Conversion Factors	79
19. Control Room Dose Summary Using Ref. 22 Thyroid Dose Conversion Factors	80
20. Infiltration Rates to Obtain a 30 Day Control Room Thyroid Dose of 30 Rem (R.G. 1.109)	82
21. Infiltration Rates to Obtain a 30 Day Control Room Thyroid Dose of 30 Rem (ICRP-30)	84
22. Infiltration Rates to Obtain a 30 Day Control Room Thyroid Dose of 50 Rem (ICRP-30)	86



Calcs. For Control Room Infiltration	
Study	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 7	of

Client Commonwealth Edison Company	
Project Zion	
Proj. No. 7805-11	Equip. No.

Prepared by <i>R. J. Huber</i>	Date
Reviewed by	Date
Approved by	Date

1. PURPOSE

The purpose of this calculation is to provide control room infiltration rates that produce thyroid inhalation doses equal to the regulatory limits for a variety of control room models. Whole body and beta skin doses from airborne activity within the control room are also checked against regulatory limits.

2. ASSUMPTIONS AND DATA

2.1 Assumptions

The assumptions of Reference 7 (Section 2.4) and of Reference 8 (Subsection 2.1.2) are used.

The sprayed volume of the containment is 85% of the free volume.

Various values for control room recirculation filter efficiency and control room infiltration rate are assumed.

For wall deposition purposes, the wetted area is assumed to be 410,000 ft²; see Section 4.5 for discussion.



Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 8	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

2.2 Data

Primary Containment Data

<u>Description</u>	<u>Value</u>	<u>Reference</u>
Containment Free Volume, ft ³	2.736+6	Ref. 9, Table 14.3.2.5 (1)
Fraction of Containment Vol. Sprayed	.85	Assumed
Containment Leak Rate, %/day		
0-24 hr	0.1	Ref. 10, p. 212
24-720 hr	0.05	Ref. 1, p. 1.4-1
Iodine Species Fractions		
Elemental	.91	} Ref. 1, p. 1.4-1
Particulate	.05	
Organic	.04	
Spray Flow Rate, gpm		
One pump	2615.	Calculated from two pumps
two pumps	5230.	Ref. 11, p. 6A-9
Spray Drop Fall Height, ft.	147.	Ref. 11, Table 6A-1
Sump Water Volume	—	See Section 4.4
Iodine Partition Coefficient	10,000.	See Subsection 4.2.1
Spray Nozzle Type	SPRAYCO #1713	Ref. 11, p. 6.4-4
Spray Nozzle Types #1713 and #1713A	—	Ref. 12
Have Same Characteristics	—	—
Spray Nozzle #1713A Data	—	Ref. 13



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 9	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Atmospheric Dilution Data

Description	Value	Reference
Containment Projected Area Normal to Wind Direction, ft ²	26436.	Ref. 14, p. 18
	m ² 2456.	Ref. 14, p. 18
Plan View Separation Distance, ft, (Containment surface to Control Room Air Inlet)	91.76	Ref. 14, p. 13
Circuitous Path Separation Distance, m.	80.	Ref. 15, p. 2-26
	ft. 262.5	(calculated from 80m.)
Containment Outside Diameter, ft.	147.	Ref. 14, p. 12

Control Room Data

Description	Value	Reference
Free Volume, ft ³	1.19122+5	Ref. 16
Make-up Air Flow Rate, cfm	2000. ± 10%	Ref. 10, p. 284
Conservative Value*, cfm	1800.	calculated*
Recirculation Air Flow Rate, cfm	11500.	Ref. 16
Make-up Air Filter Efficiency (Iodine)	99%	Ref. 11, Q9.8-1 & Q9.3-1

* Conservative value = 2000 - .10 * 2000. = 1800. This smaller value gives less dilution by filtered air, thus higher thyroid doses (conservative).



Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 10	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

3. METHODS

NRC guidance found in References 1 through 5 is used.

Spray removal rates, plateout rate, and decontamination factors formulations and data are taken from Reference 2, pages 6.5.2-10 through 6.5.2-12. Parameters for the elemental iodine spray removal rate are obtained from computer runs using program SPIRT, S & L Program Number SPI 09810010 (Reference 6). Effective spray times are hand calculated using the algorithms of Reference 7, pages 9, 10, and 27; these describe a two compartment model (unsprayed and sprayed) for spray removal as inferred by Reference 2, p. 6.5.2-7.

Control room (\sqrt{Q}) methodology is obtained from Reference 4 and the resulting windspeeds are converted to POSTDBA windspeeds by the methods in Reference 7.

Control room finite cloud correction factors for whole body dose are obtained from a computer run using program POSTDBA, S & L Program Number POS 098085110 (Reference 8).

Control room doses are obtained from computer runs using program POSTDBA, S & L Program Number POS 098085110 (Reference 8). Thyroid doses are supplemented with values using the Iodine Protection Factor (IPF) methodology of Reference 4.



Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. <u>ZI-5-91</u>
Rev. <u>0</u> Date
Page <u>11</u> of

Client
Project
Proj. No. <u>7805-11</u> Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4. SPRAY REMOVAL ANALYSES

4.1 Spray Description

The operation of the containment spray is described in the Zion FSAR. According to Reference 11, Appendix A, pages 6A-8 and 6A-9, two spray pumps operate at a total of 5230 gpm for 15 minutes during the injection phase. This leaves 100,000 gal. in the RWST. At this point the changeover to the recirculation phase is manually started. But the spray injection phase continues another 19 minutes depleting the last 100,000 gal. from the RWST. This implies that two spray pumps are still operating during this last 19 minutes.

However, Reference 11, page 6.2-9 says that only one spray pump operates to empty the RWST. One spray pump operating at $5230 \text{ gpm} / 2 = 2615 \text{ gpm}$ on 100,000 gal. would take $100,000 \text{ gal} / 2615 \text{ gpm} = 38.24$ minutes to empty the RWST. As will be seen in Subsections 4.7.1 and 4.7.2, the smaller spray rate results in a smaller removal rate for particulate iodine. Thus, it will take longer to reach a DF of 50 (Subsection 4.7.3); this would lead to conservatively larger thyroid doses. Thus, after the first 15 minutes of operation by two spray pumps, one spray pump will be considered as operating for an additional 38 minutes (conservatively rounded).

In summary, the spray will operate at 5230 gpm for the time period 0-15 minutes. Then, it will operate at 2615 gpm for the time period 15-53 minutes.

Form GO-3.08.1 Rev. 2

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 12 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4.2 SPIRT Calculations

4.2.1 Data and Preliminary Calculations

The SPIRT options used and most of the SPIRT data are taken from Reference 17. Exceptions are now given.

Containment Free Volume = 2.73616 ft^3 , Ref. 9, Table 14.3-2-5(1)
(SPIRT acronym CNTVOL)

Fraction of containment free volume sprayed = $.85$, assumed
(SPIRT acronym FRCVS)

Spray flow rate = 5230 gpm for two pumps } See Section 4.1
 = 2615 gpm for one pump }
(SPIRT acronym FLOW)

Partition Coefficient = $10,000$, Ref. 18, Figure 33, page 44,
(SPIRT acronym H) for pH=7 (conservative). A conservatively small H is picked at a time much less than 1000 sec; note that spray is on longer than 1000 sec (Section 4.1).

Plateout surface area = $410,000 \text{ ft}^2$ See Section 4.5.

From Reference 17, page 8, this gives

$$\text{SPIRT acronym AWALLR} = 410,000 * \frac{10}{147} = 2.78914 \text{ ft}^2$$

$$\text{and SPIRT acronym AWALTR} = 410,000 - 2.78914 = 3.821115 \text{ ft}^2$$



Calc. For _____	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date _____
Page 13 of _____

Client _____
Project _____
Proj. No. 7805-11 Equip. No. _____

Prepared by _____	Date _____
Reviewed by _____	Date _____
Approved by _____	Date _____

4.2.2 SPIRT Input

The SPIRT input instructions are in Reference 6. The input listings for both cases (5230 gpm and 2615 gpm spray flow rates) are found on the attached microfiche (Microfiche A):

ZI-5-91 RD SR NSLD 4C4-A1 SYS CR CNTRL RM INFILT STDY(SPIRT)
 S&L 03/11/91 10:15:52 WG=212 ID=DRSH
 ORIG=05 DUPS=01 PRJ=ZIO780511 PGM=SPIO98100100/

The input description for each case is as follows.

Card No. 1 Format (20A4)
 (TITLE(3), I=1, 20) Literal title (see listing, Microfiche A)

Card No. 2 Format (6I3)

NGRP = 50	Rev. 0	} Ref. 17
NTYPE = 1	Rev. 0	
NSTEPS = 147	Rev. 0	
NREAC = 1	Rev. 1	
NDATA = 0	Rev. 0	

Card No. 3 Format (8E10.8)

CNTVOL = 2.736+6	Subsection 4.2.1	} Subsection 4.2.1
FRCVS = .85	Subsection 4.2.1	
FLOW = 5230.0	for case 1	
= 2615.0	for case 2	
ZMAX = 147.0	} Ref. 17, Rev. 0	
EFC = 1.0		
H = 10000.0	Subsection 4.2.1	

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 14 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Card No. 4 Format (8E10.3)

TNORM = 70.0 Rev. 0
 TEMPF = 267.0 Rev. 0
 DMEANG = .0282 Rev. 0
 SIGMAG = 2.018 Rev. 0
 RK = 7.7-8 Rev. 1
 HR = 5.0 Rev. 1
 DMAX = 0.4 Rev. 0

} Reference 17 and
 Reference 11, Subsection 6.4.2,
 page 6.4-1.

Card No. 5 Format (8E10.3)


AWALLR = 2.789+4 }
 AWALTR = 3.8211+5 }
 WALLFR = .05 Rev. 0 }
 WALLDT = 1.0 Rev. 0 }
 CNTDIA = 140.0 Rev. 0 }
 WALLSP = 6.465+4 Rev. 0 }

Subsection 4.2.1
 Reference 17

Cards 6 and 7 are omitted because NTYPE=1

4.2.3 SPIRT Output

The SPIRT output for both SPIRT cases can be found in the attached microfiche A.



Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 15	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4.3 Elemental Iodine Spray Removal Rate

4.3.1 Spray Flow Rate of 5230 GPM (Two Pumps)

The following table presents the calculation of the elemental iodine spray removal rate, λ_s , for two spray pumps operating (accident time 0 to 15 minutes). Note that the volume mean diameter from the final SPIRT temporal distribution is used because it is larger than that from the final spatial distribution; thus, the calculated λ_s is smaller (conservative).

Variable	Case 1 SPIRT Results*		Linearly Interpolated for $D = .1829$ cm**
	at Drop Diameters (D) of		
	$D = .1715$ cm	$D = .1918$ cm	
h (input)	147. ft.	147. ft.	—
v (calculated)	417.6 cm/sec	441.5 cm/sec	—
$T = h/v$.35201 ft·sec/cm	.33296 ft·sec/cm	.34131 ft·sec/cm
K_g (calculated)	5.544 cm/sec	5.354 cm/sec	5.437 cm/sec
V (input)	2.736 + 6 ft ³	2.736 + 6 ft ³	2.736 + 6 ft ³
F (input)	5230. gpm	5230. gpm	5230. gpm
C ***	244.4	244.4	244.4
$\lambda_s = C \frac{6K_g T F}{V D} \dagger$	31.90 hr ⁻¹	26.05 hr ⁻¹	28.44 hr ⁻¹ ††

* see attached microfiche A

** Mass mean diameter (volume) from final SPIRT temporal distribution; see microfiche A.

*** Units conversion factor, $\text{cm} \cdot \text{ft}^2 \cdot \text{min} / (\text{gal} \cdot \text{hr})$ from $(30.48 \text{ cm/ft}) \cdot (.13365 \text{ ft}^3/\text{gal}) \cdot (60 \text{ min/hr})$.

† From Ref. 2, page 6.5.2-10 (except units conversion factor C).

†† Calculated using linearly interpolated values and $D = .1829$ cm.

Form GQ-3.08.1 Rev. 2

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 16 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4.3.2 Spray Flow Rate of 2615 GPM (One Pump)

The following table presents the calculation of the elemental iodine spray removal rate, λ_s , for one spray pump operating (accident time 15 to 53 minutes).

Variable	Case 2 SPIRT Results *		Linearly Interpolated for D = .1405 cm **
	at Drop Diameters (D) of		
	D = .1382 cm	D = .1539 cm	
h (input)	147. ft.	147. ft.	—
v (calculated)	374.8 cm/sec	395.5 cm/sec	—
$T = h/v$.39221 ft·sec/cm	.37168 ft·sec/cm	.38920 ft·sec/cm
k_g (calculated)	5.944 cm/sec	5.740 cm/sec	5.914 cm/sec
V (input)	2.736 + 6 ft ³	2.736 + 6 ft ³	2.736 + 6 ft ³
F (input)	2615. gpm	2615. gpm	2615. gpm
C ***	244.4	244.4	244.4
$\lambda_s = C \frac{6k_g T F}{V D} \dagger$	23.64 hr ⁻¹	19.43 hr ⁻¹	22.96 hr ⁻¹ ††

* see attached microfiche A.

** Mass mean diameter (volume) from final SPIRT temporal distribution; see microfiche A.

*** Units conversion factor, $\text{cm} \cdot \text{ft}^2 \cdot \text{min} / (\text{gal} \cdot \text{hr})$ from $(30.48 \text{ cm/ft})(.13365 \text{ ft}^3/\text{gal})(60 \text{ min/hr})$.

† From Rep. 2, page 6.5.2-10 (except units conversion factor C).

†† Calculated using linearly interpolated values and D = .1405 cm.

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. <u>2I-5-91</u>	
Rev. <u>0</u>	Date
Page <u>17</u>	of

Client
Project
Proj. No. <u>7805-11</u> Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4.3.3 Elemental Iodine Spray Removal Summary

The SPIRT calculated parameters are now summarized for each flow rate.

Variable	Two Spray Pumps, 5230. gpm	One Spray Pump, 2615. gpm
Mass mean drop size diameter, D	.1829 cm. or 1829 μ	.1405 cm. or 1405 μ
Drop fall time, T	10.403 sec. or .1734 min.	11.863 sec. or .1977 min.
Mass transfer coefficient, K_g	5.437 cm/sec or 10.70 ft/min.	5.914 cm/sec or 11.64 ft/min.

The following table presents the elemental iodine spray removal rates that were obtained.

TABLE 1
Elemental Iodine Spray Removal Rates

Spray Flow Rate	Calculated Rate	To Be Used Rate
5230 gpm (two pumps) ; $0 \leq t \leq 15$ minutes [†]	28.44 hr ⁻¹	20. hr ⁻¹ *
2615 gpm (one pump) ; $15 < t \leq 53$ minutes [†]	22.96 hr ⁻¹	20. hr ⁻¹ *

* Spray removal rate for elemental iodine is limited to 20. hr⁻¹ by Reference 2, p. 6.5.2-11.
[†] subject to the DF=200. constraint (Section 4.4)

Form GQ-3.08.1 Rev. 2



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 18	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4.4 Elemental Iodine Spray Decontamination Factor

The elemental iodine spray decontamination factor is given by

$$(DF) = 1 + HV_s / (V - V_s) \quad (\text{Ref. 2, p. 6.5.2-12})$$

where H = partition coefficient = 10,000 (Subsection 4.2.1)
 V = containment free volume = 2.736 + 6 ft³ (Section 2.2)
 V_s = water volume in sump

V_s is comprised of:

- RWST tank minimum volume = 350,000 gal. Ref. 11, Table 6.2-4
- Accumulators volume = 25,436 gal. Ref. 11, Table 6.2-2
- Boron Injection Tank Volume = 900 gal. Ref. 11, Table 6.2-3
- Reactor coolant Volume = 95,000 gal. Ref. 11, p. 14A.8-1*
- Spray additive Tank Volume = 2,500 gal. Ref. 11, p. 6.4-2

Total Sump Volume $V_s = 473,936$ gal

$V_s = 63342$ ft³

$$(DF) = 1 + 10000 * 63342 / (2.736 + 6 - 63342)$$

$$(DF) = 238.0$$

But Ref 2, p. 6.5.2-12 limits the (DF) to 200; therefore

$$(DF) = 200.$$

* Reference gives 12,760. ft³ which is 95,470. gal. then rounded to 95,000 gal.

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. 21-5-91	
Rev. 0	Date
Page 19	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4.5 Elemental Iodine Wall Deposition Rate

The elemental iodine wall deposition rate is given as

$$\lambda_w = K_w A_w / V, \text{ Reference 2, p. 6.5.2-10}$$

where

A_w = wetted surface area, ft^2

V = containment free volume = $2.736 \times 10^6 \text{ ft}^3$

Ref. 9, Table 14.3.2-5(1)

and $K_w = 4.9 \text{ m/hr}$, Reference 2, p. 6.5.2-10.

(a units conversion factor is also required.)

Reference 9, Tables 14.3.2-5(1), 14.3.2-5(2), and 14.3.4-8 provide structural heat sink areas in the primary containment. These tables are attached as the next three pages of this calculation. When the individual areas, omitting the 15500 ft^2 floor area which is assumed flooded, are added, the total area is found to be 449211 ft^2 . All of this area may not be wetted. There is no way to determine the amount of dry area (if any). Any smaller area than this total area would give a conservatively smaller λ_w (less wall deposition implies more leakage to environment and higher doses). This calculation will arbitrarily assume an $A_w = 410,000 \text{ ft}^2$. Then,

$$\lambda_w = [4.9 \frac{\text{m}}{\text{hr}} * (410,000 \text{ ft}^2) / (2.736 \times 10^6 \text{ ft}^3)] / .3048 \frac{\text{m}}{\text{ft}}$$

$$\lambda_w = 2.41 \text{ hr}^{-1}$$

The accuracy of λ_w is not important because it is always added to λ_s (20 hr^{-1}) (Section 4.3) and $\lambda_s + \lambda_w$ is effective only until a DF of 200 is reached (Section 4.4 & 4.6) no matter how small λ_w is.

TABLE 14.3.2-5(1)

CONTAINMENT DATA

Calc. No. ZI-5-91
Rev. 0
Page 20
Proj. No. 7805-11 Safety-Related
2.736 x 10 ⁶ ft ³

NET FREE VOLUME

INITIAL CONDITIONS

Pressure	14.7 psia
Temperature	90°F
RWST Temperature	62°F
Service Water Temperature	33°F
Outside Temperature	-10°F

SPRAY SYSTEM

Number of Pumps Operating	3
Runout Flow Rate	3600 gpm/each
Actuation Time	45.0 seconds

SAFEGUARDS FAN COOLERS

Number of Fan Coolers	5
Fastest Post-Accident Initiation of Fan Coolers	38 sec

STRUCTURAL HEAT SINKS

<u>Structure Thickness (in)</u>	<u>Area (ft²)</u>
Painted Containment Cylinder .25 steel, 12 concrete; .004 paint	54447
Painted Containment Dome .25 steel, 12 concrete; .004 paint	15026
Containment Floor 18 concrete	15500
Reactor Cavity .25 steel, 12 concrete	2000
Crane Wall, Operating Deck 12 concrete	36000
Shield Walls 9 concrete	7000

Revision 2
June 30, 1990

Calc. No. ZI-5-91
 Rev. 0
 Page 21
 Proj. No. 7805-11
 Safety-Related

TABLE 14.3.2-5 (2)

CONTAINMENT DATA

<u>Thickness (in.)</u>	<u>Area (Ft²)</u>
Refueling Canal .25 steel, 12 concrete	16000
Misc. Steel Structures .25 steel	54860
Misc. Painted Steel .375 steel; .004 paint	89300
Misc. Stiffeners 0.6249 steel	1060
5.25 steel, 12 concrete	1147
.64 steel, 12 concrete	1400
10.51 steel, 12 concrete	186
24.51 steel, 12 concrete	54
.75 steel, 12 concrete	440
7.287 steel, 12 concrete	603.94
12.0308 steel, 12 concrete	180.93
Unpainted Containment Cylinder 0.25 steel, 12 concrete	14862.
Unpainted Containment Dome 0.25 steel, 12 concrete	3712
Unpainted Misc. Steel 0.375 steel	32000

Calc. No. 21-5-91
Rev. 0
Page 22
Proj. No. 7805-11
Safety-Related

TABLE 14.3.4-8

ADDITIONAL STRUCTURAL HEAT SINKS

	<u>Exposed Surface (ft²)</u>	<u>Thickness (inches)</u>
Accumulator Tanks	576	2-3/4
	404	3/8
	260	1-13/32
Ducts	7300	1/4
Fan Coolers	11,760	3/8
Polar Crane	40,000	3/8*
Duct	2050	1/4
CRDM Missile Shield Support Beams	1,913	3/8*
Cable Pan Structural Framing	2,279	3/8*
Steam Generator and Reactor Coolant Pump Supports	14,794	3/8*
Galleries	37,596	3/8*

*Both sides exposed

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 23 of	

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4.6 Calculation of Elemental Iodine Spray Time (Effective)

The following is a calculation of the spray time for which the elemental iodine spray removal rate is effective. The removal rate should be the sum of λ_s (spray removal rate, see Subsection 4.3.3) and λ_w (wall deposition rate, see Section 4.5). This idea is obtained by the following considerations.

- if λ_w is omitted the spray time will be too long (nonconservative) because the (DF) will not be reached at proper time (removal from the air is too small).
- if λ_w is included the spray time will be too short (conservative) because the (DF) will be reached before the proper time (removal by λ_w was to the wall and not to the water).
- Radiodecay should not be included because that rate occurs both in the air and in the water and, thus, does not affect the concentration ratio.
- Leakage from the primary containment can be ignored because it is (comparatively) negligible.

Thus, to be conservative the removal rate λ_R to be used in the calculation of the elemental iodine spray time is

$$\lambda_R = \lambda_s + \lambda_w$$

$$\lambda_R = 20. + 2.41 = 22.41 \text{ hr}^{-1} \quad (\text{two spray pumps})$$

$$\lambda_R = 20. + 2.41 = 22.41 \text{ hr}^{-1} \quad (\text{one spray pump}).$$

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. 7805-11	Approved by	Date
Equip. No.		

As in Reference 7, the primary containment is described by a two compartment model - an unsprayed volume and a sprayed volume. The sprayed volume is assumed to be 85% of the total volume.

Primary Containment total volume = $2.736+6 \text{ ft}^3$ (Ref. 9, Table 14.3.2.5(1))

Unsprayed volume, $V_1 = .15 \times 2.736+6 = 4.104+5 \text{ ft}^3$

Sprayed Volume, $V_2 = .85 \times 2.736+6 = 2.3256+6 \text{ ft}^3$

The Reactor Containment Fan Coolers provide mixing between the two volumes. The flow rate for each fan is 66,000 cfm (Reference 19). During accident conditions three of the five fans must operate (Reference 19). Therefore, the flow rate for containment mixing is

$$3 \times 66,000 = 198,000 \text{ cfm.}$$

Subsections 6.1.4 and 6.1.7 of Reference 19 contain the referenced information.



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 25 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

The methodology for calculating the spray time is given in Reference 7, pp. 9, 10, and 27.

Assumption: the initial activity release is into the unsprayed volume (conservative); thus, $a_2(0) = 0.0$

Data:

$$Q_{12} = Q_{21} = 1.98 + 5 \text{ cfm}$$

$$S = \lambda_R = 22.41 \text{ hr}^{-1}$$

$$V_1 = .15 * (2.736 + 6) = 4.104 + 5 \text{ ft}^3 \text{ (unsprayed)}$$

$$V_2 = .85 * (2.736 + 6) = 2.3256 + 6 \text{ ft}^3 \text{ (sprayed)}$$

$$l_1 = (Q_{12} / V_1) * 60 \frac{\text{min}}{\text{hr}} = 28.94736842 \text{ hr}^{-1}$$

$$m_1 = \lambda + L + P + l_1 = 28.94736842 \text{ hr}^{-1}$$

($\lambda, L, \text{ and } P \equiv 0.0$)

$$l_2 = (Q_{21} / V_2) * 60 \frac{\text{min}}{\text{hr}} = 5.108359133 \text{ hr}^{-1}$$

$$m_2 = \lambda + L + P + S + l_2 = 27.51835913 \text{ hr}^{-1}$$

$$\mu_a = \frac{1}{2} \left[-(m_1 + m_2) + \sqrt{(m_1 + m_2)^2 - 4(m_1 m_2 - l_1 l_2)} \right] = -16.05156373$$

$$\mu_b = \frac{1}{2} \left[-(m_1 + m_2) - \sqrt{(m_1 + m_2)^2 - 4(m_1 m_2 - l_1 l_2)} \right] = -40.41416382$$

Since the fraction of the activity remaining airborne is independent of the initial activity, set

$$a_1(0) = 1.0 \text{ (initial activity release in unsprayed volume)}$$

Then,

$$C_a = -(\mu_b + m_1) / (\mu_a - \mu_b) = .4706720694$$

$$C_b = (\mu_a + m_1) / (\mu_a - \mu_b) = .5293279306$$

$$C_{a1} = C_a (\mu_a + m_1) / l_2 = 1.188188794$$

$$C_{b1} = C_b (\mu_b + m_1) / l_2 = -1.188188794$$

Form G.O.3.06.1 Rev. 2

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. 7805-11
Rev. 0 Date
Page 26 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Therefore,

$$a_1(t) = .4706720694 e^{-16.05156373 t} + .5293279306 e^{-40.41416382 t}$$

$$a_2(t) = 1.188188794 e^{-16.05156373 t} - 1.188188794 e^{-40.41416382 t}$$

The fraction remaining airborne is just

$$F_R(t) = a_1(t) + a_2(t)$$

and the decontamination factor is

$$DF(t) = 1.0 / F_R(t)$$

The above equations (this page) must be solved for t_c (spray effectiveness cutoff time) at which $DF(t_c) = 200$ (see Section 4.4). The procedure is illustrated in the following table.

Estimated Time, t		$a_1(t)$	$a_2(t)$	$F_R(t)$	$DF(t)$
Minutes	Hours				
15	.25	8.531912210-3	2.143506148-2	2.996697369-2	33.37007
20	.3333333333	2.234404222-3	5.637083632-2	2.871487854-3	127.04079
21.697	.3616166667	1.418807125-3	3.580574193-3	4.999381319-3	200.02475
21.69654	.3616090000	1.418977985-3	3.581005175-3	4.999983160-3	200.000

Therefore, the spray effectiveness cutoff time is

$$t_c = .361609 \text{ hr for elemental iodine. (less than the 53 minute spray operating time).}$$



Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 27	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4.7 Particulate Iodine Spray Removal Rate

4.7.1 Spray Flow Rate of 5230 GPM (Two Pumps)

The particulate iodine spray removal rate, λ_p , is given by

$$\lambda_p = \frac{3hF}{2V} \left(\frac{E}{D} \right) \quad (\text{Ref. 2, p. 6.5.2-11})$$

where

h = spray drop fall height = 44.8 m. (147 ft)

F = spray flow rate = 5230 gpm

$\left(\frac{E}{D} \right) = 10. \text{ m}^{-1}$ until a decontamination factor of 50 is reached (Ref. 2, p. 6.5.2-12)

and V = containment free volume = 2.736 + 6 ft³

Then,

$$\lambda_p = \frac{3 * 44.8 (\text{m}) * 5230. \left(\frac{\text{gal.}}{\text{min.}} \right) * 10. \left(\frac{1}{\text{m}} \right) * 1.3365 \left(\frac{\text{ft}^3}{\text{gal.}} \right) * 60. \left(\frac{\text{min.}}{\text{hr}} \right)}{2 * 2.736 + 6 (\text{ft}^3)}$$

$\lambda_p = 10.3 \text{ hr}^{-1}$ until a decontamination factor of 50 is reached or until the spray flow rate is changed or until spray injection stops, whichever is first.



Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. <u>ZI-5-91</u>	
Rev. <u>0</u>	Date
Page <u>28</u>	of

Client
Project
Proj. No. <u>7805-11</u> Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4.7.2 Spray Flow Rate of 2615 GPM (One Pump)

As in the previous Subsection, the particulate iodine spray removal rate can be calculated for a spray flow rate, $F = 2615 \text{ gpm}$; thus,

$$\lambda_p = \frac{3 * 44.8 \text{ (m)} * 2615. \left(\frac{\text{gal}}{\text{min}}\right) * 10. \left(\frac{\text{L}}{\text{m}}\right) * 1.3365 \left(\frac{\text{ft}^3}{\text{gal}}\right) * 60. \left(\frac{\text{min}}{\text{hr}}\right)}{2 * 2.7366 \text{ (ft}^3\text{)}}$$

$\lambda_p = 5.15 \text{ hr}^{-1}$ until a decontamination factor of 50 is reached or until spray injection stops, whichever is first.

4.7.3 Particulate Iodine Spray Removal Summary

The following table presents the particulate iodine spray removal rates that were obtained

TABLE 2

Particulate Iodine Spray Removal Rates

Spray Flow Rate	To Be Used Rate
5230. gpm (two pumps); $0 \leq t \leq 15 \text{ minutes}^*$	10.3 hr^{-1}
2615. gpm (one pump); $15 \leq t \leq 53 \text{ minutes}^*$	5.15 hr^{-1}

* subject to the DF=50 constraint (Ref. 2, p. 6.5.2-12).

Form GQ-3.08.1 Rev. 2

Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 29 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4.7.4 Calculation of Particulate Iodine Spray Time (Effective)

The following is a calculation of the spray time for which the particulate iodine spray removal is effective. The spray removal rates for two time intervals should be the values given in Table 2 (Subsection 4.7.3). Radiodecay should not be included because the particulate iodine spray removal theory is based on aerosol mechanics which are not affected by radiodecay (radiodecay does not remove particles). Leakage from the primary containment can be ignored because it is (comparitively) negligible.

The methodology for calculating the spray time is given in Reference 7, pp. 9, 10, and 27.

Assumption: the initial activity release is into the unsprayed volume (conservative); thus, $a_2(0) = 0.0$

Data:

$$Q_{12} = Q_{21} = 1.98 + 5 \text{ cfm Section 4.6}$$

$$S = \lambda_p = 10.3 \text{ hr}^{-1} \quad (0 \leq t \leq 15 \text{ minutes})$$

$$S = \lambda_p = 5.15 \text{ hr}^{-1} \quad (15 < t \leq 53 \text{ minutes})$$

$$V_1 = .15 * (2.736 + 6) = 4.104 + 5 \text{ ft}^3$$

$$V_2 = .85 * (2.736 + 6) = 2.3256 + 6 \text{ ft}^3$$

$$l_1 = (Q_{12} / V_1) * 60 \frac{\text{min}}{\text{hr}} = 28.94736842 \text{ hr}^{-1}$$

$$m_1 = \lambda + L + P + l_1 = 28.94736842 \text{ hr}^{-1}$$

($\lambda, L, \text{ and } P \equiv 0.0$)

$$l_2 = (Q_{21} / V_2) * 60 \frac{\text{min}}{\text{hr}} = 5.108359133 \text{ hr}^{-1}$$

$$m_2 = \lambda + L + P + S + l_2 = 15.40835913 \text{ hr}^{-1} \quad (0 \leq t \leq 15 \text{ min.})$$

$$m_2 = \lambda + L + P + S + l_2 = 10.25835913 \text{ hr}^{-1} \quad (15 < t \leq 53 \text{ min.})$$

Form GQ-3.08.1 Rev. 2



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 30 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Variable	Calculated Values	
	$0 \leq t \leq 15 \text{ min.}$	$15 < t \leq 53 \text{ min.}$
$\mu_a = \frac{1}{2} [-(m_1+m_2) + \sqrt{(m_1+m_2)^2 - 4(m_1 m_2 - l_1 l_2)}]$	$-8.260258129 \text{ hr}^{-1}$	$-4.266849924 \text{ hr}^{-1}$
$\mu_b = \frac{1}{2} [-(m_1+m_2) - \sqrt{(m_1+m_2)^2 - 4(m_1 m_2 - l_1 l_2)}]$	$-36.09546943 \text{ hr}^{-1}$	$-34.93887763 \text{ hr}^{-1}$
t_1 (beginning of time period)	0	0.25 hr.
$a_1(t_1)$ (initial condition)	1.0	$3.265447579 \cdot 2^*$
$a_2(t_1)$ (initial condition)	0.0	$1.317514968 \cdot 1^*$
$C_a = [l_2 a_2(t_1) - (\mu_b + m_1) a_1(t_1)] / [\mu_a - \mu_b]$	0.2568006734	$2.832168654 \cdot 2$
$C_b = [(\mu_a + m_1) a_1(t_1) - l_2 a_2(t_1)] / [\mu_a - \mu_b]$	0.7431993266	$4.332789253 \cdot 3$
$C_{a1} = C_a (\mu_a + m_1) / l_2$	1.039955045	0.1368333530
$C_{b1} = C_b (\mu_b + m_1) / l_2$	-1.039955045	$-5.081856234 \cdot 3$

* obtained from the equations for $a_1(t)$ and $a_2(t)$ (see next page) evaluated at 0.25 hr (15 minutes) using the data in the $0 \leq t \leq 15 \text{ min}$ column.

Form GO-3.08.1 Rev. 2

Client	
Project	
Proj. No. <u>7805-11</u>	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

For $0 \leq t \leq .25$ hr (15 minutes):

$$a_1(t) = .2568006734 e^{-8.260258129t} + .7431993266 e^{-36.09546943t}$$

$$a_2(t) = 1.039955045 e^{-8.260258129t} - 1.039955045 e^{-36.09546943t}$$

For $.25 < t \leq .8833$ hr (53 minutes):

$$a_1(t) = (2.832168654 - 2) e^{-4.266849924(t-.25)} + (4.332789253 - 3) e^{-34.93887763(t-.25)}$$

$$a_2(t) = .1368333530 e^{-4.266849924(t-.25)} - (5.081856234 - 3) e^{-34.93887763(t-.25)}$$

The fraction remaining airborne is just $F_R(t) = a_1(t) + a_2(t)$, and the decontamination factor is $DF(t) = 1.0 / F_R(t)$.

The above equations (this page) must be solved for t_c (spray effectiveness cutoff time) at which $DF(t_c) = 50$. (Ref. 2, p. 6.5.2-12). Thus,

Form GO-3.06.1 Rev. 2

Estimated Time, t		$a_1(t)$	$a_2(t)$	$F_R(t)$	$DF(t)$
Minutes	Hours				
15	.25	3.265447579-2	1.317514968-1	1.644059725-1	6.0825
40	.666666667	4.786378713-3	2.312489040-2	2.791126912-2	35.82782
44.687	.7447833333	3.429661715-3	1.657006155-2	1.999972326-2	50.00069
44.6868	.7447800000	3.429710494-3	1.657029722-2	2.000000772-2	49.99998

Therefore, the spray effectiveness cutoff time is

$$t_c = .74478 \text{ hr for particulate iodine (less than the 53 minute spray operating time).}$$



Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 32 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

4.7.5 POSTDBA Effective Spray Removal Rate for Particulate Iodine

Program POSTDBA (References 7 and 8) can accommodate only one spray removal rate for each iodine species. Since the particulate iodine spray removal rate changes at 15 minutes into the accident, POSTDBA cannot model the conditions. However, if a spray removal rate can be found which achieves a DF of 50 at the spray effectiveness cutoff time ($t_c = .74478$ hr, see Subsection 4.7.4), that removal rate would be conservative because at all times between 0 and .74478 hr, the airborne activity (particulate) would be higher than that using the correct model. At and after .74478 hr, the airborne activity (particulate) would be the same as that using the correct model.

Such a removal rate can be found by evaluating the equations given in Subsection 4.7.4 with $t_1 = 0.0$

$t = .74478$ hr

$a_1(t_1) = 1.0$

$a_2(t_1) = 0.0$

and iterating on the spray removal rate, S , (instead of on the time) until a DF = 50 is reached.

The data from Subsection 4.7.4 can be used:

$l_1 = 28.94736842$ hr⁻¹

$m_1 = 28.94736842$ hr⁻¹

$l_2 = 5.108359133$ hr⁻¹

But

$m_2 = S + 5.108359133$ hr⁻¹

$a_1(t) = C_a e^{u_a t} + C_b e^{u_b t}$

$a_2(t) = C_{a1} e^{u_a t} + C_{b1} e^{u_b t}$

Form GQ-3.00.1 Rev. 2

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 33 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Iteration Index	S, hr^{-1}	M_a	M_{at}	$e^{M_{at}}$
1	6.6	-5.422515269	-4.038580922	1.762246233-2
2	6.67	-5.477727774	-4.079702092	1.691250328-2
3	6.672	-5.479304468	-4.080876382	1.689265475-2
4	6.6721	-5.479383302	-4.080935096	1.689166294-2
5	6.67217	-5.479438485	-4.080976195	1.689096873-2

Iteration Index	M_b	M_{bt}	$e^{M_{bt}}$	C_a
1	-35.23321229	-26.24099185	4.014967556-12	.2108586680
2	-35.24799978	-26.25200528	3.970991612-12	.2116417128
3	-35.24842309	-26.25232055	3.969739864-12	.2116641324
4	-35.24844425	-26.25233631	3.969677303-12	.2116652535
5	-35.24845907	-26.25234735	3.969633487-12	.2116660382

Iteration Index	C_b	C_{a1}	C_{b1}	$a_1(t)$
1	.7891413320	.9710396374	-.9710396374	3.715848937-3
2	.7883582872	.9723582107	-.9723582107	3.579391166-3
3	.7883358676	.9723958842	-.9723958842	3.575569115-3
4	.7883347465	.9723977679	-.9723977679	3.575378123-3
5	.7883339618	.9723990864	-.9723990864	3.575244435-3

Iteration Index	$a_2(t)$	$F_R(t)$	$DF(t)$
1	1.711210943-2	2.082795837-2	48.01238712
2	1.644501143-2	2.002440259-2	49.93906786
3	1.642634795-2	2.000191706-2	49.99520780
4	1.642541534-2	2.000079347-2	49.99801641
5	1.642476255-2	2.000000699-2	49.99998253

Form GO-3.06.1 Rev. 2



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No.	ZI-5-91		
Rev.	0	Date	
Page	34	of	

Client			
Project			
Proj. No.	7805-11	Equip. No.	

Prepared by		Date	
Reviewed by		Date	
Approved by		Date	

From the foregoing, a POSTDBA effective spray removal rate of

$$S = 6.67217 \text{ hr}^{-1}$$

will achieve a DF of 50 at the spray effectiveness cutoff time of .74478 hr.



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 35	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

5. CONTROL ROOM FINITE CLOUD CORRECTION FACTORS

The control room finite cloud correction factors for whole body dose that are required in Section 6 are calculated in a separate POSTDBA run.

5.1 Data

The control room dimensions are 47 ft 9 in wide by 106 ft long by 24 ft 3 in high (Reference 16). The dose point is conservatively selected at 6 feet above the center of the floor. The center of the floor is at

$$\frac{1}{2} \times 106 = 53 \text{ ft in the long dimension}$$

$$\frac{1}{2} \times 47.75 = 23.875 \text{ ft. in the wide dimension.}$$

Calculations were performed for each nuclide used in Section 6.

Discrete gamma energies and frequencies for the radiodecay of each nuclide are from Reference 20; values are discussed in the next section (Section 5.2).

5.2 POSTDBA Input

POSTDBA input instructions are in Reference 8. The input listing is found on the attached microfiche (Microfiche B):

ZI-5-91 RD SR NSLD 4C4-A1 SYS CR CNTRL RM INFILT STDY (CLOUD)

S&L 03/11/91 10:26:56 WQ=212 ID=DRSH

ORIG=05 DUPS=01 PRJ=ZIO780511 PGM=POS098085110/

Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 36 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

The input description is as follows.

Line 1 Format (9I5, 3A6) (POSTDBA Card 1)

$IP = 0$
 $ISPRAY = 3$
 $MURF = 1$
 $ICONT = 1$
 $ICI = 0$

} not used in the calculation

$IC2 = 2$ Calculate finite cloud correction factors for control room and quit (no dose calculations).

$IC3 = 0$ not used in the calculation

$MET = 0$ read nuclide discrete gamma energies (and frequencies)

$INL = 0$ not used in the calculation

$(ISTAT(I), I=1,3) = ZION 7805-11$ literal station name and charge number.

Lines 2 through 133 (POSTDBA Cards 23 through 26 repeated as a group for each nuclide)
 Nuclide discrete gamma energy data

Line 134 Format (3A6) (POSTDBA Card 23)
 $(TI(I), I=1,3) = \text{blank}$ (no nuclide name)

Line 135 Format (I10) (POSTDBA Card 24)
 $NI = 0$ signals end of nuclide data.



Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 37	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Line 136 Format (I10) (POSTDBA Card 27)

IREC = 1 use a rectangular parallelepiped room

Line 137 Format (6E10.2) (POSTDBA Card 28 for IREC = 1)

$XL = 53.0$	center of floor in length dimension	} ft.
$XL = 106.0$	room (floor) length	
$WL = 23.875$	center of floor in width dimension	
$W = 47.75$	room (floor) width	
$H(1) = 6.0$	dose point height above floor	
$H(2) = 18.25$	dose point distance below ceiling: Room height 24.25 - 6.0 above floor	

Line 138 Format (4I10) (POSTDBA Card 29)

$NORJA = 6$	} Reference 8, p.40, recommended values.
$NHA = 4$	
$NORJG = 6$	
$NHG = 2$	

Form GO-3.0B.1 Rev. 2

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 38	of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

5.3 POSTDBA Output

The POSTDBA output for the finite cloud correction factors calculation can be found in the attached microfiche B. The results are given in the following table.

TABLE 3

Control Room Finite Cloud Correction Factors (Dose Ratios)

<u>Nuclide</u>	<u>Infinite to Finite Gamma Cloud Dose Ratio</u>
I-131	16.65
I-132	18.10
I-133	17.46
I-134	18.55
I-135	20.04
XE-133M	6.701
XE-133	7.976
XE-135M	16.55
XE-135	16.49
KR-85M	15.08
KR-85	17.07
KR-87	20.85
KR-88	21.86

Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 39 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

6. CONTROL ROOM DOSE CALCULATIONS

6.1 Preliminary Calculations

6.1.1 Calculation of POSTDBA Effective Windspeeds.

The POSTDBA effective windspeeds and, thus, the control room ($\frac{1}{2}$'s) are based on the default parameters and diffuse source-point receptor ($\frac{1}{2}$ ') equation given in Reference 4. The default parameters are given as ($\frac{1}{2}$ ') reduction factors for four time periods (Ref. 4, Table 1). Reference 4, also, suggests a wind speed of 1.0 m/sec for the five percentile case (0. to 8 hours). Thus, since ($\frac{1}{2}$ ') is inversely proportional to windspeed, the reciprocal of the overall reduction factor can be thought of as a windspeed including wind direction and occupancy. Then, from Reference 4,

Time Period, Hours	Overall Reduction Factor, R	Wind Speed, m/sec, $u = 1/R$
0-8	1.0	1.0
8-24	.59	1.695
24-96	.225 *	4.444
96-720	.066	15.15

* In Ref. 4, Table 1, the product of the individual reduction factors gives .225 which will not be rounded to .22.

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 40 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

From Reference 4, for only one inlet,

$$\left(\frac{V}{Q'}\right) = \frac{(K+2)}{uA}, \quad (\sigma_y \text{ and } \sigma_z \text{ are negligible for Class F})$$

where A = projected area, m^2 , of containment building

$$K = 3 / \left[(\Delta/d)^{1.4} \right]$$

Δ = distance between containment surface and inlet
 d = diameter of containment (outside diameter)

From Reference 7,

$$\left(\frac{V}{Q'}\right) = \frac{2}{\bar{u}_{eff} A}$$

where \bar{u}_{eff} = an effective windspeed to give the correct $\left(\frac{V}{Q'}\right)$.

Then,

$$\frac{2}{\bar{u}_{eff} A} = \frac{K+2}{uA}$$

$$\bar{u}_{eff} = 2u / (K+2), \quad (\text{POSTDBA effective wind speed})$$

\bar{u}_{eff} for each time period must be input to POSTDBA so that that program can calculate the correct $\left(\frac{V}{Q'}\right)$. These input data are dependent on the separation distance, Δ .



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 41	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

6.1.1.1 Plan View Separation Distance

The plan view separation distance was given as $e = 91.76$ ft. (Ref. 14, p. 13)
 The containment outside diameter was given as $d = 147$ ft. (Ref. 14, p. 12)

Then, $K = 3 / [(91.76/147)^{1.4}] = 5.8030$

$\bar{u}_{eff} = 2u / (5.8030 + 2)$

$\bar{u}_{eff} = .25631u$ (see Subsection 6.1.1 for u)

The evaluation of \bar{u}_{eff} for various time periods according to Reference 4 is presented in the following table.

TABLE 4

POSTDBA Effective Windspeeds for Plan View Separation Distance

Ref. 4 Time Period, Hours	Ref. 4 Wind Speed, u , m/sec *	POSTDBA $\bar{u}_{eff} = .25631u$, m/sec	Occupancy Ref. 4, Occ.	Full Occupancy Control Room $(\sqrt{Q'})$, sec/m ³ **
0-8	1.0	.2563	1.0	3.177×10^{-3}
8-24	1.695	.4344	1.0	1.875×10^{-3}
24-96	4.444	1.139	.60	1.192×10^{-3}
96-720	15.15	3.883	.40	5.243×10^{-4}

* including speed, direction, and occupancy (see Subsection 6.1.1).
 ** $(\sqrt{Q'}) = 2 / [Occ. * \bar{u}_{eff} * A]$ where $A = 2456$ m² (Ref. 14, p. 18)
 (division by Occ. to remove Occ. from \bar{u}_{eff}). This $(\sqrt{Q'})$ is given for information only.

Form G0.3.06.1 Rev. 2

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 42 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

6.1.1.2 Circuitous Path Separation Distance

The circuitous path separation distance was given as $\Delta = 80. \text{m} \stackrel{\text{(Ref. 15, p. 2-26)}}{=} 262.5 \text{ ft.}$
 The containment outside diameter was given as $d = 147. \text{ ft.}$ (Ref. 14, p. 12)

Then,
$$K = 3 / \left[\left(\frac{262.5}{147.} \right)^{1.4} \right] = 1.3322$$

$$\bar{u}_{\text{eff}} = 2u / (1.3322 + 2)$$

$$\bar{u}_{\text{eff}} = .60020 u \quad (\text{see Subsection 6.1.1 for } u)$$

The evaluation of \bar{u}_{eff} for various time periods according to Reference 4 is presented in the following table.

TABLE 5

POSTDBA Effective Windspeeds for Circuitous Path Separation Distance

Ref. 4 Time Period, Hours	Ref. 4 Wind Speed, $u, \text{ m/sec}^*$	POSTDBA $\bar{u}_{\text{eff}} = .60020 u,$ m/sec	Ref. 4 Occupancy, Occ.	Full Occupancy Control Room $(\sqrt[3]{Q'})$, sec/m^3 **
0-8	1.0	.6002	1.0	1.357×10^{-3}
8-24	1.695	1.0173	1.0	8.005×10^{-4}
24-96	4.444	2.667	.60	5.089×10^{-4}
96-720	15.15	9.093	.40	2.239×10^{-4}

* including speed, direction, and occupancy (see Subsection 6.1.1).
 ** $(\sqrt[3]{Q'}) = 2 / [\text{Occ.} * \bar{u}_{\text{eff}} * A]$ where $A = 2456. \text{ m}^2$, (Ref. 14, p. 18)
 (division by Occ. to remove Occ. from \bar{u}_{eff}). This $(\sqrt[3]{Q'})$ is given for information only.

Form GO-3.08.1 Rev. 2

Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 43 of	

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

6.1.2 ECCS Leakage

6.1.2.1 ECCS Leak Rate (POSTDBA Purge Rate)

The ECCS leak rate is 1770 cc/hr (Ref. 11, Table 6.2.3-4). Two times this leak rate should be used in the calculations (Ref. 5, p. 15.6.5-17). Hence, the leak rate is 3540 cc/hr. Since ESF atmosphere filtration is provided (Ref. 11, p. 9.10-3), potential leakage from a gross failure of passive components need not be considered (Ref. 5, p. 15.6.5-17). Then,

$$3540 \frac{\text{cm}^3}{\text{hr}} \times \frac{1 \text{ m}^3}{10^6 \text{ cm}^3} \times 264.2 \frac{\text{gal.}}{\text{m}^3} = .9353 \text{ gal./hr.}$$

The sump water volume in which the iodine activity resides is 473,936 gal. (see Section 4.4). Thus, the ECCS leak rate is

$$.9353 \frac{\text{gal.}}{\text{hr}} / 473936 \text{ gal.} = 1.97347 \times 10^{-6} \text{ hr}^{-1}$$

$$1.97347 \times 10^{-6} \text{ hr}^{-1} \times \frac{1 \text{ hr}}{60 \text{ min.}} = 3.2891 \times 10^{-8} \text{ min.}^{-1}$$

In POSTDBA this ECCS leakage can be modelled by a containment purge in which the purge rate P is given by

$$P = 3.2891 \times 10^{-8} \text{ min.}^{-1} V \text{ ft}^3 \text{ where } V = \text{free volume of containment.}$$

But $V = 2.736 \times 10^6 \text{ ft}^3$; therefore,

$$P = .08999 \text{ cfm.}$$

However, the injection phase of the ECCS lasts 15 minutes (see Section 4.1). Thus, the ECCS leak rate is zero for the first 15 minutes ($P=0.0$). It will be conservatively assumed that the recirculation phase starts at 15 minutes ($P=.08999 \text{ cfm}$) and lasts for 30 days. (The containment leak rate in POSTDBA must be set to zero.)



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. 21-5-91	
Rev. 0	Date
Page 44	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

6.1.2.2 Effective POSTDBA Purge Filter Efficiency

Since the sump water is less than 212 °F*, 10% of the iodine in the ECCS leakage becomes airborne (Ref 5, page 15.6.5-17). This is the conservative maximum amount. The airborne iodine is instantaneously exhausted (conservative) to the atmosphere through a 90% efficient filter (Ref. 11, Vol. VIII, @ 9.8, page 3). These iodine reduction capabilities can be effected in POSTDBA by setting the POSTDBA purge filter fractional efficiency E_p so that

$$(1 - E_p) = (1 - E) F_p$$

where E = actual filter efficiency (fractional) = .90
 F_p = iodine fraction airborne = .10

Then,

$$E_p = 1 - F_p + F_p E$$

$$E_p = 1 - .10 + .10 \times .90$$

$$E_p = .99$$

* Reference 9, Subsection 14.3.5.6.3, page 14.3-46 gives a sump water temperature of 200 °F.

Form GO-3.08.1 Rev. 2

Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 45 of	

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

6.1.3 Nuclide Data

6.1.3.1 Initial Airborne Activity in Primary Containment

Table 6 presents the calculation of initial airborne activity in the primary containment for releases based on both core and gap inventory.

6.1.3.2 Nuclide Data Adjustments

Thyroid inhalation doses based on adult thyroid dose conversion factors from both Reference 21, page 1.109-45, and Reference 22*, Table 2.1, page 136 were desired. However, the thyroid inhalation dose conversion factors are built-in to program POSTDBA and cannot be changed. Since for each iodine nuclide the thyroid dose is proportional to this factor and proportional to the initial airborne activity in the containment, the initial airborne activity can be multiplied by the ratio of the desired dose conversion factor to the POSTDBA dose conversion factor. When using this resulting activity for each iodine nuclide, the thyroid inhalation dose as calculated by POSTDBA would be based on the desired dose conversion factor.

But in order to obtain the correct whole body and beta skin doses for each iodine nuclide, both the average gamma energy and the average beta energy for that nuclide must be multiplied by the reciprocal of the ratio that was applied to the activity.

These calculations for Reference 21 dose conversion factors are performed in Table 7. These calculations for Reference 22 dose conversion factors are performed in Table 8.

* The Reference 22 dose conversion factors come from ICRP-30, Supplement to Part 1, Volume 3, No. 1-4, 1979.



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. 21-5-91
Rev. 0 Date
Page 46 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

TABLE 6

Calculation of Initial Airborne Activity in Primary Containment

Nuclide	Ref. 9, Table 14.3.5-5, Activity, * Curies	LOCA Airborne Activity, ** Curies	Ref. 11, Table A.2-1 Percent of Core Inventory Activity in Gap	Calculated Gap Activity, *** Curies
I-131	9.34 +7	2.335 +7	2.3	2.148 +6
I-132	1.38 +8	3.450 +7	.26	3.588 +5
I-133	1.76 +8	4.400 +7	.79	1.390 +6
I-134	2.19 +8	5.475 +7	.16	3.504 +5
I-135	1.78 +8	4.450 +7	.43	7.654 +5
Kr-85m	2.70 +7	2.70 +7	.29	7.830 +4
Kr-85	9.40 +5	9.40 +5	21.57	2.028 +5
Kr-87	5.08 +7	5.08 +7	.20	1.016 +5
Kr-88	7.70 +7	7.70 +7	.29	2.233 +5
Xe-133m	4.94 +6	4.94 +6	1.27	6.274 +4
Xe-133	1.88 +8	1.88 +8	1.85	3.478 +6
Xe-135m	5.20 +7	5.20 +7	.086	4.472 +4
Xe-135	5.42 +7	5.42 +7	.54	2.927 +5

Form GO-3.0B.1 Rev. 2

* End of Life Core Inventory for 3391 Mwt (~104% Full Power).
 ** 25% Core inventory of iodines; 100% core inventory of nobles; Ref. 1.
 *** 100% is assumed airborne after LOCA when using the Gap Source.

TABLE 7 : Nuclide Data Adjustments For Reference 21 Thyroid Dose Conversion Factors

Nuclide	Thyroid Dose Conversion Factor, Rem/Ci		Airborne Activity, Curies, (Based on 25% Core Inventory)		Airborne Activity, Curies, (Based on 100% Gap Activity)	
	POSTDBA *	Ref. 21 **	Actual ***	Adjusted †	Actual ***	Adjusted †
	A	B	C	D	E	F
I-131	1.49+6	1.49+6	2.335+7	2.335+7	2.148+6	2.148+6
I-132	5.48+4	1.43+4	3.450+7	9.003+6	3.588+5	9.363+4
I-133	3.66+5	2.69+5	4.400+7	3.234+7	1.390+6	1.022+6
I-134	2.87+4	3.73+3	5.475+7	7.116+6	3.504+5	4.554+4
I-135	1.17+5	5.60+4	4.450+7	2.130+7	2.654+5	3.663+5

Nuclide	Average Gamma Energy, Mev/dis.		Average Beta Energy, Mev/dis.	
	POSTDBA *	Adjusted †	POSTDBA *	Adjusted †
	G	H	I	J
I-131	.381	.381	.191	.191
I-132	2.26	8.661	.490	1.878
I-133	.608	.8272	.411	.5592
I-134	2.601	20.01	.621	4.778
I-135	1.557	3.253	.368	.7689

* Reference 7, page 30.

** page 1.109-45, Adult thyroid values were multiplied by 10³ to convert units.

† (Column D) = (Column C)(Column B)/(Column A); (Column F) = (Column E)(Column B)/(Column A)
 (Column H) = (Column G)(Column A)/(Column B); (Column J) = (Column I)(Column A)/(Column B)

*** Table 6

SARGENT & LUNDY
ENGINEERS

Client _____
 Project _____
 Proj. No. 7805-11
 Equip. No. _____

Prepared by _____ Date _____
 Reviewed by _____ Date _____
 Approved by _____ Date _____

Calc. For _____
 Safety-Related
 Non-Safety-Related

Calc. No. ZI-5-91
 Rev. 0 Date _____
 Page 47 of _____

TABLE 8 : Nuclide Data Adjustments For Reference 22 Thyroid Dose Conversion Factors

Nuclide	Thyroid Dose Conversion Factor, Rem/Ci		Airborne Activity, Curies, (Based on 25% Core Inventory)		Airborne Activity, Curies (Based on 100% Gap Activity)	
	POSTDBA*	Ref. 22**	Actual***	Adjusted†	Actual***	Adjusted†
	A	B	C	D	E	F
I-131	1.49+6	1.08+6	2.335+7	1.692+7	2.148+6	1.557+6
I-132	5.48+4	6.4+3	3.450+7	4.029+6	3.588+5	4.190+4
I-133	3.66+5	1.80+5	4.400+7	2.164+7	1.390+6	6.836+5
I-134	2.87+4	1.07+3	5.475+7	2.041+6	3.504+5	1.306+4
I-135	1.17+5	3.13+4	4.450+7	1.190+7	7.65+5	2.048+5

Nuclide	Average Gamma Energy, Mev/dis.		Average Beta Energy, Mev/dis.	
	POSTDBA*	Adjusted†	POSTDBA*	Adjusted†
	G	H	I	J
I-131	.381	.5256	.191	.2635
I-132	2.26	19.35	.490	4.196
I-133	.608	1.236	.411	.8357
I-134	2.601	69.77	.621	16.66
I-135	1.557	5.820	.363	1.376

* Reference 7, page 30.

** Reference 22, Table 2.1.

† (Column D) = (Column C)(Column B)/(Column A); (Column F) = (Column E)(Column B)/(Column A)
 (Column H) = (Column G)(Column A)/(Column B); (Column J) = (Column I)(Column A)/(Column B)

*** Table 6



Client _____
 Project _____
 Proj. No. 7805-11
 Equip. No. _____

Prepared by _____ Date _____
 Reviewed by _____ Date _____
 Approved by _____ Date _____

Calc. For _____
 Safety-Related
 Non-Safety-Related

Calc. No. ZI-5-91
 Rev. 0 Date _____
 Page 48 of _____

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 49	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

6.2 POSTDBA Calculations

6.2.1 Description

In POSTDBA the spray effectiveness cutoff time can be calculated only for a decontamination factor of 100. Hence, this option could not be used in this calculation. Spray effectiveness cutoff times were hand calculated in Section 4.6 and Subsection 4.7.4. There were two different spray effectiveness cutoff times, one for elemental iodine and one for particulate iodine. However, POSTDBA can accept only one spray effectiveness cutoff time. Thus, whenever control room doses due to containment leakage are desired, two POSTDBA cases must be run, one for elemental iodine and noble gas, and one for particulate and organic iodine. These cases are designated by the suffixes A and B respectively. Since these cases involve containment leakage the case designations will contain a C; cases involving ECCS leakage will have an E in the case designation but no A or B suffix.

POSTDBA results were desired for all combinations of initial airborne activity (based on core inventory or gap inventory), (V_d') model (plan view or circuitous path), and thyroid dose conversion factors (Ref. 21 or Ref. 22). These eight possible combinations were given case numbers 1 through 8. Each of these cases were run three times, once for 30 cfm control room infiltration, once for 1000.0 cfm infiltration, and once for 2000.0 cfm infiltration which were thought to bracket any possible measured value. The case designation will contain a 0, 1, or 2 after the C or E to denote the infiltration (0, 1000, and 2000 cfm respectively). Thus, a total of 72 POSTDBA cases were required. Table 9 relates the case designations to the parameters used in each case.

TABLE 9
POSTDBA Cases

POSTDBA Case Designation	Activity Inventory Source	(1/2) Model	Thyroid Dose Conversion Factors	Leakage (C)ontainment (E)CCS	Control Room Infiltration, cfm	Nuclides (E)lemental Iodine (P)articulate Iodine (O)rganic Iodine (N)oble Gas		
1CO-A	Core	Plan View	Ref. 21	C	0	E & N		
1CO-B				C	0	P & O		
1EO				E	0	E, P, & O		
1C1-A				C	1000	E & N		
1C1-B				C	1000	P & O		
1E1				E	1000	E, P, & O		
1C2-A				C	2000	E & N		
1C2-B				C	2000	P & O		
1E2				E	2000	E, P, & O		
2CO-A				Circuitous Path	↓	C	0	E & N
2CO-B						C	0	P & O
2EO						E	0	E, P, & O
2C1-A						C	1000	E & N
2C1-B						C	1000	P & O
2E1						E	1000	E, P, & O
2C2-A						C	2000	E & N
2C2-B						C	2000	P & O
2E2						E	2000	E, P, & O

Client		Prepared by	Date
Project		Reviewed by	Date
Proj. No.	7805-11	Approved by	Date
Equip. No.			

Calc. For		Calc. No.	ZI-5-91
<input checked="" type="checkbox"/> Safety-Related		Rev.	0
<input type="checkbox"/> Non-Safety-Related		Date	
		Page	50 of

TABLE 9 , Cont'd
POSTDBA Cases

POSTDBA Case Designation	Activity Inventory Source	(1/4') Model	Thyroid Dose Conversion Factors	Leakage		Control Room Infiltration, cfm	Nuclides			
				(C)ontainment	(E)CCS		(E)lemental Iodine (P)articulate Iodine (O)rganic Iodine (N)oble Gas			
3CO-A	Gap	Plan View	Ref. 21	C		0	E & N			
3CO-B				C		0	P & O			
3EO				E		0	E, P, & O			
3CI-A				C		1000	E & N			
3CI-B				C		1000	P & O			
3EI				E		1000	E, P, & O			
3C2-A				C		2000	E & N			
3C2-B				C		2000	P & O			
3E2				E		2000	E, P, & O			
4CO-A				Circuitous Path			C		0	E & N
4CO-B							C		0	P & O
4EO							E		0	E, P, & O
4CI-A							C		1000	E & N
4CI-B							C		1000	P & O
4EI							E		1000	E, P, & O
4C2-A							C		2000	E & N
4C2-B							C		2000	P & O
4E2							E		2000	E, P, & O

SARGENT & LUNDY
ENGINEERS

Calcs. For _____

Safety-Related

Non-Safety-Related

Calcs. No. 21-5-91

Rev. 0 Date _____

Page 51 of _____

Client	_____	Prepared by	_____	Date	_____
Project	_____	Reviewed by	_____	Date	_____
Proj. No. <u>7805-11</u>	Equip. No.	Approved by	_____	Date	_____

TABLE 9 , Cont'd
POSTDBA Cases

POSTDBA Case Designation	Activity Inventory Source	(1/a') Model	Thyroid Dose Conversion Factors	Leakage		Control Room Infiltration, cfm	Nuclides			
				(C)ontainment	(E)CCS		(E)lemental Iodine	(P)articulate Iodine	(O)rganic Iodine	(N)oble Gas
5CO-A	Core	Plan View	Ref. 22	C		0	E & N			
5CO-B				C		0	P & O			
5EO				E		0	E, P, & O			
5C1-A				C		1000	E & N			
5C1-B				C		1000	P & O			
5E1				E		1000	E, P, & O			
5C2-A				C		2000	E & N			
5C2-B				C		2000	P & O			
5E2				E		2000	E, P, & O			
6CO-A				Circuitous Path		C		0	E & N	
6CO-B		C					0	P & O		
6EO		E					0	E, P, & O		
6C1-A		C					1000	E & N		
6C1-B		C					1000	P & O		
6E1		E					1000	E, P, & O		
6C2-A		C					2000	E & N		
6C2-B		C					2000	P & O		
6E2		E					2000	E, P, & O		

Client	
Project	
Proj. No. 7805-11	Equip. No.
Prepared by	Date
Reviewed by	Date
Approved by	Date

Calcs. For	
Safety-Related	Non-Safety-Related
Page 52	of
Calc. No. ZI-5-91	
Rev. 0	Date

TABLE 9 , Cont'd
POSTDBA Cases

POSTDBA Case Designation	Activity Inventory Source	(1/a) Model	Thyroid Dose Conversion Factors	Leakage		Control Room Infiltration, cfm	Nuclides					
				(C)ontainment	(E)CCS		(E)lemental Iodine	(P)articulate Iodine	(O)rganic Iodine	(N)oble Gas		
7C0-A	Gap	Plan View	Ref. 22	C		0	E & N					
7C0-B				C		0	P & O					
7E0				E		0	E, P, & O					
7C1-A				C		1000	E & N					
7C1-B				C		1000	P & O					
7E1				E		1000	E, P, & O					
7C2-A				C		2000	E & N					
7C2-B				C		2000	P & O					
7E2				E		2000	E, P, & O					
8C0-A				↓	↓	↓	C		0	E & N		
8C0-B							C		0	P & O		
8E0							E		0	E, P, & O		
8C1-A							C		1000	E & N		
8C1-B							C		1000	P & O		
8E1							E		1000	E, P, & O		
8C2-A							C		2000	E & N		
8C2-B							C		2000	P & O		
8E2							E		2000	E, P, & O		

↓
Circuitous Path

Client		Prepared by	Date
Project		Reviewed by	Date
Proj. No. 7805-11	Equip. No.	Approved by	Date

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calcs. No. 21-5-91
Rev. 0 Date
Page 53 of

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

6.2.2 POSTDBA Input

The POSTDBA input instructions are in Reference 8. The input listing for case designations 1C0-A through 4E2 (all cases using Reference 21 thyroid dose conversion factors) is found on the attached microfiche (Microfiche C):

ZI-5-71 RD SR NSLD 4C4-A1 SYS CR CNTRL RM INFILT STDY(DOSE1)
 S&L 03/11/91 10:26:56 WQ=212 ID=DRSH
 ORIG=05 DUPS=01 PRJ=ZIO780511 PGM=POS098085110/

The input listings for case designations 5C0-A through 8E2 (all cases using Reference 22 thyroid dose conversion factors) is found on the attached microfiche (Microfiche D):

ZI-5-91 RD SR NSLD 4C4-A1 SYS CR CNTRL RM INFILT STDY(DOSE2)
 S&L 03/11/91 10:26:56 WQ=212 ID=DRSH
 ORIG=05 DUPS=01 PRJ=ZIO780511 PGM=POS098085110/

The input description for each case is as follows.

POSTDBA Card Type 1; Format (9I5, 3A6)

IP = 0 for all cases except those with an E in the case designation;
 for those (ECCS Leakage) IP = 4, number of entries in purge table.

ISPRAY = 3 } not used
 MURF = 2 }

ICONT = 1 use HVAC System I

IC1 = 0 }
 IC2 = 0 } not used
 IC3 = 0 }
 MET = 0 }

INL = 0 Input POSTDBA \bar{u}_{eff} on Card Type 14 (and 16 for ECCS cases)
 (ISTAT(I), I=1,3) = ZION 7805-11 literal station name and charge number.

Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 56 of	

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

POSTDBA Card Type 5; Format (7D10.2)

AREA = 26436.	Ref. 14, p. 18
FI(1) = 0.0	when suffix B is in case designation,
= .91	all other cases. Ref. 1, p. 1.4-1
FI(2) = 0.0	when suffix A is in case designation,
= .05	all other cases. Ref. 1, p. 1.4-1
FI(3) = 0.0	when suffix A is in case designation,
= .04	all other cases. Ref. 1, p. 1.4-1
PFILT(1) = .99	when E is in case designation (purge will be used)*
= 0.0	all other cases.
PFILT(2) = .99	when E is in case designation (purge will be used)*
= 0.0	all other cases.
PFILT(3) = .99	when E is in case designation (purge will be used)*
= 0.0	all other cases.

POSTDBA Card Type 6; Format (6D10.2)

This card type is omitted for all cases containing a C in the case designation; for cases containing an E in the case designation, this card type contains:

TP(1) = .25	beginning time of recirculation phase purge is zero until TP(1) Subsection 6.1.2.1 Purge rate is .08999 cfm from .25 hr to 720.0 hr. Subsection 6.1.2.1 ending time
P(1) = 0.0	
TP(2) = 2.0	
P(2) = .08999	
TP(3) = 8.0	
P(3) = .08999	
TP(4) = 720.0	

* Subsection 6.1.2.2

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. 21-5-91	
Rev. 0	Date
Page 57 of	

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

POSTDBA Card Type 7; Format (7D10.2)

All entries are zero because EAB and LPZ doses are not required.

POSTDBA Card Type 8; Format (3D10.2)

All entries are zero because off site doses are not required.

POSTDBA Card Types 9 through 13

These card types are omitted because $INL = 0$ on card type 1.

POSTDBA Card Type 14; Format (5D10.2)

DMURF(1) = .2563	} Table 4	} for case designations beginning with 1, 3, 5, and 7.
DMURF(2) = .2563		
DMURF(3) = .4344		
DMURF(4) = 1.139		
DMURF(5) = 3.883		

but

DMURF(1) = .6002	} Table 5	} for case designations beginning with 2, 4, 6, and 8.
DMURF(2) = .6002		
DMURF(3) = 1.0173		
DMURF(4) = 2.667		
DMURF(5) = 9.093		

POSTDBA Card Type 15; Format (7D10.2)

All entries are zero for case designations containing an E because EAB and LPZ doses are not required.

This card type is omitted for all other cases because $IP = 0$ on card type 1.

Client	
Project	
Proj. No. <u>7805-11</u>	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

POSTDBA Card Type 16 ; Format (5D10.2)

DMURFG(1) = .6002
 DMURFG(2) = .6002
 DMURFG(3) = 1.0173
 DMURFG(4) = 2.667
 DMURFG(5) = 9.093

Table 5

for case designations containing an E

This card type is omitted for all other cases because IP=0 on card type 1.

POSTDBA Card Type 17 ; Format (6D10.2)

RI = 1800.
 RIFILT(1) = .99
 RIFILT(2) = .99
 RIFILT(3) = .99
 VC = 1.19122+5
 RF = 0.0
 = 1000.0
 = 2000.0

Section 2.2 Conservative Make-up Air Flow Rate (Control Room)

Ref. 11, Q.9.8-1 & Q.9.3-1

Ref. 16

for case designations with 0 following the C or E
 for case designations with 1 following the C or E
 for case designations with 2 following the C or E

POSTDBA Card Type 18 ; Format (7D10.2)

RC = 0.0
 RCFILT(1) = 0.0
 RCFILT(2) = 0.0
 RCFILT(3) = 0.0
 CBRTH(1) = 3.47-4
 CBRTH(2) = 3.47-4
 CBRTH(3) = 3.47-4

recirculation not used.

Ref. 4

POSTDBA Card Type 19 ; Format (3D10.2)

This card type is omitted because ICONT=1 on card type 1.

POSTDBA Card Type 20 ; Format (I5)

IRPT = 0 Nuclide data are to be read on card type 21.

SARGENT & LUNDY
ENGINEERS

Client	
Project	
Proj. No.	7805-11
Equip. No.	
Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	
<input type="checkbox"/> Non-Safety-Related	
Prepared by	
Reviewed by	
Approved by	
Date	
Date	
Date	

POSTDBA Card Type 21; Format (A6, I4, D10.2, 3F6.2, 2X, 3D10.2, 2F5.4)

For case designations beginning with 1 or 2, and for case designations containing a C. There is one record (card) for each nuclide (ISO). However, case designations with the suffix B omit the noble gas records.

Note: Noble gas AAD is from Table 6, LOCA Airborne Activity.

ISO	IPRW	Table 7 Col. D (Iodine) AAD	FINA	Table 3 FINC	FINS & DLAM	Table 7 Col. H EG	Table 7 Col. J EB	BOD & SKN
I-131	1	2.335+7	blank	16.65	blank	.3810	.1910	blank
I-132	1	9.003+6	↓	18.10	↓	8.661	1.878	↓
I-133	1	3.234+7	↓	17.46	↓	.8272	.5592	↓
I-134	1	7.116+6	↓	18.55	↓	20.01	4.778	↓
I-135	1	2.130+7	↓	20.04	↓	3.253	.7689	↓
XE-33M	0	4.940+6	↓	6.701	↓	blank	blank	↓
XE-133	0	1.880+8	↓	7.976	↓	↓	↓	↓
XE-35M	0	5.200+7	↓	16.55	↓	↓	↓	↓
XE-135	0	5.420+7	↓	16.49	↓	↓	↓	↓
KR-85M	0	2.700+7	↓	15.08	↓	↓	↓	↓
KR-85	0	9.400+5	↓	17.09	↓	↓	↓	↓
KR-87	0	5.080+7	↓	20.85	↓	↓	↓	↓
KR-88	0	7.700+7	↓	21.86	↓	↓	↓	↓

POSTDBA Card Type 22; Format (A3)

ISO = END

This card type follows the last record (card) in the above table.

Calcs. No.	21-5-91
Rev. 0	Date
Page 59	of

SARGENT & LUNDY
MEMBERSHIP

Client _____
Project _____
Proj. No. 7805-11 Equip. No. _____

Calcs. For _____
 Safety-Related
 Non-Safety-Related

Prepared by _____ Date _____
Reviewed by _____ Date _____
Approved by _____ Date _____

Calc. No. ZI-5-91
Rev. 0 Date _____
Page 60 of _____

POSTDBA Card Type 21; Format (A6, I4, D10.2, 3F6.2, 2X, 3D10.2, 2F5.4)

For case designations beginning with 1 or 2, and for case designations containing an E. There is one record (card) for each nuclide (ISO).

ISO	IPRN	(see note below) AAO	FINA	Table 3 FINC	FIN5 & DLAM	Table 7 Col. H EQ	Table 7 Col. J EB	BOD & SKN
I-131	1	4.670+7	blank	16.65	blank	.3810	.1910	blank
I-132	1	1.801+7	↓	18.10	↓	8.661	1.878	↓
I-133	1	6.468+7	↓	17.46	↓	.8272	.5592	↓
I-134	1	1.423+7	↓	18.55	↓	20.01	4.778	↓
I-135	1	4.260+7	↓	20.04	↓	3.253	.7689	↓

Note: These values of AAO are two times the values in Table 7, Col. J, because 50% of the core inventory is supposed to be in the sump water.

POSTDBA Card Type 22; Format (A3)

ISO = END This card type follows the last record (card) in the above table.

SARGENT & LUNDY
ENGINEERS

Client _____
Project _____
Proj. No. 7805-11
Equip. No. _____

Calc. For _____
Safety-Related Non-Safety-Related

Prepared by _____ Date _____
Reviewed by _____ Date _____
Approved by _____ Date _____

Calc. No. ZI-5-91
Rev. 0 Date _____
Page 61 of _____

POSTDBA Card Type 21; Format (A6, I4, D10.2, 3F6.2, 2X, 3D10.2, 2F5.4)

For case designations beginning with 3 or 4, and for case designations containing a C. There is one record (card) for each nuclide (ISO).

However, case designations with the suffix B omit the noble gas records.

Note: Noble gas AAO is from Table 6, Calculated Gap Activity.

ISO	IPRW	Table 7 Col. F (iodine) AAO	FINA	Table 3 FINC	FINS & DLAM	Table 7 Col. H EG	Table 7 Col. J EB	BOD & SKN
I-131	1	2.148+6	blank	16.65	blank	.3810	.1910	blank
I-132	1	9.363+4	↓	18.10	↓	8.661	1.878	↓
I-133	1	1.022+6	↓	17.46	↓	.8272	.5592	↓
I-134	1	4.554+4	↓	18.55	↓	20.01	4.778	↓
I-135	1	3.663+5	↓	20.04	↓	3.253	.7689	↓
XE-33M	0	6.274+4	↓	6.701	↓	blank	blank	↓
XE-133	0	3.478+6	↓	7.976	↓	↓	↓	↓
XE-35M	0	4.472+4	↓	16.55	↓	↓	↓	↓
XE-135	0	2.927+5	↓	16.49	↓	↓	↓	↓
KR-85M	0	7.830+4	↓	15.08	↓	↓	↓	↓
KR-85	0	2.028+5	↓	17.09	↓	↓	↓	↓
KR-87	0	1.016+5	↓	20.85	↓	↓	↓	↓
KR-88	0	2.233+5	↓	21.86	↓	↓	↓	↓

POSTDBA Card Type 22; Format (A3)

ISO = END This card type follows the last record (card) in the above table.

SARGENT & LUNDY
ENGINEERS ARCHITECTS

POSTDBA Card Type 21; Format (A6, I4, D10.2, 3F6.2, 2X, 3D10.2, 2F5.4)

For case designations beginning with 3 or 4, and for case designations containing an E. There is one record (card) for each nuclide (ISO).

ISO	IPRW	Table 7 Col. F AA0	FINA	Table 3 FINC	FINS & DLAM	Table 7 Col. H EQ	Table 7 Col. J EB	BOD & SKN
I-131	1	2.148+6	blank	16.65	blank	.3810	.1910	blank
I-132	1	9.363+4	↓	18.10	↓	8.661	1.878	↓
I-133	1	1.022+6	↓	17.46	↓	.8272	.5592	↓
I-134	1	4.554+4	↓	18.55	↓	20.01	4.778	↓
I-135	1	3.663+5	↓	20.04	↓	3.253	.7689	↓

POSTDBA Card Type 22; Format (A3)

ISO = END

This card type follows the last record (card) in the above table.

Client		Calcs. For	
Project		<input checked="" type="checkbox"/> Safety-Related	
Proj. No.	7805-11	<input type="checkbox"/> Non-Safety-Related	
Equip. No.		Prepared by	
		Reviewed by	
		Approved by	
		Date	
		Date	
		Date	
Calc. No.	ZI-5-91	Rev.	0
		Date	
		Page	62 of

SARGENT & LUNDY
ENGINEERS

Client _____
Project _____
Prod. No. 7805-11 Equip. No. _____

Calcs. For _____
 Safety-Related Non-Safety-Related

Prepared by _____ Date _____
Reviewed by _____ Date _____
Approved by _____ Date _____

Calcs. No. ZI-5-91
Rev. 0 Date _____
Page 63 of _____

POSTDBA Card Type 21; Format (A6, I4, D10.2, 3F6.2, 2X, 3D10.2, 2F5.4)

For case designations beginning with 5 or 6, and for case designations containing a C. There is one record (card) for each nuclide (ISO).

However, case designations with the suffix B omit the noble gas records.

Note: Noble gas AAO is from Table 6, LOCA Airborne Activity.

ISO	IPRW	Table 8 Col. D (iodine) AAO	FINA	Table 3 FINC	FINS & DLAM	Table 8 Col. H EG	Table 8 Col. J EB	BOD & SKN
I-131	1	1.692+7	blank	16.65	blank	.5256	.2635	blank
I-132	1	4.029+6	↓	18.10	↓	19.35	4.196	↓
I-133	1	2.164+7	↓	17.46	↓	1.236	.8357	↓
I-134	1	2.041+6	↓	18.55	↓	69.77	16.66	↓
I-135	1	1.190+7	↓	20.04	↓	5.820	1.376	↓
XE-33M	0	4.940+6	↓	6.701	↓	blank	blank	↓
XE-133	0	1.880+8	↓	7.976	↓	↓	↓	↓
XE-35M	0	5.200+7	↓	16.55	↓	↓	↓	↓
XE-135	0	5.420+7	↓	16.49	↓	↓	↓	↓
KR-85M	0	2.700+7	↓	15.08	↓	↓	↓	↓
KR-85	0	9.400+5	↓	17.09	↓	↓	↓	↓
KR-87	0	5.080+7	↓	20.85	↓	↓	↓	↓
KR-88	0	7.700+7	↓	21.86	↓	↓	↓	↓

POSTDBA Card Type 22; Format (A3)

ISO = END

This card type follows the last record (card) in the above table.

SARGENT & LUNDY
ENGINEERS

Client _____
Project _____
Proj. No. 7805-11 Equip. No. _____

Calcs. For _____
 Safety-Related
 Non-Safety-Related

Prepared by _____ Date _____
Reviewed by _____ Date _____
Approved by _____ Date _____

Calc. No. ZI-5-91
Rev. 0 Date _____
Page 64 of _____

POSTDBA Card Type 21; Format (A6, I4, D10.2, 3F6.2, 2X, 3D10.2, 2F5.4)

For case designations beginning with 5 or 6, and for case designations containing an E. There is one record (card) for each nuclide (ISO).

ISO	IPRW	(see note below) AAD	FINA	Table 3 FINC	FINV & DLAM	Table 8 Col. H EG	Table 8 Col. J EB	BOD & SKN
I-131	1	3.384+7	blank	16.65	blank	.5256	.2635	blank
I-132	1	8.058+6	↓	18.10	↓	19.35	4.196	↓
I-133	1	4.328+7	↓	17.46	↓	1.236	.8357	↓
I-134	1	4.082+6	↓	18.55	↓	69.77	16.66	↓
I-135	1	2.380+7	↓	20.04	↓	5.820	1.376	↓

Note: These values of AAD are two times the values in Table 8, Col. D, because 50% of the core inventory is supposed to be in the sump water.

POSTDBA Card Type 22; Format (A3)

ISO = END This card type follows the last record (card) in the above table.

SARGENT & LUNDY
ENGINEERS

Client _____
Project _____
Proj. No. 7805-11 Equip. No. _____

Prepared by _____ Date _____
Reviewed by _____ Date _____
Approved by _____ Date _____

Calcs. For _____
 Safety-Related
 Non-Safety-Related

Calcs. No. 21-5-91
Rev. 0 Date _____
Page 65 of _____

POSTDBA Card Type 21; Format (A6, I4, D10.2, 3F6.2, 2X, 3D10.2, 2F5.4)

For case designations beginning with 7 or 8, and for case designations containing a C. There is one record (card) for each nuclide (ISO). However, case designations with the suffix B omit the noble gas records.
Note: Noble gas AAO is from Table 6, Calculated Gap Activity.

ISO	IPRN	Table 8 Col. F (Iodine) AAO	FINA	Table 3 FINC	FINS & DLAM	Table 8 Col. H EG	Table 8 Col. J EB	BOD & SKN
I-131	1	1.557+6	blank	16.65	blank	.5256	.2635	blank
I-132	1	4.190+4	↓	18.10	↓	19.35	4.196	↓
I-133	1	6.836+5	↓	17.46	↓	1.236	.8357	↓
I-134	1	1.306+4	↓	18.55	↓	69.77	16.66	↓
I-135	1	2.048+5	↓	20.04	↓	5.820	1.376	↓
XE-33M	0	6.274+4	↓	6.701	↓	blank	blank	↓
XE-133	0	3.478+6	↓	7.976	↓	↓	↓	↓
XE-35M	0	4.472+4	↓	16.55	↓	↓	↓	↓
XE-135	0	2.927+5	↓	16.49	↓	↓	↓	↓
KR-85M	0	7.830+4	↓	15.08	↓	↓	↓	↓
KR-85	0	2.028+5	↓	17.09	↓	↓	↓	↓
KR-87	0	1.016+5	↓	20.85	↓	↓	↓	↓
KR-88	0	2.233+5	↓	21.86	↓	↓	↓	↓

POSTDBA Card Type 22; Format (A3)

ISO = END This card type follows the last record (card) in the above table.

SARGENT & LUNDY
ENGINEERS

Client _____
Project _____
Proj. No. 7805-11 Equip. No. _____

Prepared by _____
Reviewed by _____
Approved by _____
Date _____
Date _____
Date _____

Calcs. For _____
 Safety-Related
 Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date _____
Page 66 of _____

POSTDBA Card Type 21; Format (A6, I4, D10.2, 3F6.2, 2X, 3D10.2, 2F5.4)

For case designations beginning with 7 or 8, and for case designations containing an E. There is one record (card) for each nuclide (ISO).

ISO	IPRN	Table 8 Col. F AAO	FINA	Table 3 FINC	FINS & DLAM	Table 8 Col. H EG	Table 8 Col. J EB	BOD & SKN
I-131	1	1.557+6	blank	16.65	blank	.5256	.2635	blank
I-132	1	4.190+4	↓	18.10	↓	19.35	4.196	↓
I-133	1	6.836+5	↓	17.46	↓	1.236	.8357	↓
I-134	1	1.306+4	↓	18.55	↓	69.77	16.66	↓
I-135	1	2.048+5	↓	20.04	↓	5.820	1.376	↓

POSTDBA Card Type 22; Format (A3)

ISO = END This card type follows the last record (card) in the above table.



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 67	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

6.2.3 POSTDBA Output

The POSTDBA output for the control room dose calculations that used Reference 21 thyroid dose conversion factors can be found in the attached microfiche C.

The POSTDBA output for the control room dose calculations that used Reference 22 thyroid dose conversion factors can be found in the attached microfiche D.

Note that the total dose for any specific set of parameters must be hand calculated as the sum of

the containment leakage dose in case designation with suffix A plus the containment leakage dose in case designation with suffix B plus the ECCS leakage dose in case designation containing an E.

Although this calculation does not use the "Cumulative Activity Output to Environment" found on the individual iodine nuclide output pages, it should be pointed out that these POSTDBA output values are in error because the initial iodine activities were adjusted to give correct thyroid doses based on different thyroid dose conversion factors.

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

7. IODINE PROTECTION FACTOR METHODOLOGY

Reference 4 presents an Iodine Protection Factor (IPF) equation; IPF is the ratio of the iodine activity outside of the control room to that inside the control room. The IPF is a function of control room parameters only.

If the thyroid dose D_1 is known for one set of control room parameters (IPF)₁, then the thyroid dose D_2 can be found for any other set of parameters (IPF)₂ because

$$D_1 (IPF)_1 = D_2 (IPF)_2$$

The Reference 4 equation for IPF is

$$IPF = \frac{F_1 + \eta F_2 + F_3}{(1-\eta)F_1 + F_3} \quad \text{if make-up and recirculation filters are identical.}$$

Reference 4 then explains that if the make-up and recirculation filters are different,

$$IPF = \frac{F_1 + \eta_2 F_2 + F_3}{(1-\eta_1)F_1 + F_3}$$

where

F_1 = make-up air flow rate

η_1 = make-up air filter fractional efficiency for iodine

F_2 = recirculation air flow rate

η_2 = recirculation air filter fractional efficiency for iodine

F_3 = infiltration air flow rate

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

For this calculation, $F_1 = 1800$ cfm See Section 2.2
 $F_2 = 11500$ cfm Ref. 16
 $\eta_1 = .99$ Ref. 11, @ 9.8-1 & @ 9.3-1

Then,

$$IPF = \frac{(1800 + 11500\eta_2 + F_3)}{[(1-.99)1800 + F_3]} = \frac{(F_3 + 11500\eta_2 + 1800)}{(F_3 + 18)}$$

Let the dose D_{1000} be known from a POSTDBA calculation
 for $F_3 = 1000$ cfm
 and $\eta_2 = 0.0$

Then the $(IPF)_{1000}$ for the known dose D_{1000} is

$$(IPF)_{1000} = \frac{(1000 + 1800)}{(1000 + 18)} = 2.750491159$$

Now the dose D for any other combination of F_3 and η_2 is
 $D = D_{1000} (IPF)_{1000} / IPF$

Thus,

$$D = \frac{D_{1000} * 2.750491159 (F_3 + 18)}{(F_3 + 11500\eta_2 + 1800)}$$

Solving for F_3 ,

$$F_3 = \left[11500\eta_2 + 1800 - 49.50884086 \left(\frac{D_{1000}}{D} \right) \right] / \left[2.750491159 \left(\frac{D_{1000}}{D} \right) - 1 \right]$$

where D will be any target 30 day thyroid dose; e.g.,

$D = 30$ Rem (Refs. 23⁴; single inlet; no iodine blockers)

$D = 120$ Rem (manually operated dual inlets - (1/2) reduced by factor of 4 from Ref. 3; no iodine blockers)

$D = 50$ Rem (Ref. 24; single inlet; no iodine blockers)

$D = 200$ Rem (manually operated dual inlets; no iodine blockers)

These values can be multiplied by 10 if iodine blockers are used (Ref. 25, p. 2, states, "90% effective if taken immediately prior to or concurrent with exposure to radioactive iodine").

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 70 of	

Client
Project
Proj. No. 7805-11 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

8. CONTROL ROOM DOSE RESULTS

Tables 10 through 13 summarize the 30 Day Control Room Doses when using Regulatory Guide 1.109 (Ref. 21) thyroid dose conversion factors. These POSTDBA calculated doses are found on the attached microfiche C. These tables also give the total doses as defined in Subsection 6.2.3 (paragraph 3).

Tables 14 through 17 summarize the 30 Day Control Room Doses when using ICRP-30 (Ref. 22) thyroid dose conversion factors. These POSTDBA calculated doses are found on the attached microfiche D. These tables also give the total doses as defined in Subsection 6.2.3 (paragraph 3).

Tables 18 and 19 summarize the total doses at 0, 1000, and 2000 cfm and define a Model designation (A, B, C, and D) for the different combinations of Initial source and ($1/Q^2$). Table 18 is for the use of Ref. 21 thyroid dose conversion factors, and Table 19 is for the use of Ref. 22 thyroid dose conversion factors. In addition thyroid doses at intermediate infiltration rates are calculated using the dose equation of Section 7 with $\eta_2 = 0.0$ (no recirculation). These calculated doses are based on the POSTDBA dose at 1000 cfm infiltration. Calculated values at 0 cfm and 2000 cfm are in parentheses and can be compared to the POSTDBA values showing the accuracy of the IPF methodology. Tables 18 and 19 also summarize the whole body and beta skin doses and provide comparisons with regulatory limits (Ref. 23) for all doses.

TABLE 10

POSTDBA 30 Day Control Room Doses Using
Core Inventory; Plan View ($\frac{1}{2}$); R.G. 1.109 Thyroid Dose Conversion Factors

Case No.	Infiltrating cfm	Leakage	Iodine Species*	Nobles	30 Day Thyroid, Rem	30 Day Whole Body, Rem	30 Day Beta Skin, Rem
1C0-A	0.0	Containment	E	Yes	4.21	1.81	15.2
1C0-B	0.0	Containment	P&O	No	22.6	.001	.005
1E0	0.0	ECCS	all	—	.71	0	.0001
Totals	0.0	—	all	Yes	27.52	1.811	15.21
1C1-A	1000.0	Containment	E	Yes	154.	1.90	15.9
1C1-B	1000.0	Containment	P&O	No	823.	.041	.21
1E1	1000.0	ECCS	all	—	25.7	.001	.01
Totals	1000.0	—	all	Yes	1002.7	1.942	16.12
1C2-A	2000.0	Containment	E	Yes	225.	1.95	16.3
1C2-B	2000.0	Containment	P&O	No	1200.	.061	.31
1E2	2000.0	ECCS	all	—	37.6	.001	.01
Totals	2000.0	—	all	Yes	1462.6	2.012	16.62

* E = elemental ; P = particulate ; O = organic

SARGENT & LUNDY
ENGINEERS

Client	
Project	
Proj. No.	7805-11
Equip. No.	

Calc. For	
Safety-Related	<input checked="" type="checkbox"/>
Non-Safety-Related	<input type="checkbox"/>

Prepared by		Date	
Reviewed by		Date	
Approved by		Date	

Calc. No.	ZI-5-91
Rev. 0	Date
Page 71	of

TABLE II

POSTDBA 30 Day Control Room Doses Using
Core Inventory; Circuitous Path ($\frac{1}{10}$); R.G.1.109 Thyroid Dose Conversion Factors

Case No.	Infiltration, cfm	Leakage	Iodine Species*	Nobles	30 Day Thyroid, Rem	30 Day Whole Body, Rem	30 Day Beta Skin, Rem
2C0-A	0.0	Containment	E	Yes	1.80	.771	6.47
2C0-B	0.0	Containment	P&O	No	9.64	.0005	.002
2E0	0.0	ECCS	all	—	.301	0	0
Totals	0.0	—	all	Yes	11.741	.7715	6.472
2C1-A	1000.0	Containment	E	Yes	65.7	.811	6.79
2C1-B	1000.0	Containment	P&O	No	352.	.0173	.088
2E1	1000.0	ECCS	all	—	11.0	.0004	.002
Totals	1000.0	—	all	Yes	428.7	.8287	6.880
2C2-A	2000.0	Containment	E	Yes	96.2	.833	6.96
2C2-B	2000.0	Containment	P&O	No	515.0	.0258	.130
2E2	2000.0	ECCS	all	—	16.1	.0006	.003
Totals	2000.0	—	all	Yes	627.3	.8594	7.093

* E = elemental ; P = particulate ; O = organic

SARGENT & LUNDY
ENGINEERS

Client

Project

Proj. No.

7805-11

Equip. No.

Calc. For

 Safety-Related

 Non-Safety-Related

Prepared by

Date

Reviewed by

Date

Approved by

Date

Calc. No. ZI-5-91

Rev. 0 Date

Page 72 of



Calcs. For

Safety-Related Non-Safety-Related

Calc. No. ZI-5-91

Rev. 0 Date

Page 73 of

Client

Project

Proj. No. 7805-11 Equip. No.

Prepared by

Reviewed by

Approved by

Date

Date

Date

TABLE 12

POSTDBA 30 Day Control Room Doses Using
 Gap Inventory; Circuitous Path (30); R.G. 1.109 Thyroid Dose Conversion Factors

Case No.	Inj./Inhal. Cfm.	leakage	Iodine Species #	Nobles	30 Day Thyroid, Rem	30 Day Whole Body, Rem	30 Day Beta Skin, Rem
4C0-A	0.0	Containment	E	Yes	.142	.00783	.0844
4C0-B	0.0	Containment	P & O	No	.796	.000016	.00009
4E0	0.0	ECCS	all	—	.0128	0	.000001
Totals	0.0	—	all	Yes	.9508	.007846	.08449
4C1-A	1000.0	Containment	E	Yes	5.18	.00808	.0861
4C1-B	1000.0	Containment	P & O	No	29.0	.000578	.00317
4E1	1000.0	ECCS	all	—	.465	.000008	.00004
Totals	1000.0	—	all	Yes	34.645	.008666	.08831
4C2-A	2000.0	Containment	E	Yes	7.57	.00821	.0869
4C2-B	2000.0	Containment	P & O	No	42.4	.000852	.00466
4E2	2000.0	ECCS	all	—	.68	.000012	.00006
Totals	2000.0	—	all	Yes	50.65	.009074	.09162

* E = elemental; P = particulate; O = organic

SARGENT & LUNDY
ENGINEERS

Client _____
Project _____
Prof. No. 7805-11
Equip. No. _____

Calc. For _____
 Safety-Related
 Non-Safety-Related

Prepared by _____
Reviewed by _____
Approved by _____
Date _____
Date _____
Date _____

Calc. No. ZI-5-91
Rev. 0
Page 74 of _____
Date _____

TABLE 13

POSTDBA 30 Day Control Room Doses Using
Gap Inventory; Plan View (1/2); R.G. 1.109 Thyroid Dose Conversion Factors

Case No.	Infiltration, cfm	Leakage	Iodine Species*	Nobles	30 Day Thyroid, Rem	30 Day Whole Body, Rem	30 Day Beta Skin, Rem
3C0-A	0.0	Containment	E	Yes	.333	.0183	.198
3C0-B	0.0	Containment	P&O	No	1.86	.0004	.0002
3E0	0.0	ECCS	all	—	.030	0	0
Totals	0.0	—	all	Yes	2.223	.01834	.1982
3C1-A	1000.0	Containment	E	Yes	12.1	.0189	.202
3C1-B	1000.0	Containment	P&O	No	67.9	.00135	.0074
3E1	1000.0	ECCS	all	—	1.09	.00002	.0001
Totals	1000.0	—	all	Yes	81.09	.02027	.2095
3C2-A	2000.0	Containment	E	Yes	17.7	.0192	.204
3C2-B	2000.0	Containment	P&O	No	99.3	.00199	.0109
3E2	2000.0	ECCS	all	—	1.59	.00003	.0002
Totals	2000.0	—	all	Yes	118.59	.02122	.2151

* E = elemental ; P = particulate ; O = organic

TABLE 14

POSTDBA 30 Day Control Room Doses Using
Core Inventory; Plan View ($\frac{1}{2}$); ICRP-30 Thyroid Dose Conversion Factors

Case No.	Infiltration, cfm	Leakage	Iodine Species*	Nobles	30 Day Thyroid, Rem	30 Day Whole Body, Rem	30 Day Beta Skin, Rem
5C0-A	0.0	Containment	E	Yes	2.99	1.81	15.2
5C0-B	0.0	Containment	P&O	No	16.1	.001	.01
5E0	0.0	ECCS	all	—	.506	0	0
Totals	0.0	—	all	Yes	19.596	1.811	15.21
5C1-A	1000.0	Containment	E	Yes	109.	1.90	15.9
5C1-B	1000.0	Containment	P&O	No	588.	.040	.20
5E1	1000.0	ECCS	all	—	18.4	.001	.01
Totals	1000.0	—	all	Yes	715.4	1.941	16.11
5C2-A	2000.0	Containment	E	Yes	160.	1.95	16.3
5C2-B	2000.0	Containment	P&O	No	860.	.060	.30
5E2	2000.0	ECCS	all	—	27.0	.001	.01
Totals	2000.0	—	all	Yes	1047.0	2.011	16.61

* E = elemental ; P = particulate ; O = organic

SARGENT & LUNDY
ENGINEERS

Client
Project
Prof. No. 7805-11
Equip. No.

Prepared by
Reviewed by
Approved by
Date
Date
Date

Calc. For
 Safety-Related
 Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0
Page 75 of
Date

TABLE 15

POSTDBA 30 Day Control Room Doses Using
Core Inventory; Circuitous Path ($\frac{1}{2}$); ICRP-30 Thyroid Dose Conversion Factors

Case No.	Infiltration, cfm	Leakage	Iodine Species*	Nobles	30 Day Thyroid, Rem	30 Day Whole Body, Rem	30 Day Beta Skin, Rem
6C0-A	0.0	Containment	E	Yes	1.27	.771	6.47
6C0-B	0.0	Containment	P&O	No	6.88	.0005	.002
6E0	0.0	ECCS	all	—	.216	0	0
Totals	0.0	—	all	Yes	8.366	.7715	6.472
6C1-A	1000.0	Containment	E	Yes	46.5	.811	6.79
6C1-B	1000.0	Containment	P&O	No	251.	.0173	.088
6E1	1000.0	ECCS	all	—	7.87	.0004	.002
Totals	1000.0	—	all	Yes	305.37	.8287	6.880
6C2-A	2000.0	Containment	E	Yes	68.1	.833	6.96
6C2-B	2000.0	Containment	P&O	No	367.	.0258	.130
6E2	2000.0	ECCS	all	—	11.5	.0006	.003
Totals	2000.0	—	all	Yes	446.6	.8594	7.093

* E = elemental ; P = particulate ; O = organic

SARGENT & LUNDY
ENGINEERS

Client
Project
Equip. No. 7805-11

Calc. For
 Safety-Related
 Non-Safety-Related

Prepared by
Reviewed by
Approved by
Date
Date
Date

Calc. No. 21-5-91
Rev. 0
Page 76 of

Client _____
Project _____
Proj. No. 7805-11 Equip. No. _____

Prepared by _____ Date _____
Reviewed by _____ Date _____
Approved by _____ Date _____

TABLE 16

POSTDBA 30 Day Control Room Doses Using ICRP-30 Thyroid Dose Conversion Factors
Gap Inventory; Circuitous Path (30);

Case No.	Infiltration cfm	Leakage	Iodine Species #	Nobles	30 Day Thyroid, Rem	30 Day Whole Body, Rem	30 Day Beta Skin, Rem
8C0-A	0.0	Containment	E	Yes	.102	.00783	.0844
8C0-B	0.0	Containment	P&O	No	.574	.00016	.00009
8E0	0.0	ECCS	all	—	.0092	0	0
Totals	0.0	—	all	Yes	.6852	.007846	.08449
8C1-A	1000.0	Containment	E	Yes	3.73	.00808	.0861
8C1-B	1000.0	Containment	P&O	No	20.9	.000578	.00317
8E1	1000.0	ECCS	all	—	.336	.000008	.00004
Totals	1000.0	—	all	Yes	24.966	.008666	.08931
8C2-A	2000.0	Containment	E	Yes	5.45	.00821	.0869
8C2-B	2000.0	Containment	P&O	No	30.6	.000852	.00466
8E2	2000.0	ECCS	all	—	.491	.000012	.00006
Totals	2000.0	—	all	Yes	36.541	.009074	.09162

* E = elemental; P = particulate; O = organic

SARGENT & LUNDY
 ENGINEERS

Client

Project

Proj. No. 7805-11

Equip. No.

Calc. For

Safety-Related

Non-Safety-Related

Prepared by

Reviewed by

Approved by

Date

Date

Date

Calc. No. ZI-S-91

Rev. 0 Date

Page 78 of

TABLE 17

 POSTDBA 30 Day Control Room Doses Using
 Gap Inventory; Plan View ($\frac{1}{2}$); ICRP-30 Thyroid Dose Conversion Factors

Case No.	Infiltration, cfm	Leakage	Iodine Species*	Nobles	30 Day Thyroid, Rem	30 Day Whole Body, Rem	30 Day Beta Skin, Rem
7C0-A	0.0	Containment	E	Yes	.239	.0183	.198
7C0-B	0.0	Containment	P&O	No	1.34	.00004	.0002
7E0	0.0	ECCS	all	—	.0216	0	0
Totals	0.0	—	all	Yes	1.6006	.01834	.1982
7C1-A	1000.0	Containment	E	Yes	8.72	.0189	.202
7C1-B	1000.0	Containment	P&O	No	49.0	.00135	.0074
7E1	1000.0	ECCS	all	—	.786	.00002	.0001
Totals	1000.0	—	all	Yes	58.506	.02027	.2095
7C2-A	2000.0	Containment	E	Yes	12.8	.0192	.204
7C2-B	2000.0	Containment	P&O	No	71.6	.00199	.0109
7E2	2000.0	ECCS	all	—	1.15	.00003	.0002
Totals	2000.0	—	all	Yes	85.55	.02122	.2151

* E = elemental ; P = particulate ; O = organic

TABLE 18: Control Room Dose Summary Using Ref. 21 Thyroid Dose Conversion Factors

Infiltration Rate, Cfm	Control Room 30 Day Thyroid Dose, Rem for No Recirculation Filtration and Single Inlet							
	Model A		Model B					
	Core Inventory Plan View (1/2)		Core Inventory Circuitous Path (1/2)					
	R.G. 1.109 Thyroid Dose Conv.		R.G. 1.109 Thyroid Dose Conv.					
0	27.52	(27.58)	11.741	(11.79)	.9508	(.9529)	2.223	(2.230)
200	300.6		128.5		10.39		24.31	
400	524.0		224.0		18.11		42.38	
500	621.1		265.6		21.46		50.23	
600	710.2		303.6		24.54		57.43	
1000	1002.7		428.7		34.645		81.09	
1500	1269.		542.4		43.83		102.6	
2000	1462.6	(1465.)	627.3	(626.2)	50.65	(50.60)	118.59	(118.4)
Refs. 23 & 4 Limits	30.		30.		30.		30.	

Infiltration Rate, Cfm	Control Room 30 Day Whole Body Dose, Rem, for No Recirculation Filtration and Single Inlet			
	Model A	Model B	Model C	Model D
	0	1.811	.7715	.007846
200				
400				
500				
600				
1000	1.942	.8287	.008666	.02027
1500				
2000	2.012	.8594	.009074	.02122
Refs. 23 Limits	5.	5.	5.	5.

Infiltration Rate, Cfm	Control Room 30 Day Beta Skin Dose, Rem, for No Recirculation Filtration and Single Inlet			
	Model A	Model B	Model C	Model D
	0	15.21	6.472	.08449
200				
400				
500				
600				
1000	16.12	6.880	.08931	.2095
1500				
2000	16.62	7.093	.09162	.2151
Refs. 23 Limits	30.	30.	30.	30.

Form 00-432 Rev. 1



Client _____
 Project _____
 Proj. No. 7805-11 Equip. No. _____

Prepared by _____ Date _____
 Reviewed by _____ Date _____
 Approved by _____ Date _____

Calc. For _____
 Safety-Related Non-Safety-Related

Calc. No. ZI-5-91
 Rev. 0 Date _____
 Page 79 of _____

TABLE 19: Control Room Dose Summary Using Ref. 22 Thyroid Dose Conversion Factors

Infiltration Rate, cpm	Control Room 30 Day Thyroid Dose, Rem for No Recirculation Filtration and Single Inlet		Control Room 30 Day Whole Body Dose, Rem, for No Recirculation Filtration and Single Inlet	
	Model A	Model B	Model A	Model B
0	19.596 (19.68)	8.366 (8.399)	1.811	0.7715
200	214.5	91.55	1.941	0.8287
400	373.9	159.6	2.011	0.8594
500	443.2	189.2	5.	5.
600	506.7	216.3	5.	5.
1000	715.4	305.37	5.	5.
1500	905.1	386.4	5.	5.
2000	1047.0 (1045.)	446.6 (446.0)	5.	5.
Refs. 23 & 4 Limits			30.	30.

Infiltration Rate, cpm	Control Room 30 Day Beta Skin Dose, Rem, for No Recirculation Filtration and Single Inlet		Control Room 30 Day Thyroid Dose, Rem, for No Recirculation Filtration and Single Inlet	
	Model A	Model B	Model C	Model D
0	15.21	6.472	1.6006 (1.609)	17.54
200	16.11	6.880	17.54	30.57
400	16.61	7.093	30.57	36.24
500	30.	30.	36.24	41.44
600	30.	30.	41.44	58.506
1000	30.	30.	58.506	74.02
1500	30.	30.	74.02	85.55 (85.16)
2000	30.	30.	85.55	30.

Client: _____ Project: _____

Prepared by: _____ Date: _____

Reviewed by: _____ Date: _____

Calc. No. 21-5-91

Rev. 0 Date: _____



Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 81 of

Client
Project
Proj. No. 7805-11
Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Table 20 provides a calculation of infiltration rates that should produce a 30 day control room thyroid dose of 30 Rem* when using Reference 21 thyroid dose conversion factors for the various models, for various combinations of inlet configuration and iodine blockers use, and for various control room recirculation filter fractional efficiencies. This table was produced by evaluating the F_3 equation given in Section 7. The D_{1000} (dose for 1000 cpm infiltration) for each model came from Table 18. Values of η_2 were 0.0, 0.7, 0.9, and 0.99. The target dose D was obtained as follows.

Inlet		Blockers		D
Inlet Configuration	Protection † Factor (A)	Iodine Blockers	Protection Factor (B)	Target Dose, Rem (30 Rem) * (A) * (B)
Single	1.0	No	1.0	30.0
Single	1.0	Yes	10.0 Ref. 25	300.0
Dual (manually operated)	4.0 Ref. 3, page 6.4-11	No	1.0	120.0
Dual (manually operated)	4.0 Ref. 3, page 6.4-11	Yes	10.0 Ref. 25	1200.0

* 30 Rem limit from Reference 23 and Reference 4.
 † Protection comes from a reduction in (\sqrt{V}).

TABLE 20

Infiltration Rates to Obtain a 30 Day Control Room Thyroid Dose of 30 Rem (R.G. 1.109)

Using: SRP Occupancy, 11500 cfm Recirculation Rate; IPF Methodology Based on 1000 cfm Infiltrating and Zero Recirculation Filter Fractional Efficiency; Infiltration Rates Not Rounded Up

Model	Activity Inventory Source	Thyroid Contamination Factors (Ref. 21)	Inlet Configuration	Iodine Blockers	Infiltration Rate, cfm, for the Indicated Recirculation Filter Fractional Efficiencies			
					0.0	0.7	0.9	0.99
A	Core	R.G. 1.109 (Ref. 21)	Plan View	No	1.597	90.12	115.4	126.8
			Single	No	199.5	1182.	1462.	1589.
			Single	No	63.06	429.2	533.8	580.9
			Dual	Yes	1354.	7555.	9326.	10120.
B	Core	R.G. 1.109 (Ref. 21)	Single	No	28.52	238.6	298.7	325.7
			Single	Yes	590.0	333.7	4121.	4475.
			Dual	No	183.9	1095.	1356.	1473.
			Dual	Yes	∞	∞	∞	∞
C	Gap	R.G. 1.109 (Ref. 21)	Single	No	800.7	4499.	5556.	6032.
			Single	Yes	∞	∞	∞	∞
			Dual	No	∞	∞	∞	∞
			Dual	Yes	∞	∞	∞	∞
D	Gap	R.G. 1.109 (Ref. 21)	Single	No	2589	1509.	1867.	2028.
			Single	No	∞	∞	∞	∞
			Dual	No	2057.	11430.	14110	15310.
			Dual	Yes	∞	∞	∞	∞

Client	Project		Safety-Related		Non-Safety-Related	
	Proj. No. 7805-11		Equip. No.		Calc. No. ZI-S-91	
Prepared by	Date	Rev. 0	Date	Page 82	of	
Reviewed by	Date					
Approved by	Date					



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 83 of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Table 21 provides a calculation of infiltration rates that should produce a 30 day control room thyroid dose of 30 Rem* when using Reference 22 thyroid dose conversion factors for the various models, for various combinations of inlet configuration and iodine blocker use, and for various control room recirculation filter fractional efficiencies. This table was produced by evaluating the F_3 equation given in Section 7. The D_{1000} (dose for 1000 cfm infiltration) for each model came from Table 19. Values of η_2 were 0.0, 0.7, 0.9, and 0.99. The target dose D was obtained in the manner given on page 81.

* 30 Rem limit from Reference 23 and Reference 4.

TABLE 21

Infiltration Rates to Obtain a 30 Day Control Room Thyroid Dose of 30 Rem (ICRP-30)

Using: SRP Occupancy; 11500 cfm Recirculation Rate; IPF Methodology Based on 1000 cfm Infiltration and Zero Recirculation Filter Fractional Efficiency; Infiltration Rates Not Rounded Up

Model	Activity Inventory Source	(Yd) Model	Thyroid Comparison Factors	Intel Configuration	Iodine Blockers	Infiltration Rate, cfm, for the Indicated Recirculation Filter Fractional Efficiencies			
						0.0	0.7	0.9	0.99
						A	Core	Plan View	ICRP-30*
				Single	Yes	302.5	1750.	2164.	2350.
				Dual	No	97.73	620.5	769.9	837.1
				Dual	Yes	2767.	15350.	18940.	20560.
B	Core	Crosshairs	ICRP-30	Single	No	48.00	346.1	431.3	469.7
				Single	Yes	972.1	5445.	6723.	7298.
				Dual	No	279.0	1620.	2004.	2176.
				Dual	Yes	∞	∞	∞	∞
C	GRP	Circuitous	ICRP-30	Single	No	1364.	7609.	9394.	10190.
				Single	Yes	∞	∞	∞	∞
				Dual	No	∞	∞	∞	∞
				Dual	Yes	∞	∞	∞	∞
D	GRP	Plan View	ICRP-30	Single	No	390.3	2234.	2762.	2999.
				Single	Yes	∞	∞	∞	∞
				Dual	No	5207.	28810.	35550.	38590.
				Dual	Yes	∞	∞	∞	∞

* As reported in Reference 22, Table 2.1

Form 00-432 Rev. 1



Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91
Rev. 0 Date
Page 84 of

Client _____
 Project _____
 Proj. No. 7805-11 Equip. No. _____

Prepared by _____ Date _____
 Reviewed by _____ Date _____
 Approved by _____ Date _____

Table 22 provides a calculation of infiltration rates that should produce a 30 day control room thyroid dose of 50 Rem* when using Reference 22 thyroid dose conversion factors for the various models, for various combinations of inlet configuration and iodine blockers use, and for various control room recirculation filter fractional efficiencies. This table was produced by evaluating the F_3 equation given in Section 7. The D_{1000} (dose for 1000 cfm infiltration) for each model came from Table 19. Values of η_2 were 0.0, 0.7, 0.9, and 0.99. The target dose D was obtained as follows.

Inlet		Blockers		$D,$
Inlet Configuration	Protection† Factor (A)	Iodine Blockers	Protection Factor (B)	Target Dose, Rem (50 Rem) * (A) * (B)
Single	1.0	No	1.0	50.0
Single	1.0	Yes	10.0 Ref. 25	500.0
Dual (manually operated)	4.0 Ref. 3, page 6.4-11	No	1.0	200.0
Dual (manually operated)	4.0 Ref. 3, page 6.4-11	Yes	10.0 Ref. 25	2000.0

* 50 Rem limit from Reference 24.
 † Protection comes from a reduction in $(1/Q')$.

TABLE 22

Infiltration Rates to Obtain a 30 Day Control Room Thyroid Dose of 50 Rem (ICRP-30)

Using: SRP Occupancy; 11500 cfm Recirculation Rate; IPF Methodology Based on 1000 cfm Infiltration and Zero Recirculation Filter Fractional Efficiency; Infiltration Rates Not Rounded Up

Model	Activity Inventory Source	Thyroid Conversion Factors ICRP-30*	Inlet Configuration	Iodine Blocked	Fractional Efficiencies		
					0.0	0.7	0.9
A	Core	Plan View	Single	No	28.46	238.3	298.3
			Single	No	589.0	3331	4114
			Dual	No	183.6	1094	1354
			Dual	Yes	∞	∞	∞
B	Core	Circuits	Single	No	94.79	604.3	749.9
			Single	Yes	2603	14440	17820
			Dual	No	538.9	3054	3773
			Dual	Yes	∞	∞	∞
C	Gap	Circuits	Single	No	4754	26310	32470
			Single	Yes	∞	∞	∞
			Dual	No	∞	∞	∞
			Dual	Yes	∞	∞	∞
D	Gap	Plan View	Single	No	785.2	4414	5450
			Single	Yes	∞	∞	∞
			Dual	No	∞	∞	∞
			Dual	Yes	∞	∞	∞

* As reported in Reference 22, Table 2.1

SARGENT & LUNDY CHICAGO	Client	Prepared by	Date	Calc No ZI-5-91 Rev 0 Date RL
	Project	Reviewed by	Date	
Proj. No. 7805-11	Equip. No.	Approved by	Date	<input checked="" type="checkbox"/> Safety-Related Min. Calc.



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 87	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

9. SUMMARY

Control Room infiltration rates that produce thyroid inhalation doses equal to the regulatory limits for a variety of control room models were found. The results were summarized in Tables 20, 21, and 22.

Whole body and beta skin doses from airborne activity within the control room were also found. The results were summarized in Tables 18 and 19. These doses were less than the regulatory limits as indicated in these tables.

Calcs. For		Calc. No. ZI-5-91	
		Rev. 0	Date
		Page 88 of	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related		
Client		Prepared by	Date
Project		Reviewed by	Date
Proj. No. 7805-11	Equip. No.	Approved by	Date

10. REFERENCES

1. U.S. Nuclear Regulatory Commission, "Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss of Coolant Accident for Pressurized Water Reactors," USNRC Regulatory Guide 1.4, Rev. 2, June 1974.
2. U.S. Nuclear Regulatory Commission, Standard Review Plan, Section 6.5.2, "Containment Spray as a Fission Product Cleanup System," NUREG-0800, Rev. 2, December 1988.
3. U.S. Nuclear Regulatory Commission, Standard Review Plan, Section 6.4, "Control Room Habitability System," NUREG-0800, Rev. 2, July 1981.
4. K. G. Murphy and K. M. Campe, "Nuclear Power Plant Control Room Ventilation System Design for Meeting General Criterion 19," USNRC, 13th AEC Air Cleaning Conference, August 1974.
5. U.S. Nuclear Regulatory Commission, Standard Review Plan, Section 15.6.5, Appendix B, "Radiological Consequences of a Design Basis Loss-of-Coolant Accident: Leakage From Engineered Safety Feature Components Outside Containment," NUREG-0800, Rev. 1, July 1981.
6. Sargent & Lundy Program Number SPI 09.8.100-1.0, "Technological Bases For Models of Spray Washout of Airborne Contaminants in Containment Vessels SPIRT", From NUREG/CR-0009, October 1978.



Calc. For		Calc. No. ZI-5-91
		Rev. 0 Date
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related	Page 89 of

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. 7805-11 Equip. No.	Approved by	Date

7. R. S. Hubner, "A PWR Power Plant Dose after Design Basis Accident Code," User's Manual for POSTDBA, S & L Program Number 09.8.085-1.0, Oct. 12, 1978.
8. R. S. Hubner, "User's Manual for POSTDBA-Supplement for Modification No. 1 - A PWR Power Plant Dose After Design Basis Accident Code," Sargent & Lundy Program Number 09.8.085-1.1, August 25, 1980.
9. Zion UFSAR, Commonwealth Edison Company.
10. "Radiological Safety Technical Specifications for Zion Station Units 1 & 2", Appendix A, page 212, of Zion Operating License.
11. Zion FSAR, Commonwealth Edison Company.
12. Bill Meyer, Lechler, Inc., Fax Correspondence with Barry Schwartz (S&L), 3/27/91, attached as pages 96 through 100.
13. M. O. Sanford, "SPRAYCO Model 1713A Nozzle Spray Drop-Size Distribution," Westinghouse, WCAP-8258, Rev. 1, May 1975.
14. R. S. Hubner, "Control Room Doses from Inside Atmosphere after LOCA," Sargent & Lundy Calc. No. ZI-TMI-A1-5, Rev. 0, for Commonwealth Edison Company, September 5, 1980.

Form 00-3-08.1 Rev. 2 SL-F647 10-85 KPS



Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 90	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

15. John N. Hamawi, "Engineering Calculations Related to the Habitability of the Control Room Under Accident Conditions," ENTECH Engineering, Inc., P106-ECT, February 1982.
16. W.J. Adams, "Control Room Volume and Air Change Rate," Sargent & Lundy, DIT No. ZI-HVAC-0040-00, January 18, 1991.
17. J.S. Britis, "Calculation of Post-LOCA Iodine Spray Removal Rate," Sargent & Lundy Calc. No. ZI-3-86, Rev. 0, for Commonwealth Edison Company, January 8, 1987, and W.J. Johnson, Rev. 1 to that calculation, March 23, 1987.
18. J. T. Bell, M.H. Lietzke, and J.A. Palmer, "Predicted Rates of Formation of Iodine Hydrolysis Species at pH Levels, Concentrations, and Temperatures Anticipated in LWR Accidents," ORNL-5876, NUREG/CR-2900, October 1982.
19. Reactor Containment Ventilation Systems Functional Description, FD-RV-01, Rev. B, January 28, 1987.
20. M. J. Martin, Editor, "Nuclear Decay Data for Selected Radionuclides," Oak Ridge National Laboratory, ORNL-5114, March 1976.

Form GG-3.06.1 Rev. 2 BL-F847 10-85 KPS

Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. <i>ZI-5-91</i>
Rev. <i>0</i> Date
Page <i>91</i> of

Client
Project
Proj. No. <i>7805-11</i> Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

21. U. S. Nuclear Regulatory Commission, "Calculation of Annual Doses to Man From Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance With 10 CFR Part 50, Appendix I," U.S.N.R.C. Regulatory Guide 1.109, Revision 1, October 1977.
22. Federal Guidance Report No. 11, "Limiting Values of Radionuclide Intake and Air Concentration and Dose Conversion Factors for Inhalation, Submersion, and Ingestion," EPA-520/1-88-020, September 1988.
23. 10CFR 50, Appendix A, Criterion 19 of Group II - Control Room.
24. 10CFR 20.201, "Occupational Dose Limits for Adults," Effective January 1, 1993; SECY-90-387, "Transmittal of Revised Part 20", Nov. 26, 1990.
25. GSEP Environs Group Emergency Plan Implementing Procedure, Commonwealth Edison Company, "Use of Potassium Iodide Tablets by Emergency Workers" (Formerly EG-5), CEPJP 3005-1, Rev. 5, April, 1990, (Approved December 20, 1990).

Calc. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 92 of	

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

11. ATTACHMENTS

11.1 Microfiche A

ZI-5-91 RO SR NSLD 404-A1 SYS CR CNTRL RM INFILT STDY (SPIRT)
S&L 03/11/91 10:15:52 WG=212 ID=DRSH
ORIG=05 DUPS=01 PRJ=ZI0780511 PGM=SPID98100100/

SLIT THIS END



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 93	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

11.2 Microfiche B

ZI-5-91 R0 SR NSLD 404-A1 SYS CR CNTRL RM INFILT STDY(CLOUD)
S & L 03/11/91 10:26:56 WQ=212 ID=DRSH
ORIG=05 DUPS=01 PRJ=ZIO780511 PGM=POS098085110/

SLIT THIS END



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. ZI-5-91	
Rev. 0	Date
Page 94	of

Client	
Project	
Proj. No. 7805-11	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

11.3 Microfiche C

ZI-5-91 RO SR NSLD 4C4-A1 SYS CR CNTRL RM INFILT STDY (DOSE 1)
S&L 03/11/91 10:26:56 WG=212 ID=DRSH
ORIG=05 DUPS=01 PRJ=ZIO 780511 PGM=POS098085110/

SET THIS END



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc. No. <u>ZI-5-91</u>
Rev. <u>0</u> Date
Page <u>95</u> of

Client
Project
Proj. No. <u>7805-11</u> Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

11.4 Microfiche D

ZI-5-91 R0 SR NSLD 4C4-A1 SYS CR CNTRL RM INFILT STDY (DOSE 2)
S&L 03/11/91 10:26:56 WQ=212 ID=DRSH
ORIG=05 DUFS=01 PRJ=ZIO780511 PGM=POS098085110/

SLIT THIS END



FAX CORRESPONDENCE

Lechler Inc, 445 Kautz Rd, St. Charles, IL 60174
Phone 708-377-6611 Fax 708-377-6657
Send to Fax No. (312) 269-3680

Attention: BARRY SCHWARTZ Company: SARGENT & LUNDY

From: BILL MEYER Total Pages: 5 Date: 3-27-91

THE FOLLOWING PAGES OF THIS FAX SHOW FLOW RATE & DROPLET SIZE DATA FOR THE 1713 & 1713 A NOZZLES. AS YOU CAN SEE, THE PERFORMANCE IS ESSENTIALLY IDENTICAL.

THE MAIN DIFFERENCE BETWEEN THE 2 IS THAT THE 1713 WAS MANUFACTURED TO STANDARD COMMERCIAL SPECIFICATIONS & TOLERANCES WHILE THE 1713A IS MANUFACTURED TO THE MUCH TIGHTER NUCLEAR SPECIFICATIONS.

I HOPE THIS HELPS.

BEST REGARDS,

Bill Meyer

Calc. No. ZI-5-91
Rev. 0
Page 96
Proj. No. 7805-11
Safety-Related


R5431

RADC 28719


SPATIAL DROPLET SIZE DISTRIBUTION OF
SPRACO 171A NOZZLE APPLYING SURFACE
AREA CORRECTION AND SPRAYING WATER AT
40 PSIG UNDER LABORATORY CONDITIONS

NUMBER MEDIAN DIAMETER 250 μ m

SPRAY ENGINEERING CO.
BURLINGTON, MASS



1713A



* 373084.XX, BN (1713)

Calc. No. ZI-5-91 Rev. 0 page 98 Proj. No. 7805-11 Safety-Related

MEDIUM ANGLE

NOZZLE NO.	Female Conn. (Inches)	Orifice Diameter	FLOW RATE IN GALLONS PER MINUTE at POUNDS PER SQUARE INCH PRESSURES												Effective Angle at 2' Distance			WT. IN LBS.	DIMENSIONS (Inches)				
			5	7	10	15	20	25	30	40	50	75	100	5	15	50	A		B (Max)	C	D	E	
			1706	3/4	1/2	2.7	3.3	4.0	4.9	5.7	6.4	7.0	8.0	8.8	10.7	12.3	53°		67°	74°	4	2 1/2	1 1/2
1708	3/4	3/4	2.8	4.3	5.2	6.3	7.3	8.1	9.0	10.4	11.7	14.2	16.5	64°	71°	74°	4	2 1/2	1 1/2	1 1/2	1 1/2	3/4	
1710	3/4	1 1/4	4.4	5.2	6.2	7.7	8.9	10.0	10.9	12.5	13.9	16.9	19.5	69°	77°	74°	4	2 1/2	1 1/2	1 1/2	1 1/2	3/4	
1713	1	1/2	3.4	6.4	7.7	9.5	11.0	12.3	13.6	15.2	17.5	21.4	24.6	57°	60°	64°	7	2 1/2	1 1/2	2 1/2	1 1/2	3/4	
1717	1	3/4	6.6	7.6	9.2	11.2	13.1	14.7	16.1	18.6	20.9	25.7	29.7	62°	69°	67°	7	2 1/2	1 1/2	2 1/2	1 1/2	3/4	
1721	1	1 1/4	8.0	9.4	11.2	13.7	16.0	17.7	19.5	22.5	25.0	30.8	36.0	69°	78°	71°	7	2 1/2	1 1/2	2 1/2	1 1/2	3/4	
1723	1	1 1/4	9.0	10.8	13.2	16.2	18.5	20.8	22.8	26.5	29.6	36.0	41.5	77°	81°	78°	7	2 1/2	1 1/2	2 1/2	1 1/2	3/4	
1728	1 1/4	1 1/4	11.0	13.0	15.6	19.2	22.2	24.9	27.4	31.7	35.6	44.2	50.0	67°	74°	77°	13	3 1/2	1 1/2	2 1/2	2	3/4	
1730	1 1/4	1 1/4	12.7	15.0	18.0	22.5	26.2	29.3	32.4	37.5	42.0	51.3	59.4	64°	72°	72°	13	3 1/2	1 1/2	2 1/2	2	3/4	
1732	1 1/4	1 1/4	13.7	16.2	19.8	24.5	28.7	32.2	35.5	41.1	46.0	56.1	65.0	64°	72°	72°	13	3 1/2	1 1/2	2 1/2	2	3/4	
1736	1 1/4	1 1/2	17.7	20.5	24.5	30.3	35.5	40.0	44.2	51.7	57.7	69.0	78.2	78°	81°	81°	13	3 1/2	1 1/2	2 1/2	2	3/4	
1739	1 1/2	1 1/4	21.0	24.6	30.0	37.0	43.5	48.5	53.0	60.7	67.1	81.0	93.0	77°	81°	84°	20	3 1/2	2 1/2	3 1/2	2 1/2	3/4	
1741	1 1/2	1 1/2	23.0	27.6	33.6	42.3	49.3	55.0	60.0	68.5	76.2	93.0	108	78°	80°	80°	20	3 1/2	2 1/2	3 1/2	2 1/2	3/4	
1743	1 1/2	1 1/2	25.0	30.0	38.0	47.5	55.0	61.3	67.0	77.0	85.5	104	121	71°	75°	75°	20	3 1/2	2 1/2	3 1/2	2 1/2	3/4	
1746	2	1 1/2	31.5	37.0	44.0	54.0	62.0	69.0	75.0	87.0	97.0	118	135	62°	66°	66°	28	4 1/2	2 1/2	3 1/2	2 1/2	3/4	
1748	2	1 1/2	34.0	43.0	53.0	64.5	74.0	82.0	89.5	103	115	141	163	71°	74°	74°	28	4 1/2	2 1/2	3 1/2	2 1/2	3/4	
1751	2	1 1/2	45.0	53.0	63.5	79.0	90.5	101	110	126	141	174	202	77°	80°	82°	28	4 1/2	2 1/2	3 1/2	2 1/2	3/4	
1753	2	1 3/4	50.0	60.0	72.0	89.0	103	115	125	143	161	195	225	80°	91°	80°	28	4 1/2	2 1/2	3 1/2	2 1/2	3/4	
1755	2 1/2	1 1/2	63.0	72.0	86.0	104	120	134	148	173	193	237	275	72°	74°	74°	45	5 1/2	3 1/2	5 1/2	3 1/2	3/4	
1757	2 1/2	1 3/4	65.0	78.0	93.0	114	132	147	160	185	207	252	290	78°	80°	80°	45	5 1/2	3 1/2	5 1/2	3 1/2	3/4	
1759	2 1/2	1 3/4	75.0	88.0	107	130	150	166	181	208	232	280	320	78°	80°	80°	45	5 1/2	3 1/2	5 1/2	3 1/2	3/4	
1761	2 1/2	1 3/4	83.0	100	120	145	166	184	200	229	255	312	360	78°	80°	80°	45	5 1/2	3 1/2	5 1/2	3 1/2	3/4	

MEDIUM ANGLE

NOZZLE NO.	FEMALE CONN. (Inches)	Orifice Diameter	FLOW RATE IN GALLONS PER MINUTE at POUNDS PER SQUARE INCH PRESSURES												Effective Angle at 2' Distance			WT. IN LBS.	DIMENSIONS (Inches)				
			2	3	4	5	7	10	15	20	40	60	3	7	15	A	B		C	D	E		
			1763	3	1 1/4	44	53	61	68	80	94	114	132	183	220	53°	58°		60°	10.0	6 1/2	4	4 1/2
1764	3	1 1/2	56	67	77	86	100	119	144	165	230	278	60°	64°	65°	10.0	6 1/2	4	4 1/2	4 1/2	1 1/2		
1765	3	1 3/4	67	80	93	103	120	143	173	198	277	335	60°	64°	65°	10.0	6 1/2	4	4 1/2	4 1/2	1 1/2		
1767	3	2 1/4	78	94	108	120	140	166	202	232	320	388	65°	70°	75°	10.0	6 1/2	4	4 1/2	4 1/2	1 1/2		
1768	3	2 3/4	84	101	115	128	150	178	215	246	341	413	68°	74°	75°	10.0	6 1/2	4	4 1/2	4 1/2	1 1/2		
1771	4	2 1/4	84	101	115	128	150	178	215	246	341	413	62°	65°	67°	32.3	8 1/2	5	7 1/2	5 1/2	1 1/2		
1772	4	2 1/2	98	117	135	150	175	207	250	285	395	480	69°	72°	76°	32.3	8 1/2	5	7 1/2	5 1/2	1 1/2		
1774	4	2 1/2	112	135	154	171	200	236	285	328	450	545	74°	78°	80°	32.3	8 1/2	5	7 1/2	5 1/2	1 1/2		
1775	4	2 3/4	127	152	174	194	225	266	322	368	508	615	76°	80°	82°	32.3	8 1/2	5	7 1/2	5 1/2	1 1/2		
1777	4	2 3/4	137	165	188	208	245	287	348	399	550	662	78°	81°	85°	32.3	8 1/2	5	7 1/2	5 1/2	1 1/2		
1778	4	3 1/4	167	201	230	255	300	353	428	490	680	820	80°	83°	87°	32.3	8 1/2	5	7 1/2	5 1/2	1 1/2		

NARROW ANGLE

1763N	3	1 1/4	44	53	61	68	80	94	114	132	183	220	43°	45°	46°	11.0	6 1/2	4	6 1/2	4 1/2	1 1/2
1764N	3	1 1/2	56	67	77	86	100	119	144	165	230	278	39°	45°	48°	11.0	6 1/2	4	6 1/2	4 1/2	1 1/2
1765N	3	1 3/4	67	80	93	103	120	143	173	198	277	335	42°	45°	46°	11.0	6 1/2	4	6 1/2	4 1/2	1 1/2
1767N	3	2 1/4	78	94	108	120	140	166	202	232	320	388	39°	45°	48°	11.0	6 1/2	4	6 1/2	4 1/2	1 1/2
1768N	3	2 3/4	84	101	115	128	150	178	215	246	341	413	37°	45°	48°	11.0	6 1/2	4	6 1/2	4 1/2	1 1/2
1771N	4	2 1/4	84	101	115	128	150	178	215	246	341	413	40°	45°	46°	35.6	8 1/2	5	9 1/2	5 1/2	1 1/2
1772N	4	2 1/2	98	117	135	150	175	207	250	285	395	480	39°	45°	50°	35.6	8 1/2	5	9 1/2	5 1/2	1 1/2
1774N	4	2 1/2	112	135	154	171	200	236	285	328	450	545	39°	45°	50°	35.6	8 1/2	5	9 1/2	5 1/2	1 1/2
1775N	4	2 3/4	127	152	174	194	225	266	322	368	508	615	39°	45°	49°	35.6	8 1/2	5	9 1/2	5 1/2	1 1/2
1777N	4	2 3/4	137	165	188	208	245	287	348	399	550	662	39°	45°	48°	35.6	8 1/2	5	9 1/2	5 1/2	1 1/2
1778N	4	3 1/4	167	201	230	255	300	353	428	490	680	820	39°	45°	47°	35.6	8 1/2	5	9 1/2	5 1/2	1 1/2

See following page for spray coverage data

Calc. No. ZI-5-91 Rev. 0 Page 100 Proj. No. 7805-11 Safety-Related

3-piece medium and narrow angle amp atom nozzles

ing dust n which

WT. in Lbs.	
.015	
.035	
.035	
.035	

REVIEW METHOD SHEET

Calc. No. ZI-5-91
 Revision 0
 Page 101, LAST of Rev. 0
 Proj. No. 2805-11
 Safety-Related

This calculation has been reviewed by me according to the method(s) checked below.

1. Computer Aided Calculations

a	<input checked="" type="checkbox"/>	Review to determine that the computer program(s) has been validated and documented, is suitable to the problem being analyzed, and that the calculation contains all necessary information for reconstruction at a later date.
b	<input type="checkbox"/>	Review to determine that the input data as specified for program execution is consistent with the design input, correctly defines the problem for the computer algorithm and is sufficiently accurate to produce results within any numerical limitations of the program.
c	<input checked="" type="checkbox"/>	Review to verify that the results obtained from the program are correct and within stated assumptions and limitations of the program and are consistent with the input.
d	<input type="checkbox"/>	Review validation documentation for temporary changes to listed, or developmental, or unique single application programs, to assure that methods used adequately validate the program for the intended application.
e	<input checked="" type="checkbox"/>	Review of code input only, since the computer program has sufficient history of use at Sargent & Lundy in similar calculations.
f	<input checked="" type="checkbox"/>	Review arithmetic necessary to prepare code input data.
g	<input type="checkbox"/>	Other: <hr/>

2. Hand Prepared Design Calculations


a	<input checked="" type="checkbox"/>	Detailed review of the original calculations.
b	<input type="checkbox"/>	Review by an alternate, simplified, or approximate method of calculation.
c	<input type="checkbox"/>	Review of a representative sample of repetitive calculations.
d	<input type="checkbox"/>	Review of the calculation against a similar calculation previously performed.

3. Revisions

a	<input type="checkbox"/>	Editorial changes only.
b	<input type="checkbox"/>	Elimination of unapproved input data without altering calculated results.
c	<input type="checkbox"/>	Other: <hr/>

4. Other

<input type="checkbox"/>	<hr/>
--------------------------	-------

Reviewer:  Date: 4/10/91