

Duke Power Company
Catawba Nuclear Generation Department
4800 Concord Road
York, SC 29745

D. L. REHN
Vice President
(803)831-3205 Office
(803)831-3426 Fax



DUKE POWER

June 13, 1994

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Subject: Catawba Nuclear Station, Unit 2
Docket No. 50-414
Special Report
End of Cycle 6 Refueling Outage
15 Day Steam Generator Tube Inservice Inspection Report

Pursuant to Catawba Technical Specification 4.4.5.5 part a, the following information is submitted:

The following quantities of tubes were removed from service by plugging:

<u>Steam Generator</u>	<u>Number of Tubes Plugged</u>
A	6
B	11
C	5
D	9

For further information, please contact Kay E. Nicholson at (803) 831-3237.

Very truly yours,

D. L. Rehn

KEN\2SG15DAY.694

xc: S. D. Ebnetter, Regional Administrator
R. E. Martin, ONRR
R. J. Freudenberger, SRI

210885
9406220294 940613
PDR ADDCK 05000414
Q PDR

AD47/0