



Monday, June 6, 1994

Marvin M. Mendonca  
Senior Project Manager  
U.S. Nuclear Regulatory Commission  
MS OWFN 11-B-20  
Washington, D.C. 20555

Ref: Docket 50-27

Dear Mr. Mendonca:

In a telephone conversation with Daniel Westall on June 6, 1994 it was decided that one of the proposed changes for Amendment No. 15 on page 35 of our Technical Specifications would conflict with 10 CFR 20.2202(d)(2) which requires both a telephone call **and** a FAX in the reporting requirements. We therefore are removing this item from our list of requested changes.

Amendment No. 15 should therefore include only the following items:

Proposed Changes:

Page	Change
12	"Scram if power level exceeds 1100 kW" to "Scram if power level exceeds 125% of full licensed power"
35	In section 6.10, <u>Reporting Requirements</u> , (2): change "A report within 10 days in writing to the Director, Office of Nuclear Reactor Regulation USNRC, Washington, D.C. 20555, with a copy to the Regional Administrator, USNRC, Regional V Office, of" to "A report within 10 days in writing to the Director, Office of Nuclear Reactor Regulation USNRC, Washington, D.C. 20555, with a copy to the Regional Administrator of the appropriate USNRC Regional Office, of"

210001

A030 1/0


In section 6.10, Reporting Requirements, (3): change

"A report within 30 days in writing to the Director, Office of Nuclear Reactor Regulation, USNRC, Washington, D.C. 20555, with a copy to the Regional Administrator, USNRC, Regional V Office, of" to

"A report within 30 days in writing to the Director, Office of Nuclear Reactor Regulation, USNRC, Washington, D.C. 20555, with a copy to the Regional Administrator of the appropriate USNRC Regional Office, of"

If you have any questions, please contact Dr. Gerald Tripard, Facility Director (509) 335-0172

Sincerely,



Gerald E. Tripard  
Director



M. Howard Miles  
Chair, Reactor Safeguards Committee

cc: Document control Desk, U.S. Nuclear Regulatory Commission  
Region IV NRC office