

TABLE 4.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

| FUNCTIONAL UNIT | CHANNEL CHECK | CHANNEL CALIBRATION | CHANNEL FUNCTIONAL TEST | MODES IN WHICH SURVEILLANCE REQUIRED |
|--|---------------|---------------------|---------------------------------|--------------------------------------|
| 13. Steam Generator Water Level--Low-Low | S | R | Q | 1, 2 |
| 14. Deleted | | | | |
| 15. Undervoltage - Reactor Coolant Pumps | N.A. | R | Q | 1 |
| 16. Underfrequency - Reactor Coolant Pumps | N.A. | R | Q | 1 |
| 17. Turbine Trip A. Low Auto Stop Oil Pressure B. Turbine Throttle Valve Closure | N.A. N.A. | R R | S/U(9)(10) S/U(9)(10) | N.A. N.A. |
| 18. Safety Injection Input from ESF | N.A. | N.A. | R(4) | 1, 2 |
| 19. Reactor Coolant Pump Breaker Position Trip | N.A. | N.A. | R | 1 |
| 20. Reactor Trip System Interlocks | N.A. | R | S/U(8) | 1 |
| 21. Reactor Trip Breaker | N.A. | N.A. | M(5)(14)(15), S/U(1)(14)(15) | 1, 2, 3*, 4*, 5* |
| 22. Automatic Trip Logic | N.A. | N.A. | M(5) | 1, 2, 3*, 4*, 5* |
| 23. Reactor Trip Bypass Breaker | N.A. | N.A. | (13), R(11) | 1, 2, 3*, 4*, 5* |

9406230109 940617
PDR ADDCK 05000348
PDR

FARLEY-UNIT 1

3/4 3-13

Corrected by letter dated June 17, 1994

AMENDMENT NO.
26, 67, 104, 107

TABLE 4.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

| FUNCTIONAL UNIT | CHANNEL CHECK | CHANNEL CALIBRATION | CHANNEL FUNCTIONAL TEST | MODES IN WHICH SURVEILLANCE REQUIRED |
|--|---------------|---------------------|---------------------------------|--------------------------------------|
| 13. Steam Generator Water Level--Low-Low | S | R | Q | 1, 2 |
| 14. Steam/Feedwater Flow Mismatch and Low Steam Generator Water Level* | S | R | Q | 1, 2 |
| 15. Undervoltage - Reactor Coolant Pumps | N.A. | R | Q | 1 |
| 16. Underfrequency - Reactor Coolant Pumps | N.A. | R | Q | 1 |
| 17. Turbine Trip | | | | |
| A. Low Auto Stop Oil Pressure | N.A. | R | S/U(9)(10) | N.A. |
| B. Turbine Throttle Valve Closure | N.A. | R | S/U(9)(10) | N.A. |
| 18. Safety Injection Input from ESF | N.A. | N.A. | R(4) | 1, 2 |
| 19. Reactor Coolant Pump Breaker Position Trip | N.A. | N.A. | R | 1 |
| 20. Reactor Trip System Interlocks | N.A. | R | S/U(8) | 1 |
| 21. Reactor Trip Breaker | N.A. | N.A. | M(5)(14)(15), S/U(1)(14)(15) | 1, 2, 3*, 4*, 5* |
| 22. Automatic Trip Logic | N.A. | N.A. | M(5) | 1, 2, 3*, 4*, 5* |
| 23. Reactor Trip Bypass Breaker | N.A. | N.A. | (13), R(11) | 1, 2, 3*, 4*, 5* |

* Deletion of this functional trip shall be implemented prior to startup from refueling outage 12.

FARLEY-UNIT 2

3/4 3-13

Corrected by letter dated June 17, 1994

AMENDMENT NO.
89,97,99