



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

DOD-016

NOV 23 1982

Docket No. 50-289

FACILITY: Three Mile Island, Unit No. 1 (TMI-1)  
LICENSEE: GPU Nuclear Corporation (GPUN)  
SUBJECT: SUMMARY OF MEETING WITH GPUN ON OCTOBER 18 AND 19 CONCERNING  
GPUN'S TMI-1 STEAM GENERATOR RECOVERY PROGRAM

Background

The purpose of the October 18 and 19, 1982 meeting was to update the staff and their consultants on the status of programs underway to repair and requalify the TMI-1 OTSGs for service. In Mid-October, GPUN commenced an explosive expansion repair procedure to recover tubes with defects within the upper tubesheet (UTS). Other programs underway involve a steam generator eddy current test (ECT) program, plant performance analysis, RCS cleanup, corrosion test program, and steam generator post repair testing.

Discussion

Repair Qualification Update

GPUN described additional repair procedure qualification program results which recently became available. In general, leakage tests on qualification blocks have shown low leakage as expected. Some data available from Penn State on hardness data of the expanded joint reveals that residual stress created by the expansion process should not be of major concern. Although, the production repair procedure on the steam generator had not yet commenced at the time of this meeting, it is now well underway.

Eddy Current Testing (ECT)

GPUN described final ECT results based on their program of 100% full length testing using the standard differential .540" probe. The results indicate that of the ~31,000 tubes, 868 have defects in locations not recoverable by the repair procedure in the 'A' OTSG and 278 in the 'B' OTSG. These tubes will require plugging. Of these about 250 had previously been plugged. From the ECT results described above, 76 tubes in the freespan area have been identified which have defects <40% through wall. These defects are also of small circumferential length. GPUN is proposing to leave these tubes in service. The advantage is that these tubes would serve as a data base to verify that the corrosion does not continue to propagate during operation or shutdown.

RCS Cleanup

Testing of methods to remove sulfur from the tube and possibly other RCS surfaces is in the early stages but GPUN described the preliminary results as encouraging. Tests have been conducted at various pH levels using

8212060508 821123  
PDR ADCK 05000289  
P PDR

hydrogen peroxide as an additive. Hydrogen peroxide reacts with NiS (the sulfur form on the tube surface) to form sulfate ( $SO_4$ ) which can be removed by ion exchange. A great deal of testing and analysis remains to be performed before a decision is made whether or not to conduct the sulfur cleanup. The cleanup, if conducted, would require RCP operation and hence, could not be conducted until the steam generators are repaired.

#### Corrosion Test Program

GPUN described an extensive corrosion test program which has been ongoing since the beginning of the steam generator recovery program. Corrosion testing has been conducted to 1) assess if the primary coolant was still aggressive, 2) to attempt to simulate the tube cracking to verify the failure mechanism and corrosion scenario and 3) to support the repair qualification program. GPUN is also conducting a long term testing program designed to duplicate plant hot functional testing and operation. This corrosion program will lead actual plant operation by several months and should provide important insight into actual plant performance.

#### Post Repair Test Program

GPUN outlined a post steam generator repair program which would include eddy current testing of a baseline number of tubes, cold leak testing including a  $N_2$  bubble test and primary plant hydrostatic test and precritical operational tests. The precritical tests will involve several cooldown transients to place tubes under high tension, followed by leak rate monitoring. Following steam generator testing, the plant would proceed with hot functional testing for restart modification testing and then enter the restart sequence, assuming restart is authorized. GPUN also proposed operating for 90 days at full power before conducting a shutdown to conduct additional OTSG ECT. The staff expressed some reservations about not conducting an ECT following hot steam generator testing but before criticality. Staff consultants in general felt that more risk of corrosion propagation, if it propagates, would occur if the system were exposed to air during an ECT test than if the system were not reexposed to air. It was also pointed out that the cracks tend to propagate during low temperature, oxidizing environments while the plant operates at high temperature, reducing environments. This issue will be pursued further as staff review continues.

#### Plant Performance Analysis

GPUN has reexamined design basis accident analyses to determine what impact the repaired steam generators would have on plant performance. They have concluded that the repaired steam generators will have no effect on FSAR conclusions even assuming up to 1500 tubes are plugged. The staff asked that GPUN also address the impact, if any, on steam generator overfill transients and to verify that the effectiveness of EFW will not be significantly degraded due to tube plugging in the periphery of the tube bundle.

GPUN indicated that they would be forwarding in November, a Safety Analysis addressing the above issues in detail.

**"ORIGINAL SIGNED BY:"**

Richard H. Jacobs, Project Manager  
Operating Reactors Branch #4  
Division of Licensing

Enclosures:

- 1. List of Attendees
- 2. GPUN Mtg. Presentation Material

cc w/enclosures:  
See next page

OFFICE ▶	ORB #4: DL						
SURNAME ▶	R Jacobs / cab						
DATE ▶	11/5/82						

ORB#4:DL

MEETING SUMMARY DISTRIBUTION

Licensee: GPJN

\* Copies also sent to those people on service (cc) list for subject plant(s).

Docket File  
NRC PDR  
L PDR  
ORB#4 Rdg  
GLainas  
JStolz  
Project Manager-JVan Vliet, RJacobs  
Licensing Assistant-RIngram  
OELD  
Heltemes, AEOD  
IE  
SChowe (PWR) or CThayer (BWR), IE  
Meeting Summary File-ORB#4  
RFraley, ACRS-10  
Program Support Branch


ORAB, Rm. 542  
BGrimes, DEP  
SSchwartz, DEP  
SRamos, EPDB  
FPagano, EPLB

Meeting Participants Fm. NRC:

CMcCracken	HConrad
EBrown	CSellers
PWu	VBenaroya
LFrank	SKirslis
JRajan	CCheng
WJensen	SYoung
	PGrant



GPUN indicated that they would be forwarding in November, a Safety Analysis addressing the above issues in detail.



Richard H. Jacobs, Project Manager  
Operating Reactors Branch #4  
Division of Licensing

Enclosures:

1. List of Attendees
2. GPUN Mtg. Presentation Material

cc w/enclosures:

See next page

LIST OF ATTENDEES

GPUN/NRC October 18-19, 1982

NRC

C. McCracken  
 R. Jacobs  
 E. Brown  
 J. Van Vliet  
 P. Wu  
 L. Frank  
 H. Conrad  
 C. Sellers  
 V. Benaroya  
 S. Kirsulis  
 C. Cheng  
 J. Rajan  
 W. Jensen  
 S. Young, TMI Site, Reg. I  
 P. Grant, TMI Site, TMIPO

NRC Consultants

L. Leonard, FRC  
 T. Shook, FRC  
 V. Luk, FRC  
 C. Davey, FRC  
 S. Pandey, FRC  
 C. Dodd, ORNL  
 J. Weeks, BNL  
 D. Macdonald, Ohio State LL

GPUN

R. Wilson  
 D. Slear  
 E. Wallace  
 P. Walsh  
 S. Giacobbe  
 M. J. Graham  
 R. Neidig  
 R. Barley  
 N. Kazanas  
 G. Rhedvick  
 S. Leshnoff  
 N. Trikouros

GPUN Consultants

R. Baker, B&W  
 S. Weems, MPL  
 W. Greenoway, NUS

OTHERS

S. Maingi, Pa. BRP

**GPU Nuclear**

**TMI-1 OTSG**

**Repair Process Update  
and  
Return to Service  
Overview**

**October 18/19, 1982**

# **NRC OTSG Update**


**10/18/82**

- |  |                   |
|--|-------------------|
| <b>I. Qualification Program Update</b>                       | <b>D. Slear</b>   |
| <b>II. Final Eddy Current Test Results</b>                   | <b>N. Kazanas</b> |
| <b>III. Return to Service Safety<br/>Evaluation Overview</b> | <b>P. Walsh</b>   |
| <b>IV. Interpretation of ECT Results</b>                     | <b>D. Slear</b>   |


**10/19/82**

- |   |                     |
|---|---------------------|
| <b>IV. Plant Performance Analysis<br/>with Plugging</b>   | <b>N. Trikorous</b> |
| <b>VI. Sulfur Removal Test Program<br/>Status</b>         | <b>W. Greenaway</b> |
| <b>VII. Corrosion Test Program</b>                        | <b>S. Giacobbe</b>  |
| <b>VIII. Steam Generator Post Repair<br/>Test Program</b> | <b>P. Walsh</b>     |

## PULLOUT LOAD QUALIFICATION & PREQUALIFICATION DATA



## PULLOUT STRAIN QUALIFICATION DATA



10/18/82



Qualification Program Test Blocks

TEST PROGRAM BLOCK										
	THERMAL CYCLING	AFTER HITS	AXIAL LOAD	LEAKAGE (S-P 1275 psi)	LEAKAGE (P-S 1275 psi)	LEAKAGE (S-P 125 psi)	LEAKAGE (P-S 2500 psi N <sub>2</sub> )	PULLOUT (70°F)	PULLOUT (300-400°F)	LEAKAGE (300-400°F)
A	✓	✓			✓			✓		
B								✓		
C	✓				✓			✓		
D	✓				✓			✓		✓
E	✓				✓			✓		
G	✓				✓				✓	
H	✓				✓		✓	✓		
SP-1	✓		✓	✓						



# LEAK RATE DATA

## QUALIFICATION PROGRAM 10 TUBE TEST BLOCKS




10/18/82

# Comparison of Rockwell Hardness

Rockwell "C"  
Effective Range 70-20




Rockwell "B"  
Effective Range 100-0





Tube Region Tested

Unexpanded	Transition	Expanded
------------	------------	----------




# Unexpanded Portion Of Tubes





Unexpanded

**Roller Expanded Tube  
Transition Zone**




**Kinetically Expanded Tube  
Transition Zone**




**Transition**

**Roller Expanded Tube  
Away From Transition Area**




**Kinetically Expanded Tube  
Away From Transition Area**



**Expanded**

# IMMUNOL APPLICATION



10/18/82



# SUMMARY OTSG ECT PROGRAM








Figure V-2

### OTSG TUBING DEFECT MOCKUPS



### FILL FACTOR COMPARISON\*





Figure V-3

### GAIN COMPARISON FOR DETECTION PROBABILITY

- Standard  
Differential  
100 MV/Div.
1. .540, 50+RA, 400KHZ
  2. .540, 45+RA, 400KHZ
  3. .540, 40+RA, 400KHZ
  4. .540, 35+RA, 400KHZ
  5. .510, 35+RA, 400KHZ




Note: Response 0.300 Volts  
Min. Sensitivity  
Field Conditions

Figure V-7

### OPTIMIZING FREQUENCY MIX


- Standard  
Differential  
540.45 + RA
1. ID MIX (ONLY)  
(400 - 200) 800 KHz
  2. 400 KHz



RESPONSE 0.300 VOLTS  
MIN. SENSITIVITY

Figure V-9

**AMPLITUDE RESPONSE  
STANDARD DIFFERENTIAL VS 8x1 ABSOLUTE  
SIMULATED DEFECTS 0.005" WIDE**





RESULT CONCLUSIONS

STANDARD DIFFERENTIAL

	<u>FILL FACTOR</u>	<u>GAIN</u>	<u>FREQUENCY</u>	<u>MAGNETIC SATURATION</u>	<u>CHART SENSITIVITY</u>
OPTIMIZED PARAMETERS	.540 PROBE	60 - 65	400 KHZ BASE	PERMANENT MAGNET AFFIXED	100 MV/DIV
BENEFITS	REDUCED PROBE CHATTER (NOISE)	INCREASED SENSITIVITY	ID MIX FOR TSP	REDUCED PERMEABILITY SIGNALS	INCREASED ANALYST'S ABILITY FOR INTERPRETATION FROM S.C.R.
		SMALLER DEFECTS DETECTED (40% THRU WALL 0.060" CIRCUMFERENCE)	ID MIX TO REDUCE NOISE		
			200 } 400 } COMBINED 800 MIX		
	INCREASED RELIABILITY IN REPEATED RESULTS				

ABSOLUTE

	<u>COIL COVERAGE</u>	<u>GAIN</u>	<u>FREQUENCY</u>	<u>MAGNETIC SATURATION</u>	<u>CHART SENSITIVITY</u>
OPTIMIZED PARAMETERS	8 COILS	40 - 53	380 - 420	NOT ADAPTABLE FOR PERMANENT MAGNET	100 MV/DIV
BENEFITS	INCREASED TO 360° COVERAGE	HIGH RESPONSE SIGNAL	MINIMIZED RESONANCE AND CROSS TALK BETWEEN COILS		INCREASE ANALYST ABILITY FOR INTERPRETATION FROM S.C.R.
		WELL ABOVE NOISE			

## Recognized Characteristics

<u>S.D.</u>		<u>Absolute</u>	
<u>Advantages</u>	<u>Disadvantages</u>	<u>Advantages</u>	<u>Disadvantages</u>
● Durability	● Poor in expanded areas	● Expanded areas	● Poor durability
● Reliable percentage thru-wall calls	● Overly sensitive to some surface anomalies	● High response signals	● Coil to coil variation for response amplitude
● 360° Coverage	● Low voltage response	● Not overly sensitive to surface	● Unreliable percentage thru-wall calls
● Maintenance and analysis of data well established		● Signal distortion minimal (probe design)	● Maintenance of data analysis

## **Recommendation for Production Examination**

### **I. S.D. 540 hi-gain most suitable for full production testing.**

#### **A) Why?**

- 1. Excellent durability**
- 2. Reliable percentage thru-wall calls**
- 3. Maintenance and analysis of data well understood**
- 4. Expanded area of tubes was not a factor**

#### **B) Recognized limitations can be resolved by second method**

- 1. Over sensitivity to surface anomalies can be resolved by absolute**
- 2. Low amplitude signals can be interrogated by absolute**

### **II. Absolute as a dispositioning instrument.**


#### **A) Why not for production?**

- 1. Poor durability (0 to 100 tube coverage)**
- 2. Unreliable percentage thru-wall calls**


#### **B) Why as a support technique?**

- 1. Excellent support to S.D. limitations**
  - a. Surface anomalies**
  - b. Low amplitude**
- 2. Signal distortion is minimal**

FLOW CHART ON GPUN ECT PROGRAM  
FOR DISPOSITIONING OTSG TUBES



# EDDY CURRENT METALLOGRAPHY SUMMARY



S.D. BELOW ROLL TRANSITION  
METALLURGICAL CORRELATION

<u>GEN.</u>	<u>TUBES IN SAMPLE</u>	<u>NO. INDICATION REPORTED BY E/C</u>	<u>CONFIRMED INDICATIONS BY E/C</u>	<u>MISCALLS</u>	<u>OVERCALLS</u>
A	12	23	23	0	0
B	<u>3</u>	<u>5</u>	<u>5</u>	<u>0</u>	<u>0</u>
	15	28	28	0	1

NO. INDICATIONS  
REPORTED BY E/C      28

OVERCALL              - 0

                                 28

CONFIRMED  
INDICATION BY  
METALLOGRAPHY      28

MISCALLS              0

                                 28

15 TUBE SAMPLE

100% AGREEMENT  
S.D.



ABSOLUTE METALLURGICAL CORRELATION

Below .25" From Top of Tube

<u>GEN.</u>	<u>TUBES IN SAMPLE</u>	<u>NO. INDICATIONS REPORTED BY E/C</u>	<u>CONFIRMED INDICATIONS BY METALLOGRAPHY</u>	<u>MISCALL BY E/C</u>	<u>OVERCALLS BY E/C</u>
A	16	25	22*	2	3
B	<u>2</u>	<u>2</u>	<u>2</u>	<u>0</u>	<u>0</u>
	18	27	24	2	3

NO INDICATIONS REPORTED BY E/C      27

OVERCALLS                      - 3

    24

CONFIRMED INDICATIONS BY METALLOGRAPHY      24

MISCALLS                                      + 2

    26

18 TUBE SAMPLE (INCLUDING ROLL TRANSITION)

18 TUBE SAMPLE (EXCLUDING ROLL TRANSITION)


92% AGREEMENT ABSOLUTE

100% AGREEMENT

\* - Work performed with 4x1

ASPECT RATIO COMPARISON

METALLOGRAPHY ACTUAL CIRCUMFERENTIAL DEFECTS  
E/C SYNTHETIC DEFECTS ORIENTED IN WORST GEOMETRY



LAB INDUCED CRACKS

o 8 SAMPLES TESTED

o HIGH GAIN SD TECHNIQUE

- REPORTED INDICATIONS 7\*

\* 5 SAMPLES WERE WITH 540 HIGH GAIN

- CONFIRMED BY METALLOGRAPHY 5

o ABSOLUTE TECHNIQUE

- REPORTED INDICATIONS 5

- CONFIRMED BY METALLOGRAPHY 5

o USING GPUN RECOMMENDED ECT PROGRAM

8 SAMPLES TESTED

- NO. DISPOSITIONED AS ACCEPTABLE 4


METALLOGRAPHY CONFIRMATION 100%  
(includes two samples with <40% thru wall)

- NO. DISPOSITIONED REJECT 4


METALLOGRAPHY CONFIRMATION 100%

v

# LOWEST DEFECT BY ELEVATION



PLANT RETURN TO SERVICE SAFETY EVALUATION OVERVIEW



FAILURE MECHANISM ADEQUATELY UNDERSTOOD

- METALLURGICAL TEST RESULTS
  - STRESS ASSISTED INTERGRANULAR CORROSION
  - INITIATED FROM TUBE INSIDE SURFACE
  - SULFUR PRESENT ON FRACTURE SURFACES
  - SENSITIZED TUBING MATERIAL
  
- CORROSION TEST RESULTS
  - THIOSULFATE CAN PRODUCE SIMILAR CRACKING
  - AN OXIDIZING POTENTIAL IS REQUIRED
  - TUBING MATERIAL PROPERTIES HAVE STRONG EFFECT ON CRACKING SUSCEPTIBILITY
  - CRACK GROWTH RATES ARE RAPID

PREVENT RECURRENCE

- PROGRAM UNDER DEVELOPMENT TO OXIDIZE AND/OR REMOVE SULFUR
- THIOSULFATE REMOVED FROM PLANT
- PREVENT INTRODUCTION OF CONTAMINANTS
- INCREASE SAMPLING FREQUENCY ON SOME ANALYSIS
- NEW SPECIFICATIONS ON:
  - LITHIUM
  - CHLORIDES
  - SULFATE
  - SODIUM
  - PH
  - CONDUCTIVITY
  - SILICA
  - CALCIUM
  - MAGNESIUM

### RCS INSPECTION

- LARGE NUMBER OF COMPONENTS INSPECTED
- WIDE RANGE OF MATERIALS REPRESENTED
- WET, DRY AND INTERFACE AREAS INSPECTED
- UT, PT, ECT, VISUAL AND DESTRUCTIVE EXAMINATIONS USED

NO EVIDENCE OF ANY INTERGRANULAR CRACKING

### SUPPORTING SYSTEMS INSPECTION

- SYSTEMS INSPECTED IN 1982 AS PART OF THREE YEAR SUPPLEMENTARY ISI PROGRAM WHICH WAS INITIATED DUE TO IGSCC IN SPENT FUEL SYSTEM IN 1979
  - SPENT FUEL
  - DECAY HEAT
  - BUILDING SPRAY
- VISUAL AND UT METHODS USED
- NO DISCREPANCIES NOTED IN THESE SYSTEMS
- OTHER SYSTEM INSPECTIONS IN PROGRESS



## STEAM GENERATOR REPAIR

- KINETIC EXPANSION
  - JOINT MEETS DESIGN BASIS
  
- PLUGGED TUBES
  - THREE TYPES OF PLUGS
    - WELDED TAPERED PLUG WITH STABILIZER
    - EXPLOSIVE PLUG
    - ROLLED PLUG
  - ALL TYPES PREVIOUSLY QUALIFIED AT OTHER UNITS
  - ROLLED PLUG QUAL. PROGRAM FOR TMI-1 COMPLETED IN FEBURARY 1982
  - INTERACTION BETWEEN WELDED AND EXPLOSIVE PLUGS AND EXPANSION ANALYZED - NO IMPACT
  - INTERACTION BETWEEN ROLLED PLUG AND EXPANSION - TEST PROGRAM IN PROGRESS
  - OPERATION WITH PLUGGED TUBES ANALYZED - NO IMPACT ON OPERATIONAL OR SAFETY LIMITS

UNREPAIRED TUBE SECTIONS ARE OPERABLE

- DAMAGE MECHANISM ARRESTED
  - CORROSION TESTS - SHORT AND LONG TERM
  - FLAW GROWTH PROGRAM
  
- DEFECTS THAT COULD PROPAGATE BY MECHANICAL LOADS ARE DETECTABLE AND REMOVED FROM SERVICE
  - ECT CALIBRATION PROGRAM
  - CALCULATIONS OF THRESHOLD FOR PROPAGATION
  
- UNDETECTABLE DEFECTS ARE ACCEPTABLE
  - SMALL CRACKS WILL NOT PROPAGATE MECHANICALLY
  - LOCAL IGA IS ACCEPTABLE
  
- A SMALL NUMBER OF "MISSED" DETECTABLE DEFECTS IS ACCEPTABLE
  - SMALL PROBABILITY WITH 100% INSPECTION
  - WILL LEAK DETECTABLY BEFORE FAILURE
  
- TEST PROGRAM
  - LEAK TESTS
  - COOLDOWN TRANSIENT TESTS
  - "SOAK" TIME TO DETECT LEAKS AND ANY CRACKS THAT PROPAGATE.

## ENVIRONMENTAL IMPACT

### • ASSUMPTIONS

- 6 GPH LEAKRATE  
(50 TIMES REPAIR LEAKRATE GOAL)
- .03% FAILED FUEL  
(MAXIMUM EXPERIENCED AT TMI-1)
- BASED ON EXISTING PROCESSING CAPABILITY

### • RESULTS

- MAXIMUM HYPOTHETICAL OFF-SITE DOSES:

<u>SOURCE</u>	<u>CALCULATED DOSE</u>	<u>APP. 1 LIMIT FOR TMI 1</u>
IODINE & PARTICULATES	1.5 MREM/YR	15 MREM/YR
NOBLE GASES		
GAMMA	4.2 MRAD/YR	10 MRAD/YR
BETA	3.4 MRAD/YR	20 MRAD/YR
LIQUID EFFLUENT		
WHOLE BODY	$3 \times 10^{-4}$ MREM/YR	3 MREM/YR
LIVER	$5 \times 10^{-4}$ MREM/YR	10 MREM/YR

STEAM GENERATOR  
POST REPAIR TEST PROGRAM

LEAK TESTS

- COLD:

DRIP TEST

SECONDARY SIDE FLOODED AT 150 PSIG

PRIMARY SIDE DRY

BUBBLE TEST

SECONDARY SIDE PRESSURIZED WITH NITROGEN AT 150 PSIG

PRIMARY FLOODED ABOVE UTS

- HOT:


OPERATIONAL LEAK TEST (1500 PSI DELTA P)

PPRIMARY 2285 PSIG - SECONDARY 785 PSIG

PRECITICAL OPERATIONAL TESTS

- HEATUP
- SOAK TO MONITOR LEAKAGE
- COOLDOWN AT 70-100°F/HR FOR 1-2 HRS. (500-1100 LB. TENSION)
- HEATUP
- SOAK TO MONITOR LEAKAGE
- ACCELERATED COOLDOWN AT A RATE AND FOR A PERIOD TO OBTAIN ~ 110% OF NORMAL COOLDOWN LOADS
- HEAT UP
- SOAK TO MONITOR LEAKAGE
- COOLDOWN AT 70-100°F/HR TO COLD SHUTDOWN CONDITIONS (1100 LB. TENSION)

# STEAM GENERATOR POST REPAIR TESTING SEQUENCE



## NOTE:

DOUBLE LINE BOXES INDICATE  
NORMAL PLANT TESTING  
OR OPERATIONS

# **Flow Induced Vibration Analysis Overview**

## **Objective**

**Calculate the threshold between stable and and unstable crack growth based only on mechanical loading in a PWR environment**

**Compare this threshold to the ECT detectability and demonstrate that ECT has located cracks which would be unstable (ie: fail by fatigue crack propagation within 40 years)**


## **Basis**

**Precritical hot functional testing will confirm that a rapidly progressing corrosion process will not cause tube leaks once critical**

**Prior to criticality we require assurance that FIV will not cause rapid failure of OTSG tubes**

# FLOW INDUCED VIBRATION

## A) FRACTURE MECHANICS MODEL




- PART THROUGH-WALL CIRCUMFERENTIAL FLAWS IN TUBES
- ASPECT RATIO VARIED

$\frac{l}{h}$	.2	.4	.6	.8
$\frac{a}{h}$	1	2	4	8

10/18/82

# FLOW INDUCED VIBRATION

## B) FRACTURE MECHANICS MODEL LOADING



1)  $P_1$  AXIAL LOAD

2) BENDING STRESS DUE TO FLOW INDUCED VIBRATION ( $M_{FIV}$ )

3) INTERNAL PRESSURE ACTING ON PARTING FACES OF CRACK

4) SOLUTION OF STRESS INTENSITY PROBLEM BY PROF. F. ERDOGAN, LEHIGH UNIV., BETHLEHEM, PA.

10/18/82




# **Flow Induced Vibration**

## **C) Axial Tube Load Reflects**

- 1. Stretch of steam generator due to pressure in heads on primary side**
- 2. Elastic deformation of tubesheet at center-line (opposing stretch)**
- 3. Tube longitudinal stress from internal pressure (poisson's effect)**
- 4. Residual axial load from fabrication**
- 5. Shell-to-tube temperature difference, including higher than design basis superheat**
  - used + 500 lbf axial tensile load**
  - TMI-2 instrumentation showed 0 to +500 lbf at > 40% power**


10/18/82

### TMI-1 SUPERHEAT - DESIGN BASIS VS ACTUAL




# FLOW INDUCED VIBRATION

## D) FIV BENDING STRESS - TMI-2 INSTRUMENTATION



- DEFECT CONSIDERED TO BE AT L=0 - LOCATION OF MAXIMUM BENDING STRESS
- TMI-2 FIV RESULTS FROM EPRI NP-1876


## TMI-2 FIV INSTRUMENTATION LOCATION



- A - ACCELERATION**
- SG - STRAIN GAGE**
- - SLEEVED TUBE**
- △ - ACCELEROMETER LOCATED BETWEEN 9 AND 10 SUPPORT PLATE**

- INSTRUMENTATION BOTH ON TUBE LANE AND IN QUADRANT WITH MAIN STEAM OUTLET
- LANE TUBES EXHIBITED HIGHEST FIV RESPONSE
- HIGHEST RESPONSE VALUES USED IN GPUN'S ANALYSIS

**TMI-2 FIV INSTRUMENTATION RESULTS - STEADY  
STATE TANGENTIAL DISPLACEMENT**



- STEADY STATE DEFLECTION FOR FRACTURE MECHANICS ANALYSIS = 3 x MAX RMS VALUE = 3 MILS.
- ONE CAN SAY WITH A CONFIDENCE LEVEL OF 98% THAT FOR A GAUSSIAN DISTRIBUTION THE MAXIMUM AMPLITUDE WILL NOT EXCEED THREE TIMES THE RMS.


10/18/82

## TMI-2 FIV Instrumentation Results - Transients

PEAK HALF-AMPLITUDE DISPLACEMENTS, MILS	75% POWER, PUMP A1 TRIP	3 RC PUMP UNBAL. OTSG OPERATION (a)	90% POWER, REACTOR/ TURBINE	97% POWER, TURBINE TRIP
TUBE 77001 (LANE)	3.7	3.0	3.8	3.4
77050 (LANE)	1.5	1.9	14.9	5.4
40113 (BUNDLE)	2.4	2.4	3.3	9.1
12068 (10TH SPAN)	0.6	1.0	0.8	1.7

# TMI-2 FIV INSTRUMENTATION

## BENDING STRESS TRANSFER FUNCTION VS ESTIMATED AXIAL LOAD



● RELATION TO OBTAIN BENDING STRESS AT TUBESHEET (L=0) BASED ON TUBE DEFLECTION IN ORDER TO OBTAIN BENDING MOMENT

## **Flow Induced Vibration**

### **E) OTSG Tube Fracture Mechanics Evaluation**

- **Loads**

**Axial tension,  $F_{ax} = 500 \text{ lbf}$**

**Bending Moment = 23.73 in - lb  
(FIV) @ 75 Hz**

**Pressure acting on parting faces  
 $\Delta p = 1245 \text{ lb/in}^2$**

- **Propagation threshold,  $\Delta K_{Th}$**


**The threshold  $\Delta K$  implies a stress intensity factor range below which an initiated crack will not propagate**



## FLOW INDUCED VIBRATION


### F) LOAD CYCLE APPLIED

- FOR  $F_{AX}=500$  lb, ALTERNATING LOAD IS FIV ONLY
- 40 YEARS OF LOAD CYCLING



10/18/82


# GENERIC THRESHOLD STRESS INTENSITY



- NUREG/CR 1319 DTD JAN. 1980
- SCHEMATIC REPRESENTATION OF THE LINEAR EXTRAPOLATION OF THE UPPER BOUND LINE TO APPROXIMATE THE THRESHOLD  $\Delta K$

10/18/82

# Inconel 600 Threshold Stress Intensity (MIT Corrosion Laboratory Data)



## Stress Intensity Calculation



### G) Execution of Stress Intensity Solution

- The L.E.F.M. computational code, "BIGIF", developed for EPRI, was used to integrate over a range of stress intensities following a modified 'PARIS' equation:

$$\frac{da}{dN} = 7.4 \times 10^{-10} \Delta K^{3.5}$$

- The modification was that of applying a test for  $(\Delta K)_{Th}$
- Different R values were used when calculating crack propagation due to high or low cycle loading to capture the effect of mean stress

**ECT DETECTABILITY  
VS.  
FLOW INDUCED VIBRATION**



FIV (1):  $\Delta K_{th} = 2.2 \text{ MPa}\sqrt{\text{m}}$   
DEFLECTION = 14 MILS

FIV (2):  $\Delta K_{th} = 1.1 \text{ MPa}\sqrt{\text{m}}$   
DEFLECTION = 3 MILS

ECT: DEFECT - 4 MIL WIDE NOTCH  
PROBE - DIFFERENTIAL  
.540 IN DIA.

GAIN - 40 + RA

SENSITIVITY - 300 MV IN  
LAB EQUIVALENT  
TO FIELD

## **Flow Induced Vibration Conclusion**

- The .540 inch diameter high gain standard differential probe used at TMI-1 has detected those defects which would propagate unstably from only the mechanical loads anticipated over a 40 year service life
- Once the threshold stress intensity is exceeded and crack growth commences the crack progresses through wall in about 60 hours

# **Leak Before Break Analysis Overview**

## **Objective**


**Calculate leakage rate from circumferential cracks to establish leakage as a function of crack geometry**

**Compare calculated leakage to the detectability limits for leakage, to conclude that leaking tubes can be detected and taken out of service prior to the crack becoming unstable due to plastic tearing or ligament necking during the cooldown following leak detection**


## **Basis**

**Ensure that tubes can be taken out of service before they are degraded to the point that a double ended rupture will occur during cooldown**

### PRI-SEC LEAK RATE VS. DETECTABILITY



### ASSUMED CRACK GEOMETRY



.46 GPH OPERATING @ .03% FF  
 .1 GPH 150 psi N<sub>2</sub> BUBBLE TEST



## **Small ECT ID Indications**

### **Objective**

To leave in service a limited number of small cracks to provide inspectability for crack growth rate studies

### **ECT Results**

Cracks identified with  $< 40\%$  through wall

### **Identified cracks are acceptable:**

- Cracks will not propagate by FIV
- Cracks are too small to initiate ductile tearing
- Small number ( $\sim 76$ )

### **Conclusion**

ECT identified cracks  $< 40\%$  through wall will not be plugged

## Steam Generator Tube Plugging Plan

- Tubes with defects in high cross flow areas will be plugged and stabilized
- Tubes requiring plugging, but with no defects in high cross flow areas will be plugged but not stabilized
- Plugging plans

	<u>Crack Location</u>	<u>Number</u>	<u>Area of Stabilization</u>
<u>Stabilized:</u>	UTS + 4" → 15th TSP	551 ±	UTS + 24" → 14th TSP
<u>Being evaluated:</u>	LTS → 1st TSP	6 ±	LTS → 1st TSP
<u>Not Stabilized:</u>	UTS + 4 → UTS + 8 15th TSP → 1st TSP	246 ± 343 ±	
<u>Total Plugged Tubes</u>		<u>1146 ±</u>	


DESIGN BASIS ANALYSIS CONSIDERATIONS  
OF TMI-1 SG TUBE PLUGGING

- PLANT PERFORMANCE PARAMETERS
  - REACTOR COOLANT SYSTEM FLOW RATE
  - REACTOR COOLANT PUMP FLOW COASTDOWN RATE
- LOCA ANALYSIS CONSIDERATIONS
  - SMALL BREAK LOCA
  - LARGE BREAK LOCA
- FSAR TRANSIENTS

### RCS FLOW RATE

- MINIMUM CALCULATED RCS FLOW RATE AT TMI-1 = 109.5% OF DESIGN FLOW
- MAXIMUM ERROR ON CALCULATION = 1.5%
- MINIMUM AVAILABLE FLOW RATE = 108% DESIGN
- FLOW REQUIRED IN TMI-1 TRANSIENT ANALYSIS = 106.5% DESIGN
- FLOW MARGIN = 1.5%
- FLOW REDUCTION FROM 1500 PLUGGED TUBES = 0.8%

TOTAL RC FLOWRATE VERSUS TOTAL  
NUMBER OF TUBES PLUGGED



RC PUMP FLOW COASTDOWN RATE

- ANALYSIS PERFORMED WITH B & W "PUMP" CODE
  - HYBRID DIGITAL AND ANALOG CODE
  
- CASES ANALYZED
  - CASE 1: 1 PUMP TRIP WITH ZERO PLUGGED TUBES
  - CASE 2: CASE 1 WITH 1500 PLUGGED TUBES
  - CASE 3: TRIP ALL RC PUMPS WITH ZERO PLUGGED TUBES
  - CASE 4: CASE 3 WITH 1500 PLUGGED TUBES
  
- RESULTS
  - 1500 PLUGGED TUBES HAS NEGLIGIBLE EFFECT ON SINGLE PUMP TRIP AND TRIP OF ALL RC PUMPS

FLOW COASTDOWN  
FOR ONE PUMP TRIP

<u>TIME (SECONDS)</u>	<u>CORE FLOW (%)</u> <u>(ZERO PLUGGED TUBES)</u>	<u>CORE FLOW (%)</u> <u>(1500 PLUGGED TUBES)</u>
0	99.73	99.74
1	98.87	98.92
2	97.42	97.55
3	95.61	95.75
5	91.88	91.94
7	87.88	87.93
9	84.63	84.87

FLOW COASTDOWN FOR  
FOUR PUMP TRIP

<u>TIME (SECONDS)</u>	<u>CORE FLOW (%)</u> <u>(ZERO PLUGGED TUBES)</u>	<u>CORE FLOW (%)</u> <u>(1500 PLUGGED TUBES)</u>
0	99.92	99.83
1	98.24	97.82
2	94.0	93.24
3	87.67	86.74
5.5	71.8	71.09
7.5	62.4	61.6
9.5	54.6	54.34



SMALL BREAK LOCA

- CONCERNS
  - A. STEAM GENERATOR HEAT REMOVAL IN BOILER - CONDENSER MODE
  - B. EMERGENCY FEEDWATER SPRAY HEAT REMOVAL
  - C. EFFECTS OF REDUCED RCS LIQUID INVENTORY ON CORE UNCOVERY TIME

STEAM GENERATOR HEAT REMOVAL  
IN BOILER-CONDENSE MODE

- GENERIC LOCA ANALYSIS POWER LEVEL WAS 2772 MWT
- 1500 PLUGGED TUBES APPROXIMATELY EQUAL TO 5% SG AREA REDUCTION
- HEAT REMOVAL CAPABILITY OF SG WILL BE DEGRADED BY APPROXIMATELY 5%
- HEAT REMOVAL CAPABILITY REDUCTION CAN BE OFFSET BY POWER REDUCTION
  - 5% POWER-REDUCTION FROM GENERIC VALUE REQUIRED
- MAXIMUM ALLOWABLE GENERIC POWER LEVEL OF 2633 MWT
- TMI-1 LICENSED POWER LEVEL OF 2535 MWT PROVIDES ADDITIONAL 4% MARGIN
- GENERIC SMALL BREAK LOCA ANALYSIS IS APPLICABLE TO TMI-1 WITH PLUGGED TUBES

## SMALL BREAK LOCA

### EMERGENCY FEEDWATER HEAT REMOVAL

- SMALL BREAK LARGE ENOUGH TO DEPRESSURIZE SYSTEM (WORST CASE SB LOCA)
  - PRIMARY AND SECONDARY TEMPERATURES EQUAL AT ABOUT 300 SECONDS (SG HEAT REMOVAL CEASES)
  - CORE UNCOVERY BEGINS AT 1350 SECONDS
  - PEAK CLADDING TEMPERATURE OCCURS BETWEEN 1600 AND 1700 SECONDS
  - CORE RECOVERED AT ABOUT 1750 SECONDS
  - EFFECT OF SG COOLING ON THIS ACCIDENT IS NEGLIGIBLE (SG ACTS AS HEAT SOURCE FOR MOST OF THE TIME DURING THIS EVENT)
  - EFFECTS OF REDUCED EFW HEAT REMOVAL ARE NEGLIGIBLE
- SMALL BREAK WHICH REQUIRES SG HEAT REMOVAL TO DEPRESSURIZE SYSTEM
  - THESE BREAK SIZES DO NOT RESULT IN CORE UNCOVERY
  - REDUCED SG COOLING WILL RESULT IN ADDED PRIMARY SYSTEM INVENTORY BOIL OFF
  - INVENTORY REMAINING IS SUFFICIENT TO PREVENT CORE UNCOVERY
  - PEAK CLADDING TEMPERATURE REMAINS AT SYSTEM SATURATION TEMPERATURE (500 - 650°F)
  - REDUCED EFW COOLING NOT EXPECTED TO RESULT IN CORE UNCOVERY

SMALL BREAK LOCA  
RCS LIQUID INVENTORY

• FOR WORST CASE SB LOCA

- ANALYSIS PERFORMED AT 2772 MWT
- CORE UNCOVERY OCCURED AT APPROXIMATELY 1350 SEC
- WITH 1500 PLUGGED TUBES:
  1. CORE UNCOVERY WILL OCCUR APPROXIMATELY 3 SECONDS EARLIER
  2. PEAK CLADDING TEMPERATURE WILL INCREASE BY ABOUT 10°F
  3. PEAK CLADDING TEMPERATURE WILL REMAIN AT APPROXIMATELY 1100°F

• CONCLUSION

- GENERIC SMALL BREAK LOCA ANALYSIS APPLICABLE FOR TMI-1 WITH PLUGGED TUBES

## LARGE BREAK LOCA

### • CONCERN

- ALTERATION OF LOOP AND CORE FLOW PATTERNS DURING EARLY PHASE OF LB LOCA

### • EVALUATION

- FLOW REDUCTION OF 0.8% FROM 1500 PLUGGED TUBES
- FLOW RATE USED IN GENERIC LOCA ANALYSIS WAS  $137.9 \times 10^6$  LBS/HR
- TMI-1 DESIGN BASIS FLOW RATE IS 106.5% OF CYCLE 1 DESIGN FLOW OR  $139.8 \times 10^6$  LBS/HR. REDUCED FLOW =  $138.7 \times 10^6$  LBS/HR.
- TMI-1 REDUCED FLOW RATE GREATER THAN LOCA ANALYSIS VALUE
- B & W SENSITIVITY STUDIES HAVE SHOWN THAT HIGHER INITIAL RCS FLOW RESULTS IN LOWER PEAK CLADDING TEMPERATURES

### • CONCLUSION

- GENERIC LARGE BREAK LOCA ANALYSES ARE APPLICABLE TO TMI-1 WITH PLUGGED TUBES.

FSAR TRANSIENTS

TRANSIENT

EFFECT

- |   |   |
|---|---|
| 1. UNCOMPENSATED OPERATING REACTIVITY CHANGES | REACTIVITY AND RADIATION RELEASE TYPE OF EVENTS |
| 2. STARTUP ACCIDENT/CRA WITHDRAWAL AT POWER   | ARE UNAFFECTED BY TUBE PLUGGING                 |
| 3. MODERATOR DILUTION                         |   |
| 4. COLD WATER ACCIDENT                        |   |
| 5. STUCK/DROPPED ROD                          |   |
| 6. FUEL HANDLING                              |   |
| 7. ROD EJECTION                               |   |
| 8. MAXIMUM HYPOTHETICAL                       |   |
| 9. WASTE GAS TANK RUPTURE                     |   |

FSAR TRANSIENTS (CONT'D)

<u>TRANSIENT</u>	<u>EFFECT</u>
10. LOSS OF COOLANT FLOW	UNAFFECTED SINCE FLOW COASTDOWN RATE UNCHANGED FROM ZERO PLUGGING CASE. FSAR ANALYSIS ALSO BASED ON MINIMUM RC FLOW.
11. LOSS OF ELECTRIC POWER	FSAR RESPONSE UNCHANGED.
12. STEAMLINER FAILURE	FSAR ASSUMPTION OF SG INVENTORY WAS VERY CONSERVATIVE (55,000 LBM). FSAR BOUNDING.
13. SG TUBE RUPTURE	FSAR ANALYSIS WILL BE UNCHANGED.
14. LOSS OF FW/FEEDLINE BREAK	NO EFFECT OF TUBE PLUGGING ON PEAK PRESSURE IS EXPECTED. LONG TERM DH REMOVAL CAPABILITY WILL NOT BE EFFECTED.

CONCLUSION: PLUGGING OF 1500 TUBES WILL HAVE NO IMPACT  
ON FSAR ANALYSES. FSAR REMAINS BOUNDING.

# **RCS Cleanup**

## **Purpose - Eliminate Possibility of Future Attack**

- **Convert sulfur to innocuous form (SO<sub>4</sub>) as quickly as possible under protective (alkaline) conditions**
- **Remove as much as the SO<sub>4</sub> from the system as possible**

## **Options**

- **Steam generators only**
- **Entire primary system**
- **Core in or out**

**Use known, safe technology**



## **Extent of Sulfur Contamination ( $\mu\text{gm SO}_4/\text{ft}^2$ )**


<b>Fuel Rod (Clean)</b>	<b>533</b>
<b>Grid</b>	<b>418</b>
<b>RNS Retainer</b>	<b>530-700</b>
<b>RNS Spring</b>	<b>144</b>
<b>Tubes - upper SG plenum</b>	<b>970-3600</b>
<b>Tubes - lower SG plenum</b>	<b>770-930</b>
<b>Tubes - during fabrication</b>	<b>&lt; 250</b>

**(Method sensitivity - 250)**


## **BMI Ni S Tests**

<b>Ni S</b>	<b>17 ppm SO<sub>4</sub></b> <b>(<math>r = 5 \times 10^{-3}</math>cm)</b>
<b>H<sub>2</sub>O<sub>2</sub></b>	<b>200 ppm, 0 ppm</b>
<b>Temp</b>	<b>25°C, 33°C</b>
<b>Cover gas</b>	<b>air, argon</b>
<b>pH</b>	<b>4.5, 8, 9</b>


**SO<sub>4</sub> = FORMATION RATE MEASUREMENTS FOR REACTION BETWEEN NiS AND H<sub>2</sub>O<sub>2</sub> IN AQUEOUS MEDIA AT pH8.**



SO<sub>4</sub> = FORMATION RATE MEASUREMENTS FOR REACTION BETWEEN NiS AND H<sub>2</sub>O<sub>2</sub> IN AQUEOUS MEDIA AT ROOM TEMPERATURE, pH8, AND RELATIVE STIRRIN 3 RATE OF ONE.



**H<sub>2</sub>O<sub>2</sub> CONCENTRATION MEASUREMENTS FOR THE REACTION  
BETWEEN NiS AND H<sub>2</sub>O<sub>2</sub> IN AQUEOUS MEDIA AT ROOM  
TEMPERATURE, pH 8, AND RELATIVE STIRRING RATE OF ONE**



## **Conclusions from NiS Reaction Rate Measurements**

### **I. With H<sub>2</sub>O<sub>2</sub>**

- Decreasing stirring rate increased SO<sub>4</sub> formation rate
- Increasing temperature increased SO<sub>4</sub> formation rate
- SO<sub>4</sub> formation rate the same at pH 8 and pH 9 but initially about 4 times slower at pH 4.5
- No difference in SO<sub>4</sub> formation rate between air and argon

### **II. Without H<sub>2</sub>O<sub>2</sub>**

- SO<sub>4</sub> formation rate decreased with decrease in stirring rate
- Increasing temperature increased SO<sub>4</sub> formation rate
- SO<sub>4</sub> formation rate decreased with decreasing pH
- SO<sub>4</sub> formation rate approximately zero in argon.
- Initial and final conversion rates made slower than with H<sub>2</sub>O<sub>2</sub>

**Consultants**  
**GPUN Workshop - RCS Cleanup**  
**Battelle-Columbus**  
**August 9-10, 1982**

<u>Name</u>	<u>Company</u>
Jack H. Hicks	Bablock & Wilcox Company
Yale Solomon	Westinghouse Electric Corp.
Fred Pement	Westinghouse Electric Corp.
Marv Miller	Battelle-Columbus
Arun K. Agrawal	Battelle-Columbus
Henry Leidheiser	Lehigh University
Warren E. Berry	Battelle-Columbus
Merl J. Bell	NWT Corporation
R.H. Barnes	Battelle-Columbus
Paul Cohen	Consultant (EPRI)
Joan Lathouse	Battelle-Columbus
Afaf Wensky	Battelle-Columbus

PHASE II

Priority	Description	pH	H <sub>2</sub> O <sub>2</sub> (ppm)	B (ppm)	S Form	Temperature
1	Zero Run-1	8 (NH <sub>3</sub> )	200 (unstablized)	2300	NIS (17 ppm)	Room Temperature
	Zero Run-2	8 (NH <sub>3</sub> )	200 (unstablized)	2300	NIS + I-600	Room Temperature
	Zero Run-3	8 (NH <sub>3</sub> )	200 (unstablized)	2300	Tetrathionate (20 ppm)	Room Temperature
	Zero Run-4	8 (NH <sub>3</sub> )	200 (unstablized)	2300	NIS + I-600	130°F
2	Tubes Run-1	8 (NH <sub>3</sub> )	20 (maintained)	2300	Tubes (3"-7")	130°F
	Tubes Run-2	8 (NH <sub>3</sub> )	20 (maintained)	2300	Tubes (3"-7")	130°F
	Tubes Run-3	10 (LiOH)	20 (maintained)	0	Tubes (3"-7")	130°F
	Tubes Run-4	10 (LiOH)	20 (maintained)	0	Tubes (3"-7")	130°F
3 deleted	Tubes Run-5	8 (NH <sub>3</sub> )	O <sub>2</sub> (cover gas)	2300	Tubes (3"-7")	130°F
	Tubes Run-6	8 (NH <sub>3</sub> )	O <sub>2</sub> (cover gas)	2300	Tubes (3"-7")	130°F
	Tubes Run-7	10 (LiOH)	O <sub>2</sub> (cover gas)	0	Tubes (3"-7")	130°F
	Tubes Run-8	10 (LiOH)	O <sub>2</sub> (cover gas)	0	Tubes (3"-7")	130°F
4	Corrosion Run-1	8 (NH <sub>3</sub> )	20 (maintained)	2300	U-tubes, C-rings, and tetrathionate (20 ppm)	130°F
	Corrosion Run-2	8 (NH <sub>3</sub> )	20 (maintained)	2300		130°F
	Corrosion Run-3	10 (LiOH)	20 (maintained)	0		130°F
	Corrosion Run-4	10 (LiOH)	20 (maintained)	0		130°F
5 deleted	Corrosion Run-5	8 (NH <sub>3</sub> )	O <sub>2</sub> (cover gas)	2300	U-tubes, C-rings, and tetrathionate (20 ppm)	130°F
	Corrosion Run-6	8 (NH <sub>3</sub> )	O <sub>2</sub> (cover gas)	2300		130°F
	Corrosion Run-7	10 (LiOH)	O <sub>2</sub> (cover gas)	0		130°F
	Corrosion Run-8	10 (LiOH)	O <sub>2</sub> (cover gas)	0		130°F
6 <sup>(a)</sup>	Immunol Run-1	8 (NH <sub>3</sub> )	20 (maintained)	2300	3-1, 3-2, 3-3	130°F
	Immunol Run-2	8 (NH <sub>3</sub> )	20 (maintained)	2300	3-4, 3-5, 3-6	130°F
	Immunol Run-3	8 (NH <sub>3</sub> )	20 (maintained)	2300	3-7, 3-8, 3-9	130°F
	Immunol Run-4	8 (NH <sub>3</sub> )	20 (maintained)	2300	4-1, 4-2, 4-3	130°F

(a) = All samples (12 pieces) should be rinsed with DI H<sub>2</sub>O (pH 9-10 with NH<sub>4</sub>OH). Use 100 ml from a squirt bottle for each piece and as much as possible treat them identically.



## **Corrosion Tests**

**Conditions - like cleaning except O<sub>2</sub> cover**

**Specimens - 304SS (Sens.) U-bends, I-600  
U-bends (TMI Heat Treat),  
C-rings from TMI tubing**


**NaS added as corrodant at same rate as  
released in first test**

**Test length twice time of SO<sub>4</sub> release  $\approx$  140 hrs**


TUBE CLEANING EXPERIMENTS

Type of Test	Sample	pH	H <sub>2</sub> O <sub>2</sub> Concentration, ppm*	Reaction Temperature, of	Cover Gas
● Sulfur Cleaning	Inconel Tubes	pH 8 (H <sub>3</sub> BO <sub>3</sub> /NH <sub>4</sub> OH)	20, maintained	130	Air
		pH 10 (LiOH)	20, maintained	130	Air
● Corrosion	Inconel C-Rings and U-Bends	pH 8 (H <sub>3</sub> BO <sub>3</sub> /NH <sub>4</sub> OH)	20, maintained	130	O <sub>2</sub>
		pH 10 (LiOH)	20, maintained	130	O <sub>2</sub>
● Sulfur Cleaning of Immuno1 treated Tubes	Immuno1 Treated Inconel tubes 4 feet from expanded region	pH 8 (H <sub>3</sub> BO <sub>3</sub> /NH <sub>4</sub> OH)	20, maintained	130	Air
		pH 10 (LiOH)	20, maintained	130	Air
● Sulfur Cleaning of expanded Immuno1 treated tubes	Transition region of Immuno1 treated Inconel tube	pH 8 (H <sub>3</sub> BO <sub>3</sub> /NH <sub>4</sub> OH)	20, maintained	130	Air
	Transition region of untreated expanded Inconel Tube	pH 8 (H <sub>3</sub> BO <sub>3</sub> /NH <sub>4</sub> OH)	20, maintained	130	Air
	Immuno1 Treated Inconel tube 20 inches from expanded region	pH 8 (H <sub>3</sub> BO <sub>3</sub> /NH <sub>4</sub> OH)	20, maintained	130	Air
	Untreated Inconel Tube 20 inches from expanded region	pH 8 (H <sub>3</sub> BO <sub>3</sub> /NH <sub>4</sub> OH)	20, maintained	130	Air


\*Unstabilized H<sub>2</sub>O<sub>2</sub>



PRODUCTION OF SO<sub>4</sub> DURING CLEANING OF SULFUR CONTAMINATED INCONEL-600 TUBE SAMPLES WITH H<sub>2</sub>O<sub>2</sub> MAINTAINED AT 20<sup>4</sup>ppm (Tube A 78-32-2)




$H_2O_2$  MEASUREMENTS MADE DURING CLEANING OF SULFUR CONTAMINATED INCONEL-600 TUBE SAMPLES WITH  $H_2O_2$  MAINTAINED AT 20 ppm (Tube A 78-32-2).



36296

500X

Photomicrograph



36212


500X

Sulfur X-Ray

SEM PHOTOMICROGRAPH AND X-RAY MAP FOR SULFUR CONTAMINATED AREA IN CROSS SECTION OF AS-RECEIVED INCONEL-600 TUBE SAMPLE.

LT= 200 SECS


1000X GENERAL SCAN



ENERGY DISPERSIVE X-RAY SPECTRUM FOR SULFUR CONTAMINANT AREA (AREA C) IN CROSS SECTION OF AS-RECEIVED INCONEL-600 TUBE.

LT= 1000 SECS


TEST TUBE 1



ENERGY DISPERSIVE X-RAY SPECTRUM FOR ID SURFACE INCONEL-600 TUBE SAMPLE AFTER CLEANING WITH H<sub>2</sub>O<sub>2</sub> AT pH8.

LT= 1000 SECS

EXEC (2-V) DATA LABEL




ENERGY DISPERSIVE X-RAY SPECTRUM FOR ID SURFACES INCONEL-600 TUBE SAMPLE AFTER CLEANING WITH H<sub>2</sub>O<sub>2</sub> AT pH 10.




LT= 1000 SECS

#3 X SECTION AREA 2




ENERGY DISPERSIVE X-RAY SPECTRUM FOR SU<sub>2</sub> FOR CONTAMINATED AREA (AREA 2) IN CROSS SECTION OF INCONEL 600 TUBE SAMPLE AFTER CLEANING WITH H<sub>2</sub>O<sub>2</sub> AT pH<sub>8</sub>



36632

5000X

Photomicrograph



36634


5000X

Nickel X-Ray Map

SEM PHOTOMICROGRAPH AND X-RAY MAP OF SULFUR CONTAMINATED AREA IN CROSS SECTION OF INCONEL-600 TUBE SAMPLE FROM ABOUT FIVE FEET FROM EXPANSION ZONE AFTER REMOVAL OF SULFUR BY  $H_2O_2$  CLEANING AT pH 10 (Area 2).

LT= 300 SECS

RUN #3 X SECTION-2A



ENERGY DISPERSIVE X-RAY SPECTRUM FOR AREA 2, POINT A IN CROSS SECTION OF INHUNOL COATED INCONEL-600 TUBE SAMPLE FROM ABOUT FIVE FEET FROM EXPANSION ZONE AFTER REMOVAL OF SULFUR BY H<sub>2</sub>O<sub>2</sub> CLEANING AT pH 10.


## **Preliminary Conclusions from TMI Tubing Cleaning & Corrosion Tests**

- 1. The process works about as anticipated**
- 2. Cleaning time appears to be < 100 hrs**
- 3. No indication of corrosion has been seen**
- 4. Presence of Immunol does not appear to be detrimental to the process**

# **Work in Progress**

- 1. Loop tests**
- 2. Preparation of plant procedure**
- 3. Completion of radwaste considerations**
- 4. Confirmation of IX performance**
- 5. Method development on reduced sulfur on swipes**

# CORROSION TEST PROGRAM



# Long Term Corrosion Test Program

## Objective:

Duplicate HFT sequence and typical reactor operation in the laboratory to assess environmental effects on tube performance. This test will lead actual OTSG operation and attempt to duplicate planned operational sequences

## Test Duration:

Approximately 17 months

## Test Specimens:

### Lead Test

Full section tubes	Actual TMI tubing
C-rings	Actual TMI tubing and archive tubing (heat M2320)

### Repair Qualification

Single tube/tubesheet mockups using actual TMI tubing

## Test Parameters:

**Chemistry** - Typical primary water chemistry with contaminants at maximum specification levels


**Temperature** - Ambient to 600° F with temperature cycling

**Load** - C-rings stressed at 90% Y.S.  
Full section tubes loaded 500-1100 lbs

**Pressure** - Actual primary and secondary operating pressures




# TEST LOOP SCHEMATIC



\* AS SHOWN - LEAD TEST (FOR REPAIR TEST, WITHOUT CAN OF C-RINGS)





10/18/82

# Summary of Specimens- Long Term Corrosion Testing

## Lead Test

Solution 1 (thiosulfate)	Solution 2 (sulfate)
-----------------------------	-------------------------

## Full Tube Sections

w/o indications		
as-removed	1	1
Immunol treated		1
Immunol and H <sub>2</sub> O <sub>2</sub> treated		1
w/ indications		
as-removed	1	1
Immunol treated		1
Immunol and H <sub>2</sub> O <sub>2</sub> treated		1
ID stressed C-rings actual TMI-1 tubing	15	15
archive tubing	4	4

## Repair Test

- all actual tube sections without defects
- as expanded - 4 loaded, 2 unloaded
- Immunol treated, expanded, H<sub>2</sub>O<sub>2</sub> cleaned - 2 loaded, 1 unloaded

## SOLUTION CHEMISTRY

	<u>LEAD TEST SOLUTION 1</u>	<u>LEAD TEST SOLUTION 2</u>	<u>REPAIR TEST</u>
BORON, PPM AS B	2350-100	2350-100	1200-100
LI, PPM AS LI	0.7 - 2.5	0.7 - 2.5	0.7 - 2.5
CHLORIDE, PPM AS CL	.05 - .15	.05 - .15	.05 - .15
FLUORIDE, PPM AS F	.05 - .15	.05 - .15	.05 - .15
THIOSULFATE, PPM AS SO <sub>4</sub>	.05 - .15		
SULFATE, PPM AS SO <sub>4</sub>		.05 - .15	.05 - .15
HYDRAZINE, PPM (initial)	2 - 10	2 - 10	2 - 10
O <sub>2</sub> PPB	< 10	< 10	< 10
H <sub>2</sub> CC/KG	15 - 40	15 - 40	15 - 40
H <sub>2</sub> O <sub>2</sub>			TO BE DEFINED

# Test Loop Operation

## 1 - Precondition


- No samples in place
- Establish 550-600 F in autoclave
- Flush with demineralized water until conductivity is acceptable
- Run test solution until:  
Outlet  $\text{SO}_4$  is  $\geq 90\%$  of inlet concentration

## 2 - Insert Specimens


## 3 - Operate System

- Run simulated cycles - HFT and operational
- Specimen load - 500 lb during heatup and hold, 1100 lb during cooldown

# LEAD TESTS




# REPAIR TESTS




## LONG TERM CORROSION TEST SCHEDULE

### LEAD TEST



### REPAIR TEST



# **Specimen Evaluation**

## **1 - Full Tube Specimens**

- Eddy current prior to operation with 0.540" std. differential probe
- Eddy current after each testing cycle
- Metallurgically evaluate at end of program

## **2 - C-Rings**

- After each cycle, visually inspect all specimens
- At end of each cycle, remove one C-ring and metallurgically evaluate
- Metallurgically evaluate all specimens at end of program