

APPENDIX A

NOTICE OF VIOLATION

Philadelphia Electric Company
Limerick Generating Station, Unit 1

Docket/License: 50-352/CPPR-106

As a result of the inspection conducted on October 4 - November 14, 1982, and in accordance with the NRC Enforcement Policy (10 CFR 2 Appendix C) published in the Federal Register on March 19, 1982 (47 FR 9987), the following violation was identified:

10 CFR 50, Appendix B, Criterion V requires that activities affecting quality be accomplished in accordance with prescribed instructions, procedures, or drawings. Bechtel procedure EDPI-4.47.0, Paragraph 2.1.d, directs that any Field Change Request (FCR) received 15 days prior to issue of a drawing revision shall be incorporated in that drawing revision.

Contrary to the above, FCR's M-11.559F and M-11.939F to drawing No. GBB-102-H1, issued on or before June 1 and June 25, 1982 respectively, were not incorporated into a September 30, 1982 revision to that drawing.

This is a Severity Level V Violation (Supplement II).

Pursuant to 10 CFR 2.201, Philadelphia Electric Company is hereby required to submit to this office, within 30 days of the date of this Notice, a written reply including: (1) the corrective steps taken and results achieved; (2) corrective steps to be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending your response time.

8212070265 821123
PDR ADOCK 05000352
Q PDR

OFFICE ▶
SURNAME ▶
DATE ▶