

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION
P.O. BOX 128
SAN CLEMENTE, CALIFORNIA 92672

RECEIVED
NRC

1982 NOV 22 PM 12: 25
SCE

REGION V ISE TELEPHONE
(714) 492-7700

H. B. RAY
STATION MANAGER

November 19, 1982

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No.50-361
30-Day Report
Licensee Event Report No. 82-134
San Onofre Nuclear Generating Station, Unit 2

This submittal is in accordance with the reporting requirements of Section 6.9.1.13b of Appendix A to Facility Operating License NPF-10. It describes a reportable occurrence involving Limiting Condition for Operation (LCO) 3.4.5.1.c associated with the Reactor Coolant Leakage Detection System. A completed copy of LER 82-134 is enclosed.

On October 24, 1982, while in Mode 1 during surveillance testing in accordance with S023-3-3.26, Containment Airborne Monitor 2RT-7804-1 failed to meet its surveillance requirements due to high sample flow and was declared inoperable. Since the redundant monitor 2RT-7807-2 was out of service, the Action Statement associated with LCO 3.4.5.1.c was invoked.

As required by this Action Statement, grab samples of containment atmosphere were obtained and analyzed at least once per 24 hours during the inoperability of the monitor.

Subsequent investigation revealed that monitor high sample flow was caused by instrument drift in the sample pump flow controller. The controller was adjusted and the monitor recalibrated and declared operable in accordance with S023-3-3.26 at 2140 on October 26, 1982. This was an isolated occurrence and no further corrective action is warranted.

8212070290 821119
PDR ADOCK 05000361
S PDR

IE-22
82-421

November 19, 1982

Since no containment purging took place during this event and grab samples were obtained and analyzed at least once per 24 hours, there was no impact on health and safety of plant personnel or the public.

If there are any questions regarding the above, please contact me.

Sincerely,

HB Pany / DCM

Enclosure: LER 82-134

cc: A. E. Chaffee (USNRC Resident Inspector, San Onofre Unit 2)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Office of Management Information & Program Control

Institute of Nuclear Power Operations