

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION
P.O. BOX 128
SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY
STATION MANAGER

November 19, 1982

RECEIVED
NPC
SCE
1982 NOV 22 PM 12: 25
REGION 4
TELEPHONE
441 492-7700

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361
30-Day Report
Licensee Event Report No. 82-132
San Onofre Nuclear Generating Station, Unit 2

This submittal is in accordance with the reporting requirements of Section 6.9.1.13b of Appendix A to Facility Operating License NPF-10. It describes a reportable occurrence involving Limiting Condition for Operation (LCO) 3.3.4 associated with the Turbine Overspeed Protection System (TOPS). A completed copy of LER 82-132 is enclosed.

While in Mode 1, on October 23, 1982, turbine generator voltage regulator testing in accordance with Startup Procedure 2PA-611-01 was in progress. Due to failure of turbine stop valve 2UV-2200E to close fully, the valve was declared inoperable at 1545 and LCO 3.3.4 Action Statement a was invoked. As required by this Action Statement, the valve was secured in its closed position, isolating the turbine from the affected steam lead.

The inability of the valve to close fully was investigated and the problem was identified as failure of the electro-hydraulic servo-mechanism which controls the actuation of the valve. This assembly was replaced and the valve was declared operable in accordance with S023-3-3.34 at 1355 on October 24, 1982.

8212070379 821119
PDR ADOCK 05000361
S PDR

IE-22
82-422

This was an isolated event and no other corrective action is warranted at this time.

Since the turbine was immediately isolated from the affected steam lead, there was no impact on the health and safety of plant personnel or the public.

If there are any questions regarding the above, please contact me.

Sincerely,

HB King / JY / m...

Enclosure: LER 82-132

cc: A. E. Chaffee (USNRC Resident Inspector, San Onofre Unit 2)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Office of Management Information and Program Control

Institute of Nuclear Power Operations.