LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | CASO S2 (2) | 00-0000-00 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 1 (7) | 1 0 2 3 8 2 (8) | 1 1 1 9 8 2 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With the plant in Mode 1, during turbine generator voltage regulator testing, turbine
03 stop valve 2UV-2200E failed to close. The valve was declared
04 inoperable. Since the turbine was immediately isolated from the affected steam lead,
05 there was no impact on health and safety of plant personnel or the public.
06
07
08

09 SYSTEM CODE HA (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE VALVOP (14) | COMP. SUBCODE C (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 | — | SEQUENTIAL REPORT NO. 132 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN A (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER X999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Inability of the valve to close fully was attributable to a faulty electro-hydraulic
11 servo-mechanism which controls the actuation of the valve. The assembly was replaced.
12 No other corrective action is warranted at this time.
13
14

15 FACILITY STATUS B (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Startup Testing

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

8212070388 821119
PDR ADOCK 05000361
S PDR

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

20 PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

NAME OF PREPARER H. B. Ray HBRay / DVMoody PHONE 714/492-7700