

### LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(01) C A S O S 2 \_\_\_\_\_ 2 0 0 0 - 0 0 0 0 0 0 - 0 0 0 (3) 4 1 1 1 1 1 (4) \_\_\_\_\_ (5)

CON'T (01) REPORT SOURCE L (6) 0 5 0 0 0 3 6 1 (7) 1 0 2 1 8 2 (8) 1 1 1 1 8 8 2 (9)

#### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

(02) While in Mode 2 Control Element Assembly (CEA) #57 slipped and dropped in excess of  
(03) 7 inches (indicated position) in violation of Technical Specification 3.1.3.1. This  
(04) event had no effect on public health and safety since it did not affect the ability  
(05) of the CEA to be inserted into the core whenever required.  
(06) \_\_\_\_\_  
(07) \_\_\_\_\_  
(08) \_\_\_\_\_

(09) SYSTEM CODE I A (11) CAUSE CODE E (12) CAUSE SUBCODE B (13) COMPONENT CODE C R D R V E (14) COMP. SUBCODE Z (15) VALVE SUBCODE Z (16)  
(17) LER/RO REPORT NUMBER 8 2 (21) EVENT YEAR 8 2 (22) SEQUENTIAL REPORT NO. 1 2 8 (23) OCCURRENCE CODE 0 3 (24) REPORT TYPE L (25) REVISION NO. 0 (26)  
ACTION TAKEN B (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0 0 0 0 (22) ATTACHMENT SUBMITTED N (23) NPSR-4 FORM SUB. N (24) PRIME COMP. SUPPLIER N (25) COMPONENT MANUFACTURER C 4 9 0 (26)

#### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

(10) Cause of slippage was slow operation of the grippers. Corrective action taken  
(11) was to increase the gripper actuation voltage and duration of its application. The  
(12) CEA was tested successfully and returned to service. No other problems have been  
(13) experienced and no further corrective action is planned.  
(14) \_\_\_\_\_

(15) FACILITY STATUS B (28) % POWER 0 0 0 (29) OTHER STATUS NA (30) METHOD OF DISCOVERY A (31) DISCOVERY DESCRIPTION Low Power Physics Testing (32)

(16) ACTIVITY CONTENT Z (33) AMOUNT OF ACTIVITY NA (35) LOCATION OF RELEASE NA (36)

(17) PERSONNEL EXPOSURES NUMBER 0 0 0 (37) TYPE Z (38) DESCRIPTION NA (39)

(18) PERSONNEL INJURIES NUMBER 0 0 0 (40) DESCRIPTION NA (41)

(19) LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION NA (43) 8212070399 821118 PDR ADOCK 05000361 S PDR

(20) PUBLICITY ISSUED N (44) DESCRIPTION NA (45) NRC USE ONLY