


50-298



# Nebraska Public Power District

GENERAL OFFICE  
P.O. BOX 499, COLUMBUS, NEBRASKA 68601-0499  
TELEPHONE (402) 564-8561

LQA8200227

December 2, 1982

Office of Nuclear Reactor Regulation  
Attention: Mr. Domenic B. Vassallo, Chief  
Operating Reactors Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: Response to NRC Staff Request for Information  
Regarding Emergency Operation Facilities (EOF)

Dear Mr. Vassallo:

In response to a telephone request from our NRC Project Manager on December 2, 1982, the following information is provided:

Permanent Primary EOF

1. Response date to Generic Letter 82-10: June 4, 1982 letter from J. M. Pilant
2. Location: Onsite
3. Construction: Concrete
4. Protection factor: >5
5. Date started: September, 1982
6. % completed: Approximately 60%
7. HEPA Filters: Yes

Permanent AEOF (Back-up EOF)

1. Distance: Approximately 11 miles
2. Construction: Masonry
3. Construction status: Existing structure

Interim Primary EOF

1. Location: Onsite

Interim Back-up EOF

1. Location: The permanent back-up EOF is presently available.

If you should require additional information, please contact me.

Sincerely,

Jay M. Pilant  
Division Manager of  
Licensing & Quality Assurance

JMP:JDW:cmk

8212070402 821202  
PDR ADDCK 05000298  
F PDR

A007

298