

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER DALLAS, TEXAS 75201-3050

Log # TXX-3596  
File # 10140

December 3, 1982

Mr. Harold R. Denton  
Director of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
DOCKET NOS. 50-445 AND 50-446  
EMERGENCY OPERATIONS FACILITY SURVEY


Dear Mr. Denton:

In response to your request of December 2, 1982 concerning NRC  
Generic Letter 81-10, CPSES provides the following information:

1. The CPSES Emergency Operations Facility (EOF) is located 1.2 miles west of the power plant.
2. The EOF is constructed of concrete and the protection factor has been upgraded to  $\geq 15$ .
3. The HVAC in the EOF can be manually isolated providing a positive pressurization and HEPA filtration of any makeup air.
4. Construction of the EOF began September 1981. Construction was completed August 1982.
5. Equipment is currently being installed in the EOF and will be in place prior to fuel load.
6. An alternate EOF is not planned due to the upgraded protection factor rating of the EOF.

If you have any further questions, please contact this office.

Sincerely,



H. C. Schmidt  
Manager, Nuclear Services

HCS:grr

3001