

NOV 12 1982

Docket No. 99900317/82-01

Cooper Industries
Cooper Energy Services
ATTN: Mr. F. B. Stolba
Vice President/General Manager
Reciprocating Products
150 Lincoln Avenue
Grove City, PA 16127

Gentlemen:

This refers to the inspection conducted by Mr. W. E. Foster of this office on September 20-24, 1982, of your facilities at Grove City, Pennsylvania, associated with the manufacture of emergency diesel generators, and to the discussions of our findings with Mr. R. O. Wells and members of your staff at the conclusion of the inspection.

This inspection was made as a result of two 10 CFR Part 21 reports that have been filed by Cooper Energy Services with the Nuclear Regulatory Commission, Headquarters. The reports pertained to: (1) improperly repaired fuel nozzle holes in one power head of two diesel generators; and (2) disintegration of the mesh of the lube oil strainer basket. The latter condition affects diesel generators that have been furnished to the following nuclear generating stations: (a) Braidwood, (b) Byron, (c) Nine Mile Point, (d) Palo Verde, (e) South Texas, and (f) Susquehanna. The former was restricted to Palo Verde and Susquehanna.

Areas examined and our findings are discussed in the enclosed report. Within these areas, the inspection consisted of an examination of procedures and representative records, interviews with personnel, and observations by the inspector.

During the inspection, it was found that the implementation of your QA program failed to meet certain NRC requirements. The specific findings and references to the pertinent requirements are identified in the enclosures to this letter.

The Notice of Violation is sent to you pursuant to the provisions of Section 206 of the Energy Reorganization Act of 1974. You are required to

RIV	SC: R&CPS	BC: VPB: <i>UP</i>	D: V&TP	D: IES <i>26</i>	RA: RIV
CI: R&CPS	IBarnes	UPotapovs	RLBargart	EHJohnson	JTCollins
WEFoster/jkh	// 12/82	// 12/82	// 10/82	// 10/82	// 11/12/82
// 12/82					

8212070416 821112
PDR GA999 EMVCOIN
99900317 PDR

19:09

submit to this office within 30 days from the date of this letter, a written statement containing: (1) a description of steps that have been or will be taken to correct these items; (2) a description of steps that have been or will be taken to prevent recurrence; and (3) the dates your corrective actions and preventive measures were or will be completed. Consideration may be given to extending your response time for good cause shown.

You are also requested to submit a similar written statement for each item which appears in the enclosed Notice of Nonconformance.

The responses requested by this letter are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room. If this report contains any information that you believe to be exempt from disclosure under 10 CFR 9.5(a)(4), it is necessary that you (a) notify this office by telephone within 10 days from the date of this letter of your intention to file a request for withholding; and (b) submit within 25 days from the date of this letter a written application to this office to withhold such information. If your receipt of this letter has been delayed such that less than 7 days are available for your review, please notify this office promptly so that a new due date may be established. Consistent with Section 2.790(b)(1), any such application must be accompanied by an affidavit executed by the owner of the information which identifies the document or part sought to be withheld, and which contains a full statement of the reasons on the basis which it is claimed that the information should be withheld from public disclosure. This section further requires the statement to address with specificity the considerations listed in 10 CFR 2.790(b)(4). The information sought to be withheld shall be incorporated as far as possible into a separate part of the affidavit. If we do not hear from you in this regard within the specified periods noted above, the report will be placed in the Public Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

Uldis Potapovs, Chief
Vendor Program Branch

Enclosures:

1. Appendix A - Notice of Violation
2. Appendix B - Notice of Nonconformance
3. Appendix C - Inspection Report No. 99900317/82-01
4. Appendix D - Inspection Data Sheets (7 pages)

Cooper Industries

-3-

bcc:

IE Files

AEOD

NRC:PDR

QAB

Reg. Administrators I, II, III, IV, V

EHJohnson, RIV

RLBangart, RIV