



State of New Jersey
Department of Environmental Protection and Energy

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625-0415
Tel (609) 987-2032
Fax (609) 987-6354

June 16, 1994

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Hope Creek Generating Station
Docket No. 50-354
License Change Request LCR 94-01
Allowed Out-Of-Service Time for Emergency Core
Cooling Systems (ECCS)

By letter dated March 31, 1994, Public Service Electric and Gas Company submitted the subject license change request to the Nuclear Regulatory Commission. The proposed change would establish an allowed out-of-service time of 72 hours for any one low pressure ECCS injection/spray subsystem inoperable in addition to an inoperable High Pressure Coolant Injection system.

The New Jersey Department of Environmental Protection and Energy's Bureau of Nuclear Engineering reviewed the above amendment in accordance with the requirements of 10CFR50.91(b), and has no comments.

If you have any questions, please contact Suren Singh at (609) 987-2039 or Rich Pinney at (609) 987-2086.

Sincerely,

Kent Tosch, Manager
Bureau of Nuclear Engineering

230004

9406240133 940616
PDR ADOCK 05000354
P PDR

ADCK 1/0

c: Acting Assistant Director McMahon
Radiation Protection Programs
N.J. DEPE'

J. Stone
NRC Project Manager

D. Chawaga
NRC Region I State Liaison

C. Marschall
Artificial Island Senior Resident Inspector

F. Thomson
Manager, Licensing and Regulation
PSE&G