

DISTRIBUTION:
 Document Control 50-440/50-441
 NRC PDR
 PRC System
 LB#1 Rdg
 MRushbrook
 JStefano

NOV 30 1982

Docket Nos.: 50-440
 and 50-441

MEMORANDUM FOR: B. J. Youngblood, Chief
 Licensing Branch No. 1
 Division of Licensing

FROM: John J. Stefano, Project Manager
 Licensing Branch No. 1
 Division of Licensing

SUBJECT: REPORT OF CONFERENCE CALL WITH THE CLEVELAND ELECTRIC
 ILLUMINATING COMPANY (CEI) REGARDING SRV HYDRODYNAMIC
 LOADS TEST - PERRY NUCLEAR POWER PLANT (UNITS 1 AND 2)

During the meeting with CEI on November 22, 1982 (reported in my memo to you dated November 29, 1982) a conference call was scheduled for November 24, 1982 during which the SEB staff would advise CEI of the specific additional information required for them to reach a decision on the Perry SRV no-test proposal received from CEI. This is a report of that conference call, which was participated in by the following individuals.

<u>NRC</u>	<u>CEI</u>	<u>Gilbert Associates</u>
D. Jeng, SEB	E. Buzzelli	C. Cheng
L. Yang, SEB	P. Nevins	C. Vath
N. Chokshi, SEB		F. Lahovski
K. Skaukat, SEB		
J. Stefano, LB#1		

In summary, the SEB staff requested CEI/Gilbert Associates to (1) perform a further analysis for Perry using SRV and SRVCO loading according to GE methodology and develop the design floor spectra; (2) compare these spectra with Kuosheng spectra at corresponding locations; (3) provide a discussion of the differences found, if any, in forcing functions used at Kuosheng and Perry, and compare both radial and vertical spectra at key locations of affected structures in the suppression pool region; and (4) based on this comparison, discuss the similarities/differences between the structures and conclusions with regard to fluid-structure interaction phenomena. CEI was also requested to summarize in one comprehensive document, the technical basis for not considering in-plant SRV tests at Perry in responding; i.e. include in its response, a summarization of information contained in its submittals of October 15 and November 17, 1982.

8212080021 821130
 PDR ADOCK 05000440
 A PDR

OFFICE						
SURNAME						
DATE						

CEI was unable to advise during the conference call when we might expect to receive this information and committed to advise the project manager of a date by November 29. I stressed to CEI that the SEB staff would require 5-7 working days after receipt on this information to make a decision on its proposal, and that the information should be in hand the week of December 6, 1982 if we are to meet CEI's decision deadline of December 15, 1982.

151

John J. Stefano, Project Manager
Licensing Branch No. 1
Division of Licensing

- cc: T. Novak
- F. Schauer
- D. Jeng
- L. Yang
- N. Chokshi
- K. Skaukat
- F. Eltawila
- D. Terao

OFFICE	DL:LB#1	DL:LB#1					
SURNAME	JStefano:cw	BJYoungblood					
DATE	11/30/82	11/30/82					