



Carolina Power & Light Company  
PO Box 10429  
Southport NC 28461

Roy A. Anderson  
Vice President  
Brunswick Nuclear Plant  
910 457-2496

June 20, 1994

SERIAL: BSEP 94-0224

U. S. Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2  
DOCKET NOS. 50-325 & 50-324/LICENSE NOS. DPR-71 & DPR-62  
RESPONSE TO NRC BULLETIN 93-02, SUPPLEMENT 1: DEBRIS PLUGGING OF  
EMERGENCY CORE COOLING SUCTION STRAINERS

Gentlemen:

The purpose of this letter is to provide the 30-day confirmation of completion of actions regarding NRC Bulletin 93-02, Supplement 1, Debris Plugging of Emergency Core Cooling Suction Strainers, for Carolina Power & Light Company's (CP&L) Brunswick Steam Electric Plant, Units 1 and 2.

CP&L responded to NRC Bulletin 93-02, Supplement 1, on April 19, 1994. In that response, CP&L committed to: 1) provide training for Operations and Technical Support Center personnel and 2) revise the Unit 1 and Unit 2 Core Spray System Operating Procedures to allow switching the core spray pump suction from the suppression pool to the condensate storage tank if the suppression pool is not available as a source of water. CP&L has completed the above actions, as committed in the April 19, 1994 response to NRC Bulletin 93-02, Supplement 1. No additional procedures or other measures to provide compensatory actions to prevent, delay, or mitigate a loss of available net positive suction head (NPSH) margin under LOCA conditions are considered necessary at this time. CP&L continues to monitor the BWR Owners' Group testing efforts on this issue.


240126

9406240212 940620  
PDR ADDCK 05000324  
PDR

IF/1  
1/0


Please refer any questions regarding this submittal to Mr. R. P. Lopriore at (910) 457-2212.

Sincerely,

  
Roy A. Anderson

KAH/

Roy A. Anderson, having been first duly sworn, did depose and say that the information contained herein is true and correct to the best of his information, knowledge and belief; and the sources of his information are officers, employees, and agents of Carolina Power & Light Company.

  
Notary (Seal)

My commission expires: August 12, 1996

- cc: Mr. S. D. Ebner, Regional Administrator, Region II  
Mr. P. D. Milano, NRR Senior Project Manager - Brunswick Units 1 and 2  
Mr. R. L. Prevatte, Brunswick NRC Senior Resident Inspector