

DOCUMENT CONTROL NO. MCEI-0400-47  
REVISION NO. 0001  
PAGE NO. 1 OF 153

TITLE MCGUIRE UNIT 2 CYCLE 9  
CORE OPERATING LIMITS REPORT

		SIGNOFF DATE
PREPARED BY	<u>Geoff A. Pinto</u>	<u>6/20/94</u>
CHECKED BY	<u>Thomas D. Ray</u>	<u>June 20, 1994</u>
APPROVED BY	<u>R H Clark</u>	<u>6/20/94</u>

**McGuire Nuclear Station COLR**

**McGuire Unit 2 Cycle 9**

**Core Operating Limits Report**

**June 1994**

Revision 1

Duke Power Company

**NOTE**

The contents of this document have been reviewed to verify that no material herein either directly or indirectly changes or affects the results and conclusions presented in the 10CFR50.59 M2C9 Reload Safety Evaluation (calculation file: MCC-1552.08-00-0210)

## McGuire 2 Cycle 9 Core Operating Limits Report

### REVISION LOG

<u>Revision</u>	<u>Effective Date</u>	<u>Effective Pages</u>
Original Issue	August 25, 1993	Pages 6, 8, 9, 12, 13, 15-153
Revision 1	June 20, 1994	Pages 1-3, 3A, 4, 5, 5A, 5B, 7, 7A, 10, 11, 14, 14A

## McGuire 2 Cycle 9 Core Operating Limits Report

### 1.0 Core Operating Limits Report

This Core Operating Limits Report, (COLR), for McGuire, Unit 2, Cycle 9 has been prepared in accordance with the requirements of Technical Specification 6.9.1.9.

The Technical Specifications affected by this report are listed below:

- 2.2.1 Reactor Trip System Instrumentation Setpoints
- 3/4.1.1.3 Moderator Temperature Coefficient
- 3/4.1.2.5 Borated Water Source - Shutdown
- 3/4.1.2.6 Borated Water Source - Operating
- 3/4.1.3.5 Shutdown Rod Insertion Limit
- 3/4.1.3.6 Control Rod Insertion Limit
- 3/4.2.1 Axial Flux Difference
- 3/4.2.2 Heat Flux Hot Channel Factor
- 3/4.2.3 Nuclear Enthalpy Rise Hot Channel Factor
- 3/4.5.1.1 Accumulators
- 3/4.5.5 Refueling Water Storage Tank

## McGuire 2 Cycle 9 Core Operating Limits Report

### 1.1 Operating Limits

The cycle-specific parameter limits for the specifications listed in section 1.0 are presented in the following subsections. These limits have been developed using NRC-approved methodologies specified in Technical Specification 6.9.1.9.

### 2.0 Reactor Trip System Instrumentation Setpoints (Specification 2.2.1)

#### 2.1 Overtemperature $\Delta T$ Setpoint Parameter Values

<u>Parameter</u>	<u>Value</u>
Overtemperature $\Delta T$ reactor trip setpoint	$K_1 \leq 1.1988$
Overtemperature $\Delta T$ reactor trip heatup setpoint penalty coefficient	$K_2 = 0.03354/^{\circ}\text{F}$
Overtemperature $\Delta T$ reactor trip depressurization setpoint penalty coefficient	$K_3 = 0.001522/\text{psi}$
Measured reactor vessel $\Delta T$ lead/lag time constants	$\tau_1 \geq 8 \text{ sec.}$ $\tau_2 \leq 3 \text{ sec.}$
Measured $\Delta T$ lag time constant	$\tau_3 \leq 2 \text{ sec.}$
Measured reactor vessel average temperature lead/lag time constants	$\tau_4 \geq 28 \text{ sec.}$ $\tau_5 \leq 4 \text{ sec.}$
Measure reactor vessel average temperature lag time constant	$\tau_6 \leq 2 \text{ sec.}$
$f_1(\Delta I)$ "positive" breakpoint	$= 12.0 \% \Delta I$
$f_1(\Delta I)$ "negative" breakpoint	$= -44.0 \% \Delta I$
$f_1(\Delta I)$ "positive" slope	$= 1.619 \% \Delta T_o / \% \Delta I$
$f_1(\Delta I)$ "negative" slope	$= 3.436 \% \Delta T_o / \% \Delta I$

McGuire 2 Cycle 9 Core Operating Limits Report

2.2 Overpower  $\Delta T$  Setpoint Parameter Values

<u>Parameter</u>	<u>Value</u>
Overpower $\Delta T$ reactor trip setpoint	$K_4 \leq 1.0851$
Overpower $\Delta T$ reactor trip heatup setpoint penalty coefficient	$K_6 = 0.001207/^\circ\text{F}$
Measured reactor vessel $\Delta T$ lead/lag time constants	$\tau_1 \geq 8 \text{ sec.}$ $\tau_2 \leq 3 \text{ sec.}$
Measured $\Delta T$ lag time constant	$\tau_3 \leq 2 \text{ sec.}$
Measure reactor vessel average temperature lag time constant	$\tau_6 \leq 2 \text{ sec.}$
Measure reactor vessel average temperature rate-lag time constant	$\tau_7 \geq 5 \text{ sec.}$
$f_2(\Delta I)$ "positive" breakpoint	$= 35.0 \% \Delta I$
$f_2(\Delta I)$ "negative" breakpoint	$= -35.0 \% \Delta I$
$f_2(\Delta I)$ "positive" slope	$= 7.0 \% \Delta T / \% \Delta I$
$f_2(\Delta I)$ "negative" slope	$= 7.0 \% \Delta T / \% \Delta I$

## McGuire 2 Cycle 9 Core Operating Limits Report

### 3.0 Moderator Temperature Coefficient (Specification 3/4.1.1.3)

#### 3.0.1 The Moderator Temperature Coefficient (MTC) Limits are:

The MTC shall be less positive than the limits shown in Figure 1. The BOC, ARO, HZP MTC shall be less positive than  $0.7 \times 10E-04 \Delta K/K/^{\circ}F$ .

The EOC, ARO, RTP MTC shall be less negative than  $-4.1 \times 10E-04 \Delta K/K/^{\circ}F$ .

#### 3.0.2 The MTC Surveillance Limit is:

The 300 PPM ARO, RTP MTC should be less negative than or equal to  $-3.2 \times 10E-04 \Delta K/K/^{\circ}F$ .

Where: BOC stands for Beginning of Cycle  
EOC stands for End of Cycle  
ARO stands for All Rods Out  
HZP stands for Hot Zero Thermal Power  
RTP stands for Rated Thermal Power

## McGuire 2 Cycle 9 Core Operating Limits Report

### 3.1 Borated Water Source - Shutdown (Specification 3/4.1.2.5)

#### 3.1.1 Volume and boron concentrations for the Boric Acid Storage System and the Refueling Water Storage Tank (RWST) during modes 5 & 6:

<u>Parameter</u>	<u>Limit</u>
Boric Acid Storage System minimum contained borated water volume for LCO 3.1.2.5a	6,132 gallons
Boric Acid Storage System minimum boron concentration for LCO 3.1.2.5a	7,000 ppm
Boric Acid Storage System minimum water volume required to maintain SDM at 7,000 ppm	585 gallons
Refueling Water Storage Tank minimum contained borated water volume for LCO 3.1.2.5b	26,000 gallons
Refueling Water Storage Tank minimum boron concentration for LCO 3.1.2.5b	2,175 ppm
Refueling Water Storage Tank minimum water volume required to maintain SDM at 2,175 ppm	3,500 gallons



## McGuire 2 Cycle 9 Core Operating Limits Report

### 3.2 Borated Water Source - Operating (Specification 3/4.1.2.6)

#### 3.2.1 Volume and boron concentrations for the Boric Acid Storage System and the Refueling Water Storage Tank (RWST) during modes 1, 2, 3, & 4:

<u>Parameter</u>	<u>Limit</u>
Boric Acid Storage System minimum contained borated water volume for LCO 3.1.2.6a	20,453 gallons
Boric Acid Storage System minimum boron concentration for LCO 3.1.2.6a	7,000 ppm
Boric Acid Storage System minimum water volume required to maintain SDM at 7,000 ppm	9,851 gallons
Refueling Water Storage Tank minimum contained borated water volume for LCO 3.1.2.6b	372,100 gallons
Refueling Water Storage Tank minimum boron concentration for LCO 3.1.2.6b	2,175 ppm
Refueling Water Storage Tank maximum boron concentration for LCO 3.1.2.6b	2,275 ppm
Refueling Water Storage Tank minimum water volume required to maintain SDM at 2,175 ppm	57,107 gallons

### 3.3 Shutdown Rod Insertion Limit (Specification 3/4.1.3.5)

3.3.1 The shutdown rods shall be withdrawn to at least 222 steps.

### 3.4 Control Rod Insertion Limits (Specification 3/4.1.3.6)

3.4.1 The control rod banks shall be limited to physical insertion as shown in Figure 2.

### 3.5 Axial Flux Difference (Specification 3/4.2.1)

3.5.1 The Axial Flux Difference (AFD) Limits are provided in Figure 3.

## McGuire 2 Cycle 9 Core Operating Limits Report

### 3.6 Heat Flux Hot Channel Factor, $F_Q(X,Y,Z)$ (Specification 3/4.2.2)

3.6.1  $F_Q^{RTP} = 2.32$

3.6.2  $K(Z)$  is provided in Figure 4 for Mark-BW fuel.

3.6.3  $K(Z)$  is provided in Figure 5 for OFA fuel.

The following parameters are required for core monitoring per the Surveillance Requirements of Specification 3/4.2.2:

3.6.4  $[F_Q^L(X,Y,Z)]^{OP} = F_Q^D(X,Y,Z) \times M_Q(X,Y,Z) / (UMT \times MT \times TILT)$

where  $[F_Q^L(X,Y,Z)]^{OP}$  = cycle dependent maximum allowable design peaking factor which ensures that the  $F_Q(X,Y,Z)$  limit will be preserved for operation within the LCO limits  $[F_Q^L(X,Y,Z)]^{OP}$ .  $[F_Q^L(X,Y,Z)]^{OP}$  includes allowances for calculational and measurement uncertainties.

$F_Q^D(X,Y,Z)$  = the design power distribution for  $F_Q$ .  $F_Q^D(X,Y,Z)$  is provided in Table 1 for normal operating conditions and in Table 2 for power escalation during startup operations.

$M_Q(X,Y,Z)$  = the margin remaining in core location  $X,Y,Z$  to the LOCA limit in the transient power distribution.  $M_Q(X,Y,Z)$  is provided in Table 1 for normal operating conditions and in Table 2 for power escalation during startup operations.

UMT = Measurement Uncertainty (UMT = 1.05).

MT = Engineering Hot Channel Factor (MT = 1.03).

TILT = Peaking penalty that accounts for allowable quadrant power tilt ratio of 1.02. (TILT = 1.035)

NOTE:  $[F_Q^L(X,Y,Z)]^{OP}$  is the parameter identified as  $F_Q^{MAX}(X,Y,Z)$  in DPC-NE-2011PA.

### McGuire 2 Cycle 9 Core Operating Limits Report

$$3.6.5 \quad [F_Q^L(X,Y,Z)]^{RPS} = F_Q^D(X,Y,Z) \times (M_C(X,Y,Z)/(UMT \times MT \times TILT))$$

where  $[F_Q^L(X,Y,Z)]^{RPS}$  = cycle dependent maximum allowable design peaking factor which ensures that the centerline fuel melt limit will be preserved for operation within the LCO limits.  $[F_Q^L(X,Y,Z)]^{RPS}$  includes allowances for calculational and measurement uncertainties.

$F_Q^D(X,Y,Z)$  = the design power distributions for  $F_Q$ .  $F_Q^D(X,Y,Z)$  is provided in Table 1 for normal operating conditions and in Table 2 for power escalation during startup operations.

$M_C(X,Y,Z)$  = the margin remaining to the CFM limit in core location X,Y,Z from the transient power distribution.  $M_C(X,Y,Z)$  calculations parallel the  $M_Q(X,Y,Z)$  calculations described in DPC-NE-2011PA, except that the LOCA limit is replaced with the CFM limit.  $M_C(X,Y,Z)$  is provided in Table 3 for normal operating conditions and in Table 4 for power escalation during startup operations.

UMT = Measurement Uncertainty (UMT = 1.05).

MT = Engineering Hot Channel Factor (MT = 1.03).

TILT = Peaking penalty that accounts for allowable quadrant power tilt ratio of 1.02. (TILT = 1.035)

NOTE:  $[F_Q^L(X,Y,Z)]^{RPS}$  is the parameter identified as  $F_Q^{MAX}(X,Y,Z)$  in DPC-NE-2011PA.

### 3.6.6 KSLOPE = 0.0725

where KSLOPE = Adjustment to the  $K_1$  value from OTAT required to compensate for each 1% that  $[F_Q^L(X,Y,Z)]^{RPS}$  exceeds its limit.

## McGuire 2 Cycle 9 Core Operating Limits Report

### 3.7 Nuclear Enthalpy Rise Hot Channel Factor, $F_{\Delta H}(X,Y,Z)$ (Specification 3/4.2.3)

$$[F_{\Delta H}(X,Y)]^{LCO} = \text{MARP}(X,Y) \times [1.0 + (1/\text{RRH}) \times (1.0 - P)]$$

#### 3.7.1 McGuire 2 Cycle 9 Operating Limit Maximum Allowable Radial Peaks, (MARP(X,Y)), are provided in Table 7.

The following parameters are required for core monitoring per the Surveillance Requirements of Specification 3/4.2.3:

$$[F_{\Delta H}^L(X,Y)]^{SURV} = F_{\Delta H}^D(X,Y) \times M_{\Delta H}(X,Y) / (\text{UMR} \times \text{TILT}),$$

as identified in DPC-NE-2011PA.

where

UMR = Uncertainty value for measured radial peaks, (UMR = 1.04).

TILT = Factor to account for a peaking increase due to an allowable quadrant tilt ratio of = 1.02 (TILT = 1.035).

3.7.2  $F_{\Delta H}^D(X,Y)$  = the design power distribution for  $F_{\Delta H}$ .  $F_{\Delta H}^D(X,Y)$  is provided in Table 5 for normal operating conditions and in Table 6 for power escalation during startup operations..

3.7.3  $M_{\Delta H}(X,Y)$  = the margin remaining in core location X,Y to the DNB limit from the transient power distribution.  $M_{\Delta H}(X,Y)$  is provided in Table 5 for normal operating conditions and in Table 6 for power escalation during startup operations..

3.7.4  $\text{RRH} = 3.34$  when  $0.0 < P \leq 1.0$ ,

where  $\text{RRH}$  = Thermal Power reduction required to compensate for each 1% that  $F_{\Delta H}(X,Y)$  exceeds its limit.

$$P = \frac{\text{Thermal Power}}{\text{Rated Thermal Power}}$$

3.7.5  $\text{TRH} = 0.04$

where  $\text{TRH}$  = Reduction in  $\text{OTAT } K_1$  setpoint required to compensate for each 1% that  $F_{\Delta H}(X,Y)$  exceeds its limit.

## McGuire 2 Cycle 9 Core Operating Limits Report

### 3.8 Accumulators (Specification 3/4.5.1.1)

#### 3.8.1 Boron concentration limits during modes 1, 2, & 3:

<u>Parameter</u>	<u>Limit</u>
Cold Leg Accumulator minimum boron concentration for LCO 3.5.1.1c	2,000 ppm
Cold Leg Accumulator maximum boron concentration for LCO 3.5.1.1c	2,275 ppm
Minimum Cold Leg Accumulator boron concentration required to ensure post-LOCA subcriticality	1,900 ppm

### 3.9 Refueling Water Storage Tank (Specification 3/4.5.5)

#### 3.9.1 Boron concentration limits during modes 1, 2, 3, & 4:

<u>Parameter</u>	<u>Limit</u>
Refueling Water Storage Tank minimum boron concentration for LCO 3.5.5b	2,175 ppm
Refueling Water Storage Tank maximum boron concentration for LCO 3.5.5b	2,275 ppm