	LICENSEE EVENT REPORT
	CONTROL BLOCK: ( LEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 7 8	N J S G S 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 6 LICENSE TYPE 30 57 CAT 58
CON'T 0 1 7 8	SOURCE L 6 0 5 0 0 0 2 7 2 7 1 1 2 1 8 2 8 1 1 2 4 8 2 9  EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  On November 21, 1982, during routine refueling operations, video inspection of re-
0 3	moved fuel assemblies revealed cladding ruptures on an element in Fuel Assembly D-20.
0 4	The assembly had been in the core for 3 fuel cycles; it was in Core Location L-3 during
0 5	the most recent cycle. Following completion of inspection of the assembly, it was
0 6	placed in Spent Fuel Pit Location E-4. The event possibly constitutes abnormal
0 7	degradation of the cladding and is reportable in accordance with Technical Specification
0 8	6.9.1.8.c. (82-05)
0 9	SYSTEM CAUSE CODE SUBCODE SUBC
	LER RO REPORT NO.  LER RO REPORT NO.  REPORT NO.  SEQUENTIAL REPORT NO.  OCCURRENCE CODE TYPE NO.  NO.  NO.  17 REPORT NO.  21 22 23 24 26 27 28 29 30 31 32
	ACTION FUTURE COMPONENT NORTHOD HOURS 22 ATTACHMENT SUBMITTED FORM SUB SUPPLIER SUPPLIER WANUFACTURER W 1 2 10 20 33 37 40 40 41 23 42 43 43 45 47
1 0	The cause of the cladding failure is not known at this time. A more detailed in-
1 1	spection of the module an an investigation will be conducted by the vendor. A
1 2	Supplemental Report will be submitted upon final resolution of the problem.
1 3	
7 8	
1 5	9 FACILITY STATUS  9 OTHER STATUS  9 OTHER STATUS  9 N/A  B 30 METHOD OF DISCOVERY DESCRIPTION 32  B 31 Video Inspection  9 10 12 13 44 45 46
	CTIVITY CONTENT ELEASED OF RELEASE AMOUNT OF ACTIVITY 35  2 33 2 34 N/A  PERSONNEL EXPOSURES  AMOUNT OF ACTIVITY 35  N/A  44 45 46  LOCATION OF RELEASE 36  N/A  80
1 7	NUMBER TYPE DESCRIPTION (39) N/A
1 8	NUMBER DESCRIPTION 41 N/A 80
1 9	LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION  N/A
2 0	PUBLICITY   SSUED   DESCRIPTION (45)   PDR   ADDCK 05000272   PDR   ADDCK 05000272   PDR   68 69   80 5
	NAME OF PREPARER R. Frahm PHONE 609/935-6000 Ext 3078 6