

# LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 M N P I N 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 \_\_\_\_\_ 5  
8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

0 1 REPORT SOURCE L 6 0 5 0 0 0 2 8 2 7 1 1 1 2 8 2 8 1 1 3 0 8 2 9  
7 8 DOCKET NUMBER 60 61 68 69 EVENT DATE 74 75 REPORT DATE 80

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During power operation, control power was lost to No. 22 Diesel Cooling Water  
0 3 Pump. The pump was inoperable for about 4 hours. Not repetitive. Tech Spec  
0 4 3.3.1.d applies. No effect on public health and safety since redundant  
0 5 equipment was operable.  
0 6  
0 7  
0 8

0 9 SYSTEM CODE W A 11 CAUSE CODE E 12 CAUSE SUBCODE X 13 COMPONENT CODE X X X X X X 14 COMP SUBCODE Z 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LE/RO REPORT NUMBER 8 2 22 EVENT YEAR 21 22 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER A 25 REVISION NO 0 32 COMPONENT MANUFACTURER Z 9 9 9 26

ACTION TAKEN B 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER A 25 REVISION NO 0 32 COMPONENT MANUFACTURER Z 9 9 9 26

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Loose fuse clip was not making good contact with fuse, Clip was repaired and pump  
1 1 tested satisfactorily.  
1 2  
1 3  
1 4

1 5 FACILITY STATUS E 28 % POWER 0 7 8 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Control Room Annunciation 32  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 6 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

8212080429 821130  
PDR ADOCK 05000282  
S PDR

NRC USE ONLY

NAME OF PREPARER A. A. Hunstad

PHONE: 612-388-1121