

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N J S G S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 _____ 5
7 8 9 14 15 25 26 57 CAT 58

CON'T
01 REPORT SOURCE L 0 5 0 0 0 3 1 1 7 1 1 2 1 8 2 2 B 1 1 2 4 8 2 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 On November 21, 1982, during routine surveillance, an operator discovered a small
03 service water leak of approximately 0.25 GPM on a cooling coil of No. 25 Containment
04 Fan Coil Unit (CFCU). The leak was isolated and prompt notification of the NRC was
05 made. Action Statement 3.6.2.3a was already in effect due to planned maintenance on
06 No. 22 Service Water Header. Both containment spray systems were operable. The
07 occurrence constituted degradation of containment in accordance with Technical
08 Specification 6.9.1.8.c. (82-128, 82-122, 82-120, 82-119, 82-113)

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
S B 11 B 12 A 13 H T E X C H 14 C 15 Z 16
7 8 9 10 11 12 13 18 19 20

17 LER RO REPORT NUMBER 8 2 21 22
SEQUENTIAL REPORT NO. 1 3 5 24 26
OCCURRENCE CODE 0 1 28 29
REPORT TYPE T 30
REVISION NO. 0 32

ACTION TAKEN B 18 F 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 40
ATTACHMENT SUBMITTED Y 23 NPRD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER W 1 2 0 26
33 34 35 36 37 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The failed CFCU cooling coil resulted from erosion by silt in the service water. The
11 coil was repaired with Belzona metal filler and the CFCU was satisfactorily tested.
12 No. 22 Service Water Header was restored November 23, and the action statement was
13 terminated. New design coils are to be installed during the next refueling.
14

15 FACILITY STATUS E 28 % POWER 0 8 1 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Routine Surveillance 32
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT Z 33 Z 34 NA 35 AMOUNT OF ACTIVITY NA 36 LOCATION OF RELEASE NA 36
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 80

20 ISSUED DESCRIPTION N 44 NA 45 PDR ADOCK 05000311 S PDR
7 8 9 10 80

8212080443 821124
PDR ADOCK 05000311
S PDR

NRC USE ONLY

NAME OF PREPARER R. Frahm

PHONE 609/935-6000 Ext 3078