

Phillips

DEC 12 1990

Docket No. 50-395
License No. NPF-12

South Carolina Electric & Gas Company
ATTN: Mr. John L. Skolds
Vice President, Nuclear Operations
Virgil C. Summer Nuclear Station
P. O. Box 88
Jenkinsville, SC 29065

Gentlemen:

SUBJECT: VIRGIL C. SUMMER NUCLEAR STATION NUCLEAR CORPORATE EMERGENCY
MANAGEMENT PLAN

We have completed our review of Revision 18 to your Corporate Emergency Management Plan (CEMP-100). Based on our review, we have concluded that the changes meet the planning standards of 10 CFR 50.47(b) and the requirements of Appendix E to 10 CFR 50 with one exception.

On page 50 of 59, Section 7.3, "Maintenance and Inventory of Emergency Equipment and Supplies," the inventory frequency was changed from "at approximately six months" to "at regular intervals." The inventory list, frequency, and location of equipment is not defined in the paragraph. This matter was discussed with Mr. Mark Counts of South Carolina Electric and Gas Company. The licensee representative committed to revise the paragraph to reference EPP-019 and EPP-022 of the Site Emergency Plan. These procedures specify the inventory frequency, locations, and inventory lists for emergency equipment that are to be performed per Section 7.3 of CEMP-100. The licensee committed to complete the aforementioned changes during the next Plan review cycle.

Please be reminded that 10 CFR 50.54(q) requires that proposed changes that decrease the effectiveness of your Emergency Plan shall not be implemented without application to and approval by the Commission. However, changes may be made without Commission approval if such changes do not decrease the effectiveness of the Plan, and the Plan, as changed, continues to meet the standards of 10 CFR 50.47(b) and the requirements of Appendix E to 10 CFR 50. If a change is made without approval, you should furnish copies in accordance with 10 CFR 50.54(q). Also, any changes to the Emergency Plan Implementing Procedures should be made in accordance with the requirements of 10 CFR 50, Appendix E, Section V.

9101110150 901212
PDR ADDCK 05000395
F PDR

100014

TE35
40

Should you have any questions regarding this letter, please contact Mr. William H. Rankin of my staff at 404-331-5618.

Sincerely,

ORIGINAL SIGNED BY
DOUGLAS M. COLLINS

Douglas M. Collins, Chief
Radiological Protection and
Emergency Preparedness Branch
Division of Radiation Safety
and Safeguards

cc: G. G. Soutt, General Manager
Nuclear Plant Operations
Summer Nuclear Station
P. O. Box 88 (Mail Code 5)
Jenkinsville, SC 29065

A. R. Koon, Jr., Manager
Nuclear Licensing
Summer Nuclear Station
P. O. Box 88 (Mail Code 830)
Jenkinsville, SC 29065
J. B. Knotts, Jr.
Bishop, Cook, Purcell & Reynolds
1400 L Street, NW
Washington, D. C. 20005-3502

R. V. Tanner
Executive Vice President
South Carolina Public
Service Authority
P. O. Box 398
Moncks Corner, SC 29461-0398
Chairman, Fairfield County Council
P. O. Box 293
Winnsboro, SC 29180
Attorney General
Box 11549
Columbia, SC 29211

Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, SC 29201

bcc: (See page 3)

South Carolina Electric & Gas Company 3

bcc: G. Wunder, NRR
Document Control Desk
DRP Section Chief

NRC Resident Inspector
U.S. Nuclear Regulatory Commission
Route 1, Box 64
Jenkinsville, SC 29065

R11:DRSS
*

GSalyers
11/ /90

*See previous concurrence

R11:DRSS
*

WRankin
11/ /90

R11:DRP
*

DVerrelli
11/ /90