

JUN 17 1994

Docket Nos. 50-352  
50-353

Mr. D. M. Smith  
Senior Vice President-Nuclear  
PECO Energy  
Nuclear Group Headquarters  
Correspondence Control Desk  
P.O. Box 195  
Wayne, Pennsylvania 19087-0195

Dear Mr. Smith:

SUBJECT: COMBINED INSPECTION REPORT NOS. 50-352/94-12 AND 50-353/94-12

This letter transmits the results of the resident safety inspection by Messrs. N. Perry, T. Easlick and Ms. A. Wilford from May 3, through June 6, 1994, at the Limerick Generating Station, Limerick, Pennsylvania. The inspection focused on issues important to ensuring the public health and safety and consisted of observations of activities, reviews of documents and interviews with plant personnel. The results are documented in the enclosed report and were discussed with Mr. R. Boyce of your staff at the conclusion of the inspection.

In general, activities were found to be conducted safely. In one instance, enforcement discretion was exercised because of PECO Energy's comprehensive corrective actions. The event involved a health physics technician's failure to properly enter the projected release time into the dose assessment computer code during a reactor water cleanup (RWCU) resin transfer, as well as the technician's failure to acknowledge that the projected offsite dose was in excess of the Emergency Action Level, for an Unusual Event declaration.

The plant staff's overall response to problems associated with both the RCIC systems was assessed as weak. Operators did not identify a low oil level on the Unit 1 RCIC pump. Furthermore, it took over 2 days for plant personnel to add oil to the Unit 2 RCIC oil pump.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

9406270265 940617  
PDR ADOCK 05000352  
G PDR

TEO  
111

JUN 17 1994

Mr. D. M. Smith

2

Your cooperation is appreciated.

Sincerely,

ORIGINAL SIGNED BY  
EDWARD C. WENZINGER

Edward C. Wenzinger, Chief  
Projects Branch No. 2  
Division of Reactor Projects

Enclosures: NRC Region I Inspection Report 50-352/94-12 & 50-353/94-12

cc w/encls:

J. Doering, Chairman, Nuclear Review Board  
D. R. Helwig, Vice President - Limerick Generating Station  
G. A. Hunger, Jr., Manager - Licensing Section  
J. L. Kantner, Regulatory Engineer - Limerick Generating Station  
Secretary, Nuclear Committee of the Board  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
K. Abraham, PAO (2)  
NRC Resident Inspector, Limerick  
Commonwealth of Pennsylvania

JUN 17 1994

Mr. D. M. Smith

3

bcc w/encl:

Region I Docket Room (with concurrences)

K. Gallagher, DRP

bcc w/encl: (Via E-Mail)

V. McCree, OEDO

F. Rinaldi, NRR

C. Miller, PDI-2, NRR

M. Shannon, ILPB

A. Wilford, OE

RI:DRP

*c/a t*

NPerry

6/15/94

RI:DRP

*c/a*

CAnderson

6/15/94

RI:DRP

*EW*

EWenzinger

6/17/94

OFFICIAL RECORD COPY

a:9412.pb

*IEO1*