

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N J O C P 1 1 2 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5  
7 8 U LICENSEE CODE 14 16 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 58

CON'T  
0 1 REPORT SOURCE L 6 0 1 5 1 0 0 0 2 1 1 9 7 1 1 0 2 2 8 2 2 8 2 9  
7 8 DOCKET NUMBER 58 60 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During a brush change on recirculation pump "D" MG set recirculation  
0 3 pump "E" tripped. This is considered reportable per Tech Specs,  
0 4 paragraph 6.9.2.b.2. Because "E" Recirculation pump was restarted  
0 5 within three (3) minutes, the safety significance is considered  
0 6 minimal.  
0 7  
0 8

0 9 SYSTEM CODE C B 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE Z Z Z Z Z Z 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16  
17 LER/RD REPORT NUMBER 6 2 23 SEQUENTIAL REPORT NO. 0 5 3 27 OCCURRENCE CODE 0 3 28 REPORT TYPE L 30 REVISION NO. 0 32  
ACTION TAKEN X 18 FUTURE ACTION H 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED Y 23 NPD-4 FORM SUB N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Apparent cause is a current overload on recirculation pump "E". This  
1 1 LER will be required reading for all operations perscnnel. The  
1 2 immediate action was to restart recirculation pump "E"; further action  
1 3 included replacing worn brushes on MG set associated with recirculation  
1 4 pump "E".

1 5 FACILITY STATUS E 28 % POWER 0 5 1 2 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION STA - Observation 32

1 6 ACTIVITY CONTENT Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
8212080525 821122  
PDR ADOCK 05000219  
S PDR

2 0 PUBLICITY ISSUED DESCRIPTION N 44 NA 45  
NRC USE ONLY