



**CENTERIOR
ENERGY**

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
PO. BOX 97
PERRY, OHIO 44081

Robert A. Stratman
VICE PRESIDENT - NUCLEAR

June 16, 1994
PY-CEI/NRR-1812L

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Generic Letter 92-01, Revision 1;
Accuracy Verification Of NRC P-T and
USE Limits Tables (TAC No. M83947)

Gentlemen:

By letter dated April 6, 1994, the Nuclear Regulatory Commission (NRC) staff requested that the information contained in two Tables be verified for accuracy. Enclosure 1 to the April 6, 1994 letter provided information on pressure-temperature (P-T) limits, and Enclosure 2 provided information on Upper Shelf Energy (USE) limits.

This letter formally provides the results of the requested verification. The only changes to the Tables are to NRC Enclosure 2, where the material type for the three shell plates (heat numbers C2557-1, B6270-1 and A1155-1) should be SA 533 Grade B Class 1 rather than A 533B-1.

This information was previously transmitted to the NRC Senior Project Manager for PNPP, Jon Hopkins, by telephone on May 31, 1994, per the schedule set during a teleconference between J. Hopkins and B. Ferrell on May 5, 1994.

If you have questions or require additional information, please contact Mr. James D. Kloosterman, Manager - Regulatory Affairs, at (216) 280-5833.

Very truly yours,

RAS:BSF:sc

cc: NRC Project Manager
NRC Resident Inspector Office
NRC Region III

240080

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

9406270441 940616
PDR ADOCK 05000440
P PDR

AD28 1/0