NRC FORM 365 **U.S. NUCLEAR REGULATORY COMMISSION** (7.77) LICENSEE EVENT REPORT 1. ..... 10) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) CONTROL BLOCK: - 0 0 0 0 0 - 0 0 3 4 AE I H 0 0 0 (2)CON'T REPORT 5 0 0 0 2 8 1 1 3 0 8 74 75 REPORT DATE 6 6 7 1 1 0 3 8 0 1 LG 31 SOURCE EVENT DATE DOCKET NUMBER EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) With the RPS Alternate Supply out of service for maintenance, the RPS 0 2 Supply Over-voltage Relay was discovered to be out of calibration while 03 [0]4] [performing maintenance work. Tech. Specs. Section 4.8.2.7 requires the Irelay to trip at less than or equal to 132 VAC; the relay tripped at 0 5 1132.6 VAC. The health and safety of the public were not affected by 0 6 this non-repetitive event. 0 0 8 1 SYSTEM CAUSE CAUSE COMP VALVE ODE COMPONENT CODE CODE SUBCODE SUBCODE ELLAYX ( IBI E1(12) A (13) R D (15) Z (16 0 9 (11 REVISION SEQUENTIAL. OCCURRENCE REPORT REPORT NO CODE EVENT YEAR TYPE LER/RO 0 81 21 1 | 2 | 5 013 L REPORT NUMBER ATTACHMENT SUBMITTED NPRD-4 PRIME COMP. COMPONENT METHOD ACTION FUTURE TAKEN ACTION EFFECT ON PLANT HOURS (22) FORM SUB. MANUFACTURER A 1 4 1 9 1 9 SUPP IER. 4 N 24 Z ] (21) (18)12 Z (20) 0 010 0 N N A IE 25 (23) (26) CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The cause of the RPS Supply Over-Voltage Relay being out of calibration | 1 0 1 1 | was component failure due to setpoint drift. The relay was recalibrated according to the "RPS MG SET OVERVOLTAGE-UNDERFREQUENCY & UNDERVOLTAGE FT&C" procedure, and set to trip at 131.9 VAC. The RPS Supply Over-Voltage Relay was returned to service on November 3, 1982. 1 4 80 METHOD OF DISCOVERY OTHER STATUS (30) FACILITY DIS LOVERY DESCRIPTION (32) N POWER A (31) Operational Event 9 7 NA E (28) 0 6 80 ACTIVITY CONTENT LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY (35) RELEASED\_OF RELEASE Z 33 NA Z (34) NA 10 44 80 PERSONNEL EXPOSURES DESCRIPTION (39) NUMBER TYPE 0 0 0 (37) Z (38) NA 80 PERSONNEL INJURIES DESCRIPTION (41) NUMBER 0 0 0 (40) NA 80 LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION NA Z (42) 8212090126 821130 PUBLIC:TY NRC USE ONLY PDR ADOCK 05000366 DESCRIPTION (45 S PDR N (44) NA 68 RO NAME OF PREPARER S. B. Tipps (912) 367-7851 PHONE ..