

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[0][1] [N][C][B][E][P][1] [2] [0][0]-[0][0][0][0][0][0]-[0][0] [3] [4][1][1][1][1] [4] _____ [5]
7 8 9 14 15 25 26 30 57 CAT 58
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T
 [0][1] [L] [6] [0][5][0]-[0][3][2][5] [7] [1][1][0][3][8][2] [8] [1][2][0][3][8][2] [9]
60 61 68 69 74 75 80
 REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0][2] Routine surveillance during plant operation revealed that primary containment
 [0][3] atmosphere oxygen analyzer, 1-CAC-AT-1259-2, had tripped. An immediate attempt to
 [0][4] restart the instrument was unsuccessful. At the time, redundant instrument,
 [0][5] 1-CAC-AT-1263-2, was operable and showing expected indications. This event did
 [0][6] not affect the health and safety of the public.

Technical Specifications 3.3.5.3, 3.6.6.4, 6.9.1.9b

[0][9] [S][E] [11] [E] [12] [A] [13] [R][E][L][A][Y][X] [14] [A] [15] [Z] [16]
9 10 11 12 13 18 19 20
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
 [17] [8][2] [1][2][8] [0][3] [L] [0]
21 22 23 24 26 27 28 29 30 31 32
 LER/RD REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
 [A] [18] [C] [19] [Z] [20] [Z] [21] [0][0][0][0] [N] [23] [Y] [24] [N] [25] [B][1][3][5] [26]
33 34 35 36 37 40 41 42 43 44 47
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1][0] The instrument had tripped and could not be restarted due to a failed low sample
 [1][1] flow relay in the instrument photohelic unit. The 1259-2 photohelic unit was
 [1][2] replaced and the instrument was calibrated and returned to service. These type CAC
 [1][3] analyzers, Model No. F3M3, are being replaced in accordance with an approved plant
 [1][4] modification.

[1][5] [E] [28] [0][7][6] [29] NA [A] [31] Operator Surveillance [32]
7 8 9 10 12 13 44 45 46 80
 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
 [1][3] [Z] [33] [Z] [34] NA [NA] [35] [NA] [36]
7 8 9 10 11 44 45 80
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
 [1][7] [0][0][0] [37] [Z] [38] NA [39]
7 8 9 11 12 13 80
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
 [1][8] [0][0][0] [40] NA [41]
7 8 9 11 12 80
 PERSONNEL INJURIES NUMBER DESCRIPTION
 [1][9] [Z] [42] NA [43]
7 8 9 10 80
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
 [2][0] [N] [44] NA [45]
7 8 9 10 80
 PUBLICITY ISSUED DESCRIPTION

8212090139 821203
 PDR ADOCK 05000325
 S PDR

NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: (919) 457-9521