

Docket No. 50-266
and 50-301

January 9, 1991

Mr. C. W. Fay, Vice President
Nuclear Power Department
Wisconsin Electric Power Company
231 W. Michigan Street, Room 308
Milwaukee, Wisconsin 53201

Dear Mr. Fay:

SUBJECT: WISCONSIN ELECTRIC POWER COMPANY CONFIRMATION OF ITS RESPONSE TO
NRC BULLETIN 88-10 AND SUPPLEMENT 1 TO BULLETIN 88-10
(TAC NOS. 71338 AND 71339)

By letters dated March 30, 1989 (NRC-89-038), June 13, 1989 (NRC-89-070), November 6, 1989 (NRC-89-138), May 16, 1990 (Accession No. 9005240119), and November 5, 1990 (NRC-90-109), Wisconsin Electric Power Company responded to Bulletin 88-10 and Supplement 1 to Bulletin 88-10. In these responses, you identified actions taken in response to the bulletin and confirmed that most activities required to address the issue of substandard molded case circuit breakers discussed in Bulletin 88-10 have been performed. The November 5, 1990 letter advised us of difficulties you are having in obtaining replacements for the untraceable circuit breakers in inverters 1DY03, 2DY03, DY0C, 1DY04, 2DY04 and DY0D. You further advised that you are taking steps to replace these breakers in 1991. Replacement of these breakers will constitute full implementation of your actions in regard to the bulletin.

A detailed technical review of your responses has not been performed; however, the area may be subject to inspection at a later date. If a subsequent inspection identifies deficiencies in your actions or responses, this issue will be reopened. Presently we consider this action complete.

By copy of this memorandum, Region III is advised of your position on this matter.

Sincerely,

Original Signed By:

Robert B. Samworth, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects - III,
IV and V
Office of Nuclear Reactor Regulation

cc: See next page

<u>DISTRIBUTION</u>	<u>Docket File</u>	<u>NRC & Local PDRs</u>	<u>PD33 R/F</u>	<u>PD33 Gray</u>
BBoger	JZwolinski	PKreutzer	RSamworth	DRP, R-III
ACRS(10)	UPotapovus	EJordan	JStone	PGill
				OGC

DOCUMENT NAME: 71388/71339 - BUL 88-10

LA/PDIII-3	PM/PDIII-3	PD/PDIII-3
PKreutzer	RSamworth:rc	JHannon
1/8/90	1/8/90	1/9/90

2501

9101170048 910109
PDR ADDCK 05000266
PDR

Docket No. 50-266
and 50-301

January 9, 1991

Mr. C. W. Fay, Vice President
Nuclear Power Department
Wisconsin Electric Power Company
231 W. Michigan Street, Room 308
Milwaukee, Wisconsin 53201

Dear Mr. Fay:

SUBJECT: WISCONSIN ELECTRIC POWER COMPANY CONFIRMATION OF ITS RESPONSE TO
NRC BULLETIN 88-10 AND SUPPLEMENT 1 TO BULLETIN 88-10
(TAC NOS. 71338 AND 71339)

By letters dated March 30, 1989 (NRC-89-038), June 13, 1989 (NRC-89-070), November 6, 1989 (NRC-89-138), May 16, 1990 (Accession No. 9005240119), and November 5, 1990 (NRC-90-109), Wisconsin Electric Power Company responded to Bulletin 88-10 and Supplement 1 to Bulletin 88-10. In these responses, you identified actions taken in response to the bulletin and confirmed that most activities required to address the issue of substandard molded case circuit breakers discussed in Bulletin 88-10 have been performed. The November 5, 1990 letter advised us of difficulties you are having in obtaining replacements for the untraceable circuit breakers in inverters 1DY03, 2DY03, DY0C, 1DY04, 2DY04 and DY0D. You further advised that you are taking steps to replace these breakers in 1991. Replacement of these breakers will constitute full implementation of your actions in regard to the bulletin.

A detailed technical review of your responses has not been performed; however, the area may be subject to inspection at a later date. If a subsequent inspection identifies deficiencies in your actions or responses, this issue will be reopened. Presently we consider this action complete.

By copy of this memorandum, Region III is advised of your position on this matter.

Sincerely,

Original Signed By:

Robert B. Samworth, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects - III,
IV and V
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION	Docket File	NRC & Local PDRs	PD33 R/F	PD33 Gray
BBoger	JZwolinski	PKreutzer	RSamworth	DRP, R-III
ACRS(10)	UPotapovus	EJordan	JStone	PG111 OGC

DOCUMENT NAME: 71388/71339 - BUL 88-10

LA/PDIII-3	PM/PDIII-3	PD/PDIII-3
PKreutzer	RSamworth:rc	JHannon
1/8/90	1/8/90	1/2/90

Mr. C. W. Fay
Wisconsin Electric Power Company

Point Beach Nuclear Plant
Unit Nos. 1 and 2

cc:

Ernest L. Blake, Jr.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, DC 20037

Mr. Gregory J. Maxfield, Manager
Point Beach Nuclear Plant
Wisconsin Electric Power Company
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Chairman
Public Service Commission
of Wisconsin
Hills Farms State Office Building
Madison, Wisconsin 53702

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
6612 Nuclear Road
Two Rivers, Wisconsin 54241