



PERRY NUCLEAR POWER PLANT
10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Michael D. Lyster
Vice President - Nuclear

January 15, 1991
PY-CEI/NRR-1289 L

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Monthly Operating Report

Dear Sir:

Attached is the December 1990 Monthly Operating Report for Perry Unit 1. This report is submitted in accordance with Technical Specification 6.9.1.8.

If there are any questions, please feel free to call.

Sincerely,

Michael D. Lyster

MDL:DWC:njc

Attachment

cc: NRR Project Manager
USNRC Senior Resident Inspector - Perry
USNRC, Region III
Director, Office of Resource Management

9101230206 901231
PDR ADOCK 05000440
R PDR

230050
Operating Units
Cleveland Electric Illuminating
Toledo Edison

IF2A
11

CLEVELAND ELECTRIC ILLUMINATING COMPANY

PERRY NUCLEAR POWER PLANT

December 1, 1990 - December 31, 1990

MONTHLY OPERATING REPORT TO NRC

DOCKET NUMBER : 50-440

LICENSE NUMBER: NPF-58

Table of Contents

Average Daily Unit Power Level	1
Operating Data Report	2
Unit Shutdowns and Power Reductions	3

Average Daily Unit Power Level

DOCKET NO. 50-440
UNIT Perry-1
DATE 1/15/91
Contact H.L. Hegrat
Telephone (216)259-3737

MONTH December 1990

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1	<u>0</u>	17	<u>0</u>
2	<u>0</u>	18	<u>0</u>
3	<u>0</u>	19	<u>0</u>
4	<u>0</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>	29	<u>0</u>
14	<u>0</u>	30	<u>0</u>
15	<u>0</u>	31	<u>0</u>
16	<u>0</u>		

Operating Data Report

UNIT: PERRY-1
DATE: 1/15/91

OPERATING STATUS

1. Docket: 50-440
2. Reporting Period: December 1990
3. Utility Contact: H.L. Hegrat (216) 259-3737
4. Licensed Thermal Power (MWt): 3579
5. Nameplate Rating (Gross MWe): 1250
6. Design Electrical Rating (Net MWe): 1191
7. Maximum Dependable Capacity (Gross MWe): 1200
8. Maximum Dependable Capacity (Net MWe): 1141
9. If changes occur in capacity ratings (Item Numbers 4 through 8) since last report, give reasons:
N/A
10. Power Level To Which Restricted, If Any (Net MWe): 100%
11. Reasons for Restrictions, If Any: Operating License Limit

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
--	-------------------	-------------------	-------------------

None

27. If Shut Down at end of Report Period, Estimated Date of Startup:
Reactor startup was commenced on December 27, 1990;
Generator synchronization was performed on January 4, 1991.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH December 1990

DOCKET NO. 50-440
 UNIT NAME Perry-1
 DATE 1/15/91
 CONTACT H.L. Hegrat
 TELEPHONE 216-259-3737

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
90-09	09-07-90	S	744	C	4	N/A	N/A	N/A	Refueling outage, continued from previous month.

SUMMARY: During December 1990, Perry-1 remained in the final stages of the second refueling outage. Reactor startup commenced on December 27, 1990, and the generator was synchronized to the grid on January 4, 1991.

¹ F: Forced
 S: Scheduled

² Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³ Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continued
 5-Reduced Load
 9-Other

⁴ Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG 1022)

⁵ Exhibit I-Same Source