



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

December 1, 1982

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Inoperable Fire Dams and  
Penetration Seals  
LER 82-126/99 L-0  
AECM-82/576

In the process of repairing cables in the control room on October 26, 1982, several fire dams and penetration seals were broken. This report is being submitted pursuant to Technical Specification 3.7.7.a. Attached is LER 82-126/99 L-0. An updated report will be submitted by February 2, 1983.

Yours truly,

*J.P. McGaughy, Jr.*  
FOR J.P. McGaughy, Jr.

JPM:sap  
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8212090326 821201  
PDR ADOCK 05000416  
S PDR

NOV 19 1982  
OFFICE 3  
A.G. 50  
NRC REGION II

OFFICIAL COPY  
IE 22