

NOV 12 1982

Alabama Power Company
ATTN: Mr. R. P. McDonald
Vice President-Nuclear Generation
P. O. Box 2641
Birmingham, AL 35291

Gentlemen:

Subject: Confirmation of Meeting Arrangement

This confirms the telephone conversation between you and Mr. D. M. Verrelli of my staff on November 8, 1982 concerning an enforcement conference to be conducted at 10:00 a.m. in our Atlanta office on November 19, 1982. We requested this meeting to discuss the circumstances relating to both containment spray systems being found inoperable at Farley 2. A proposed meeting agenda is enclosed.

Should you have any questions regarding these arrangements we will be pleased to discuss them.

James P. O'Reilly
Regional Administrator

Enclosure: Meeting Agenda

cc/w encl:

- W. O. Whitt, Executive Vice President
- F. L. Clayton, Jr., Senior Vice President
- H. O. Thrash, General Manager-Nuclear Generation
- O. D. Kingsley, Jr., Manager, Nuclear Engineering and Technical Services
- J. W. McGowan, Manager-Safety Audit and Engineering Review
- W. G. Ware, Supervisor-Safety Audit and Engineering Review
- W. G. Hairston, III, Plant Manager

bcc w/encl:

NRC Resident Inspector
Document Management Branch
State of Alabama

RII <i>RB</i>	RII <i>jsc</i>	RII <i>DMV</i>	RII <i>RCL</i>	RII <i>JOS</i>	RII <i>CEA</i>
RCButcher:gr	FSCantrell	DMVerrelli	RCLewis	JOShinski	CEAlderson
11/10/82	11/10/82	11/10/82	11/10/82	11/10/82	11/12/82

~~RII
RDMartin
11/10/82~~ *CA*

8212090435 821112
PDR ADDOCK 05000364
Q PDR

IE34

ENCLOSURE

PROPOSED AGENDA

Alabama Power Company Meeting with NRC
November 19, 1982 at 10:00 a.m.

- | | | |
|------|---|-----------------------|
| I. | Opening Remarks | James P. O'Reilly |
| II. | NRC concerns relating to both containment spray systems being inoperable | R. C. Lewis |
| III. | Discussion - Investigation of circumstances of the inoperable containment spray systems | Alabama Power Company |
| IV. | Discussion of a loose part in one steam generator | Alabama Power Company |
| V. | Closing Remarks | James P. O'Reilly |