

APPENDIX A
NOTICE OF VIOLATION

Florida Power & Light
St. Lucie 1

Docket No. 50-335
License No. DPR-67

As a result of the inspection conducted on May 27 - June 10, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified.

Technical Specification 3.0.4 requires that entry into an operational mode shall not be made unless the conditions of the limiting condition for operation (LCO) are met without reliance on provisions contained in the action statement unless otherwise excepted.

Contrary to the above, on May 24, 1982, the plant entered mode 2 from mode 3 without the conditions of LCO 3.6.6.2 being met. Shield building integrity was not being maintained due to a door that was tied open and the plant was in a 24 hour action statement under LCO 3.6.6.2.

This is a Severity Level IV Violation (Supplement I.).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Date: AUG 05 1982