

APPENDIX A  
NOTICE OF VIOLATION

Florida Power & Light  
St. Lucie 1

Docket No. 50-335  
License No. DPR-67

As a result of the inspection conducted on August 11 - September 10, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified.

Technical Specification 6.8.1 requires that written procedures shall be implemented. Administrative Procedure 0010123, Administrative Control of Valves, Locks and Switches, specifies that certain valves important to safety shall be locked in their proper position. Additionally, Operating Procedure 0010122, Revision 15, In-plant Equipment Clearance Orders, requires that when issuing or releasing a clearance the Watch Engineer shall insure that applicable valves, locks and switches under administrative control are properly denoted on the order and that equipment under administrative control shall be listed as locked open or locked closed (L. Open or L. Closed).

Contrary to the above, completed equipment clearances for August and early September 1982 included eight clearances which contained safety-related valves, identified in AP-0010123, that had not been specified as "locked open or locked closed" upon release of the clearance. This is a repeat of violation 50-335/82-15-01

This is a Severity Level V Violation (Supplement I.).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

OCT 05 1982

Date: \_\_\_\_\_