



Commonwealth Edison
1400 Opus Place
Winners Grove, Illinois 60515

January 25, 1991

Dr. Thomas E. Murley, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attn: Document Control Desk

Subject: Quad Cities Nuclear Power Station Units 1 and 2
Supplement to Application for Amendment to
Facility Operating Licenses DPR-29 and DPR-30
Appendix A, Technical Specifications
NRC Docket Nos. 50-254 and 50-265

Reference: R. Stols to T.E. Murley letter dated May 25, 1989

Dr. Murley:

The reference letter transmitted a proposed amendment to Appendix A, Technical Specifications to Facility Operating Licenses DPR-29 and DPR-30. The proposed amendment revises the requirements associated with the High Pressure Coolant Injection (HPCI) and Reactor Core Isolation Cooling (RCIC) Systems.

Through discussions with the NRR Project Manager for Quad Cities Station, it was determined that an additional surveillance requirement should be added to the proposed amendment. The new surveillance requires the venting of the HPCI and RCIC systems discharge piping at a frequency of once per month to prevent water hammer in the systems. This surveillance requirement is consistent with the Standard Technical Specification.

Attachment A provides a summary of the changes to the Technical Specification and Attachment B provides a copy of the marked-up changes. The additional change is within the scope of the No Significant Hazards Consideration Evaluation, which was provided in the referenced letter.

The proposed amendment has been reviewed and approved by Commonwealth Edison's On-site and Off-site Reviews in accordance with Company procedures.


9102010089 910125
PDR ADDCK 05000254
P FDR

Aool
1/1

January 25, 1991

Commonwealth Edison is notifying the State of Illinois of the supplement to the referenced application by transmitting a copy of this letter and its attachments to the designated State officials.

Very truly yours,



R. Stols
Nuclear Licensing Administrator

Attachments: A) Summary of Changes
B) Marked-up Technical Specification Pages

cc: A.B. Davis, Administrator - Region III
L.N. Olshan, Project Manager - NRR
T. Taylor, Senior Resident Inspector
Illinois Department of Nuclear Safety

RS:lmw
ZNLD702/111

ATTACHMENT A

SUMMARY OF CHANGES

Page 3.5/4.5-10 (DPR-29)
3.5/4.5-7 (DPR-30)

Specification 4.5.G.1 should now read:

"Every month, the LPCI Mode of RHR, core spray ECCS, HPCI and RCIC discharge piping shall be vented from the high point and water flow observed."