

Docket No. 50-336
B14889

Attachment 1

Millstone Nuclear Power Station, Unit No. 2
Proposed Revision to Technical Specifications
Administrative Controls - Section 6
Marked Up Pages

June 1994

9407010205 940624
PDR ADOCK 05000336
P PDR

ADMINISTRATIVE CONTROLS

FACILITY STAFF (CONTINUED)

- d. An individual qualified in radiation protection procedures shall be on site when fuel is in the reactor. (Table 6.2-1)
- e. ALL CORE ALTERATIONS after the initial fuel loading shall be directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.
- f. A site Fire Brigade of at least 5 members shall be maintained onsite at all times. (Table 6.2-1) The Fire Brigade shall not include 2 members of the minimum shift crew necessary for safe shutdown of the unit or any personnel required for other essential functions during a fire emergency.
- g. Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety-related functions. These procedures should follow the general guidance of the NRC Policy Statement on working hours (Generic Letter No. 82-12).

6.3 FACILITY STAFF QUALIFICATIONS

6.3.1 Each member of the facility staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for: *Move to page 6-3*

C a. The Health Physics Manager who shall meet or exceed the qualifications of Regulatory Guide 1.8, Revision 1.

b. The Shift Technical Advisor (STA) who shall meet the requirements of Specification 6.3.1.b.1 or 6.3.1.b.2.

INSERT A

- 1. Dual-role individual: Must hold a senior reactor operator's license at Millstone Unit No. 2, meet the STA training criteria of NUREG-0737, Item I.A.1.1, and meet one of the following educational alternatives:
 - a. Bachelor's degree in engineering from an accredited institution;
 - b. Professional Engineer's license obtained by the successful completion of the PE examination;
 - c. Bachelor's degree in engineering technology from an accredited institution, including course work in the physical, mathematical, or engineering sciences;
 - d. Bachelor's degree in a physical science from an accredited institution, including course work in the physical, mathematical, or engineering sciences;

ADMINISTRATIVE CONTROLS

- e. Successful completion of the Memphis State University (MSU) STA program. (Note: This alternative is only acceptable for individuals who have completed the program prior to December 31, 1986); or
 - f. Successful completion of the Thames Valley State Technical College associate's degree in Nuclear Engineering Technology program, provided that the individual was enrolled in the program by October 1, 1987.
2. Dedicated STA: Must meet the STA training criteria of NUREG-0737, Item I.A.1.1, and have received specific training in plant design, and response and analysis of the plant for transients and accidents.

C. INSERT Statement from page 6-2

INSERT A

- a. If the Operations Manager does not hold a senior reactor operator license for Millstone Unit No. 2, then the Operations Manager shall have held a senior reactor operator license at a Pressurized Water Reactor other than Millstone Unit No. 2 and an individual serving in the capacity of the Assistant Operations Manager shall hold a senior reactor operator license for Millstone Unit No. 2.

Docket No. 50-336
B14889

Attachment 2

Millstone Nuclear Power Station, Unit No. 2
Proposed Revision to Technical Specifications
Administrative Controls - Section 6
Retyped Pages

June 1994

ADMINISTRATIVE CONTROLS

FACILITY STAFF (CONTINUED)

- d. An individual qualified in radiation protection procedures shall be on site when fuel is in the reactor. (Table 6.2-1)
- e. ALL CORE ALTERATIONS after the initial fuel loading shall be directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.
- f. A site Fire Brigade of at least 5 members shall be maintained onsite at all times. (Table 6.2-1) The Fire Brigade shall not include 2 members of the minimum shift crew necessary for safe shutdown of the unit or any personnel required for other essential functions during a fire emergency.
- g. Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety-related functions. These procedures should follow the general guidance of the NRC Policy Statement on working hours (Generic Letter No. 82-12).

6.3 FACILITY STAFF QUALIFICATIONS

- 6.3.1 Each member of the facility staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for:
- a. If the Operations Manager does not hold a senior reactor operator license for Millstone Unit No. 2, then the Operations Manager shall have held a senior reactor operator license at a Pressurized Water Reactor other than Millstone Unit No. 2 and an individual serving in the capacity of the Assistant Operations Manager shall hold a senior reactor operator license for Millstone Unit No. 2.
 - b. The Shift Technical Advisor (STA) who shall meet the requirements of Specification 6.3.1.b.1 or 6.3.1.b.2.
 - 1. Dual-role individual: Must hold a senior reactor operator's license at Millstone Unit No. 2, meet the STA training criteria of NUREG-0737, Item I.A.1.1, and meet one of the following educational alternatives:
 - a. Bachelor's degree in engineering from an accredited institution;
 - b. Professional Engineer's license obtained by the successful completion of the PE examination;

ADMINISTRATIVE CONTROLS

- c. Bachelor's degree in engineering technology from an accredited institution, including course work in the physical, mathematical, or engineering sciences;
 - d. Bachelor's degree in a physical science from an accredited institution, including course work in the physical, mathematical, or engineering sciences;
 - e. Successful completion of the Memphis State University (MSU) STA program. (Note: This alternative is only acceptable for individuals who have completed the program prior to December 31, 1986); or
 - f. Successful completion of the Thames Valley State Technical College associate's degree in Nuclear Engineering Technology program, provided that the individual was enrolled in the program by October 1, 1987.
2. Dedicated STA: Must meet the STA training criteria of NUREG-0737, Item I.A.1.1, and have received specific training in plant design, and response and analysis of the plant for transients and accidents.
- c. The Health Physics Manager who shall meet or exceed the qualifications of Regulatory Guide 1.8, Revision 1.