

DCS

June 27, 1994  
EN 94-076

OFFICE OF ENFORCEMENT  
NOTIFICATION OF SIGNIFICANT ENFORCEMENT ACTION

Licensee: BALTIMORE GAS AND ELECTRIC COMPANY (EA 94-060)  
(Calvert Cliffs)  
Docket No. 50-317, 50-318

Subject: EXERCISE OF ENFORCEMENT DISCRETION

This is to inform the Commission that, in a Notice of Violation being issued on or about July 1, 1994 to Baltimore Gas and Electric Company concerning violations identified in the plant security program, there is reference to a violation of a plant Technical Specification (TS) for which the staff has determined that it would be appropriate to exercise enforcement discretion and not issue an enforcement action. The violation of the plant TS involved the removal of a missile barrier door for 15 days in the emergency diesel generator room without declaring all three emergency diesel generators inoperable. In accordance with section VII.B.(6) of the Enforcement Policy, the staff is hereby notifying the Commission of its determination to exercise enforcement discretion with respect to that violation.

It should be noted that the licensee has not been specifically informed of the enforcement action. The schedule of issuance and notification is:

Mailing of Notice	July 1, 1994
Telephone Notification of Licensee	July 1, 1994

The licensee has thirty days from the date of the Notice in which to respond. Following NRC evaluation of the response, the civil penalty may be remitted, mitigated, or imposed by Order.

Contacts: D. Rosano, OE, 504-3282      J. Lieberman, OE, 504-2741

Distribution

OWFN <u>1:30</u>	OWFN <u>1:30</u>	TWFN <u>1:30</u>	Regional Offices
Chairman Selin	EDO	OC	RI <u>1:30</u> RIV <u>1:30</u>
Comm. Rogers	DEDR	AEOD	RII <u>1:30</u> WCFO <u>1:30</u>
Comm. Remick	DEDS	OP CTR	RIII <u>1:30</u>
Comm. de P' <u>3:30</u>	OC	NMSS	
GPA	OGC	IRM	<u>MAIL</u>
SECY	NRR	OIG	DCS
OCA	OI	RES	PDR
	SP	ACRS	

PRELIMINARY INFORMATION - NOT FOR PUBLIC DISCLOSURE UNTIL  
VERIFICATION THAT LICENSEE HAS RECEIVED ACTION

0/1  
1E:33