

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. B. PAY

STATION MANAGER

November 30, 1982

RECEIVED
NRC

1982 DEC -2 AM 10:57
SCE

REGION V IRE
TELEPHONE
(714) 492-7700

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361/50-362
Prompt Report
Licensee Event Report No. 82-142 (Docket No. 50-361)
Licensee Event Report No. 82-001 (Docket No. 50-362)
San Onofre Nuclear Generating Station Units 2 and 3

Pursuant to Technical Specification 6.9.1.12b of Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively, this letter confirms our November 29, 1982 prompt notification to the NRC of a reportable occurrence involving Limiting Condition for Operations (LCO's) 3.7.5 and 3.0.3 on both Units 2 and 3. This confirmation letter is dispatched a day later than the "first working day following the event" requirement of Technical Specification 6.9.1.12 as was approved by Mr. D.F. Kirsch of your office in a telephone conversation on November 29, 1982.

On November 24, 1982, while Unit 2 was in Mode 3 and Unit 3 was in Mode 6, CREACUS Train A was declared inoperable due to charcoal filter replacement on cooling unit E-418. The Action Statement associated with LCO 3.7.5 allows operations to continue for seven days before requiring that the train be restored operable.

On November 28, 1982 at 1230 while Unit 2 was in Mode 3, and Unit 3 was in Mode 6, Emergency Chiller E-335 was declared inoperable due to a high Motor Winding Temperature trip. This rendered CREACUS Train B inoperable thus exceeding the limits of LCO 3.7.5. Technical Specification LCO 3.0.3 became governing for both units, allowing one hour before a Unit 2 shutdown/cooldown was required.

8212140035 821130
PDR ADOCK 05000361
S PDR

IE-28
82-438


November 30, 1982

Cooldown of Unit 2 was initiated promptly and efforts to restore chiller E-335 continued. At 1700 on November 28, 1982, chiller E-335 was declared operable and LCO 3.0.3 satisfied.

14-day Reports and LER 82-142 and LER 82-001 for Units 2 and 3, respectively, will be provided by December 13, 1982, to complete our reporting requirements, and to describe the cause and corrective measures taken.

If there are any questions, please contact me.

Sincerely,

A handwritten signature in cursive script, appearing to read 'R. H. Engelken', written in dark ink.

cc: A. E. Chaffee (USNRC Resident Inspector, San Onofre Unit 2/3)