

Iowa Electric Light and Power Company

November 17, 1982

DAEC-82-881

Director, Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

RE: Duane Arnold Energy Center

SUBJECT: Semiannual Operating Report for the  
Duane Arnold Energy Center, Unit No.  
1, January 1, 1979 through June 30,  
1979

FILE: NRC-7

Dear Sir:

An error has been discovered in the Semiannual Report for the Duane Arnold Energy Center, Unit No. 1, for the period January 1, 1979 through June 30, 1979. The error is in the value reported for Sr-89 and Sr-90 for liquid effluents for the first quarter page 4. The error, which was discovered by an NRC Consultant, was caused by a conversion error. When the Sr-89 and Sr-90 values were calculated, the conversion from disintegrations to microcuries was omitted. The value reported for Sr-89 and Sr-90 for the first quarter, is  $<5.62 \text{ E } 0$  curies. The correct value for Sr-89 and Sr-90 is  $<2.53 \text{ E-6}$  curies.

*BR York for*

Daniel L. Mineck  
Plant Superintendent-Nuclear  
Duane Arnold Energy Center

DLM/KDY/gr

cc: L. Root

R. McGaughy

8212140134 821117  
PDR ADOCK 05000331  
R PDR

Duane Arnold Energy Center • P.O. Box 351 • Cedar Rapids, Iowa 52406 • 319/851-5611

JE24