ATTACHMENT 2

PROPOSED TECHNICAL
SPECIFICATION 3.3.3.1, TABLE 3.3-6,
FUNCTIONAL UNIT 1.a

A1/009.N20
9102280207 910222
PDR ADOCK 05000498
P PDR

ACTION STATEMENTS

ACTION 31 - With less than the Minimum Channels OPERABLE requirement, operation may continue for up to 30 days provided grab samples of the containment atmosphere are obtained and analyzed at least once per 24 hours.*

ACTION 32 - (Not Used)

ACTION 33 - (Not Used)

ACTION 34 - Must satisfy the ACTION requirement for Specification 3.4.6.1.

* Grab samples are not required to be obtained for the duration of containment pressurization for an Integrated Leak Rate Test (ILRT) provided that a grab sample is obtained and analyzed at the start of depressurization of containment following the ILRT.