

BEFORE THE

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of	:	
	:	Docket Nos. 50-277
PHILADELPHIA ELECTRIC COMPANY	:	50-278

AMENDMENT TO
MARCH 24, 1981 and AUGUST 6, 1981
APPLICATION FOR AMENDMENT
OF
FACILITY OPERATING LICENSES
DPR-44 & DPR-56

Edward G. Bauer, Jr.
Eugene J. Bradley

2301 Market Street
Philadelphia, Pennsylvania 19101

Attorneys for
Philadelphia Electric Company

BEFORE THE
UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of	:	
	:	Docket Nos. 50-277
PHILADELPHIA ELECTRIC COMPANY	:	50-278

AMENDMENT TO
MARCH 24, 1981 and AUGUST 6, 1981
APPLICATION FOR AMENDMENT
OF
FACILITY OPERATING LICENSES
DPR-44 & DPR-56

On March 24, 1981, Philadelphia Electric Company, Licensee under Facility Operating License DPR-44 and DPR-56 for Peach Bottom Units 2 and 3, filed an Application for Amendment of the Licenses which requested that Table 3.11.D.1, titled "Safety Related Shock Suppressors", of the Technical Specifications

contained in Appendix A of the Operating Licenses be amended to conform with the Standard Technical Specifications as required by Mr. D. G. Eisenhower's letter dated November 20, 1980.

Subsequently, licensee revised its application of March 24, 1981, by Amendment dated August 6, 1981 to reflect shock suppressor modifications.

Licensee has recently installed additional shock suppressors on the main steam relief valve discharge pipes to bring the pipe support design into conformance with the requirements of NUREG 0661, Safety Evaluation Report, Mark I Containment, Long Term Program. The modification involves the installation of sixteen new mechanical snubbers to the main steam relief valve discharge piping.

Accordingly, the licensee hereby amends its application of March 24, 1981, as amended August 6, 1981, by revising Table 3.11.D.1 for Unit 2 (revised pages 234r, and 234s) in accordance with the provisions of section 3.11.D.5 of the Peach Bottom Technical Specifications to reflect the installation of additional shock suppressors.

The proposed revisions to pages 234m (Units 2 and 3), 234o (Unit 2), and 234p (Unit 3), correct typographical errors in the designation numbers for shock suppressors (snubbers) listed in Table 3.11.D.1.

The Plant Operation Review Committee and the Operation and Safety Review Committee have reviewed these proposed changes to the Technical Specifications, and have concluded that they do not involve an unreviewed safety question or a significant hazard consideration and will not endanger the health and safety of the public.

Respectfully submitted,

PHILADELPHIA ELECTRIC COMPANY

By

A handwritten signature in dark ink, appearing to read "A. H. Kelly", is written over a horizontal line.

Vice President

COMMONWEALTH OF PENNSYLVANIA

:

COUNTY OF PHILADELPHIA


:

SS.


:

S. L. Daltroff, being first duly sworn, deposes and says:

That he is Vice President of Philadelphia Electric Company, the Applicant herein; that he has read the foregoing Application for Amendment of Facility Operating Licenses and knows the contents thereof; and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.



Subscribed and sworn to
before me this 10th day
of December 1982.




Notary Public

PATRICIA D. SCHOLL
Notary Public, Philadelphia, Philadelphia Co.
My Commission Expires February 10, 1986

CERTIFICATE OF SERVICE

I certify that service of the foregoing Application was made upon the Board of Supervisors, Peach Bottom Township, York County, Pennsylvania, by mailing a copy thereof, via first-class mail, to Albert R. Steele, Chairman of the Board of Supervisors, R.D. No. 1, Delta, Pennsylvania 17314; upon the Board of Supervisors, Fulton Township, Lancaster County, Pennsylvania, by mailing a copy thereof, via first-class mail, to George K. Brinton, Chairman of the Board of Supervisors, Peach Bottom, Pennsylvania 17563; and upon the Board of Supervisors, Drumore Township, Lancaster County, Pennsylvania, by mailing a copy thereof, via first-class mail, to Wilmer P. Bolton, Chairman of the Board of Supervisors, R.D. No. 1, Holtwood, Pennsylvania 17532; all this 13th day of December 1982.



Eugene J. Bradley

Attorney for
Philadelphia Electric Company

TABLE 3.11.D.1
Safety Related Shock Suppressors (Snubbers)

SNUBBER NUMBER	LOCATION	SYSTEM AND	ELEVATION	HIGH (1) RADIATION AREA DURING SHUTDOWN	ESPECIALLY (1) DIFFICULT TO REMOVE	INACCESSIBLE (1) DURING NORMAL OPERATION	TYPE (2)
				See 4.11.D.4.b.			
6-DDNL-S-12	Feedwater	Drywell	155	"	Y	Y	H
6-DDNL-S-13	Feedwater	Drywell	155	"	Y	Y	H
6-DDNL-S-14	Feedwater	Drywell	155	"	Y	Y	H
9-HB-H51	Torus	Vac. Bkr.	116	"	N	N	M
9-HB-H54	Torus	Vac. Bkr.	116	"	N	N	M
10-HB-S-1	RHR	Torus Room	93	"	N	N	H
10-HB-S-2	RHR	Torus Room	93	"	N	N	H
10-HB-S-7	RHR	B RHR Room	124	"	N	N	H
10-HB-S-8	RHR	Torus Room	93	"	N	N	H
10-GB-S-12	RHR	C RHR Room	98	"	N	N	H
10-GB-S-43-1	RHR	Torus Room	130	"	Y	N	H
10-GB-S-43-2	RHR	Torus Room	130	"	Y	N	H
10-GB-S-44	RHR	Torus Room	128	"	Y	N	H
10-GB-S-48	RHR	B RHR Room	124	"	N	N	H
10-GB-S-49	RHR	B RHR Room	124	"	N	N	H
10-GB-S-50	RHR	B RHR Room	98	"	N	N	H
10-GB-S-51	RHR	C RHR Room	98	"	N	N	H

TABLE 3.11.D.1
Safety Related Shock Suppressors (Snubbers)

SNUBBER NUMBER	LOCATION	SYSTEM AND	ELEVATION	HIGH (1) RADIATION AREA DURING SHUTDOWN	ESPECIALLY (1) DIFFICULT TO REMOVE	INACCESSIBLE (1) DURING NORMAL OPERATION	TYPE (2)
				See 4.11.D.4.b.			
12-DCN-S-2	RWCU	Iso. Valve Rm	173.5	"	Y	N	H
12-DCN-S-5	RWCU	Drywell	165	"	Y	Y	H
12-DCN-S-7	RWCU	Drywell	165	"	Y	Y	H
12-DCN-S-8A	RWCU	Drywell	165	"	N	Y	M
14-DCN-S-23	Core Spray	Drywell	168	"	Y	Y	H
14-DCN-S-24	Core Spray	Drywell	168	"	Y	Y	H
14-DCN-S-26	Core Spray	Drywell	168	"	Y	Y	H
14-DCN-S-27	Core Spray	Drywell	168	"	Y	Y	H
13-HB-S-1	RCIC	RCIC Room	107	"	Y	N	H
13-DDN-S-13	RCIC	RCIC ROOM	96	"	N	N	H
13-HB-S-14	RCIC	RCIC Room	102	"	Y	N	H
13-DBN-S-15	RCIC	RCIC Room	107	"	Y	N	H
13-DBN-S-16	RCIC	Torus Room	140	"	Y	N	H
23-DBN-S-1	HPCI	HPCI Room	112	"	Y	Y	H
23-DBN-S-2	HPCI	HPCI Room	112	"	Y	N	H

TABLE 3.11.D.1
Safety Related Shock Suppressors (Snubbers)

SNUBBER NUMBER	LOCATION	SYSTEM AND ELEVATION	HIGH (1) RADIATION AREA DURING SHUTDOWN	ESPECIALLY (1) DIFFICULT TO REMOVE	INACCESSIBLE (1) DURING NORMAL OPERATION	TYPE (2)
			See 4.11 D.4.b.			
1-GG-S-108-B	MSRV	Drywell 145	"	Y	Y	M
1-GG-S-109-A	MSRV	Drywell 145	"	Y	Y	M
1-GG-S-109-B	MSRV	Drywell 145	"	Y	Y	M
1-GG-S-110-A	MSRV	Drywell 145	"	Y	Y	M
1-GG-S-110-B	MSRV	Drywell 145	"	Y	Y	M
1-GG-S-111-A	MSRV	Drywell 145	"	Y	Y	M
1-GG-S-111-B	MSRV	Drywell 145	"	Y	Y	M
1-GG-S-112-A	MSRV	Drywell 145	"	Y	Y	M
1-GG-S-112-B	MSRV	Drywell 145	"	Y	Y	M
1-GG-S201	MSRV	Drywell 160	"	Y	Y	M
1-GG-S202	MSRV	Drywell 160	"	Y	Y	M
1-GG-S203-A	MSRV	Drywell 160	"	Y	Y	M
1-GG-S203-B	MSRV	Drywell 160	"	Y	Y	M
1-GG-S204-A	MSRV	Drywell 130	"	Y	Y	M
1-GG-S204-B	MSRV	Drywell 130	"	Y	Y	M
1-GG-S205-A	MSRV	Drywell 160	"	Y	Y	M
1-GG-S205-B	MSRV	Drywell 160	"	Y	Y	M
1-GG-S206-A	MSRV	Drywell 160	"	Y	Y	M

TABLE 3.11.D.1
Safety Related Shock Suppressors (Snubbers)

SNUBBER NUMBER	LOCATION	SYSTEM AND ELEVATION	HIGH (1) RADIATION AREA DURING SHUTDOWN	ESPECIALLY (1) DIFFICULT TO REMOVE	INACCESSIBLE (1) DURING NORMAL OPERATION	TYPE (2)
See 4.11.D.4.b.						
1-GG-S206-B	MSRV	Drywell 160	"	Y	Y	M
1-GG-S207-A	MSRV	Drywell 125	"	Y	Y	M
1-GG-S207-B	MSRV	Drywell 125	"	Y	Y	M
1-GG-S208-A	MSRV	Drywell 125	"	Y	Y	M
1-GG-S208-B	MSRV	Drywell 125	"	Y	Y	M
1-GG-S209-A	MSRV	Drywell 125	"	Y	Y	M
1-GG-S209-B	MSRV	Drywell 125	"	Y	Y	M

Notes for Table 3.11.D.1

1) Yes (Y) or No (N)

2) Hydraulic (H) or Mechanical (M)

TABLE 3.11.D.1
Safety Related Shock Suppressors (Snubbers)

SNUBBER NUMBER	LOCATION	SYSTEM AND	ELEVATION	HIGH (1) RADIATION AREA DURING SHUTDOWN	ESPECIALLY (1) DIFFICULT TO REMOVE	INACCESSIBLE (1) DURING NORMAL OPERATION	TYPE (2)
				See 4.11.D.4.b.			
6-DDNL-S-8	Feedwater	Drywell	168	"	Y	Y	H
6-DDNL-S-9	Feedwater	Drywell	168	"	Y	Y	H
6-DDNL-S-10	Feedwater	Drywell	168	"	Y	Y	H
6-DDNL-S-11	Feedwater	Drywell	155	"	Y	Y	H
6-DDNL-S-12	Feedwater	Drywell	155	"	Y	Y	H
6-DDNL-S-13	Feedwater	Drywell	155	"	Y	Y	H
6-DDNL-S-14	Feedwater	Drywell	155	"	Y	Y	H
9-HB-H51	Torus	Vac. Bkr.	116	"	N	N	M
9-HB-H53	Torus	Vac. Bkr.	116	"	N	N	M
10-HB-S-1	RHR	Torus Room	93	"	N	N	M
10-HB-S-2	RHR	Torus Room	93	"	N	N	H
10-HB-S-7	RHR	B RHR Room	124	"	N	N	H
10-HB-S-8	RHR	Torus Room	93	"	N	N	H
10-GB-S-12	RHR	C RHR Room	98	"	Y	N	H
10-GB-S-43-1	RHR	Torus Room	130	"	Y	N	H
10-GB-S-43-2	RHR	Torus Room	130	"	Y	N	H
10-GB-S-44	RHR	Torus Room	128	"	Y	N	M

TABLE 3.11.D.1
Safety Related Shock Suppressors (Snubbers)

SNUBBER NUMBER	LOCATION	SYSTEM AND ELEVATION	HIGH (1) RADIATION AREA DURING SHUTDOWN	ESPECIALLY (1) DIFFICULT TO REMOVE	INACCESSIBLE (1) DURING NORMAL OPERATION	TYPE (2)
			See 4.11.D.4.b.			
13-HB-S-23	RCIC	RCIC Room 103	"	Y	Y	H
23-DBN-S-1	HPCI	Torus Room 121	"	Y	Y	H
23-HB-S-1A	HPCI	HPCI Room 103	"	Y	Y	H
23-HB-S-2A	HPCI	HPCI Room 103	"	N	Y	E
23-HB-S-3A	HPCI	HPCI Room 100	"	Y	Y	H
23-DBN-S-6-1	HPCI	Torus Room 121	"	Y	N	H
23-DBN-S-6-2	HPCI	Torus Room 121	"	Y	N	H
23-DBN-S-22	HPCI	Drywell 155	"	Y	Y	H
23-DBN-S-23	HPCI	Drywell 155	"	Y	Y	H
23-DDN-S-29	HPCI	HPCI Room 117	"	N	N	H
23-DDN-S-33	HPCI	HPCI Room 93	"	N	N	H
23-DDN-S-47	HPCI	Torus Room 121	"	N	N	M
27-HCR-S-187	HPCI	B/D Core 127.5 Spray	"	N	N	M
27-HCR-S-188	HPCI	Torus Room 122.8	"	N	N	M