



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PORTLAND GENERAL ELECTRIC COMPANY

THE CITY OF EUGENE, OREGON

PACIFIC POWER AND LIGHT COMPANY

DOCKET NO. 50-344

TROJAN NUCLEAR PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 169
License No. NPF-1

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Portland General Electric Company, et al. (licensees) dated April 22, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-1 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 169, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



James E. Dyer, Director
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 27, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 169

TO FACILITY OPERATING LICENSE NO. NPF-1

DOCKET NO. 50-344

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

REMOVE

3/4 7-18

INSERT

3/4 7-18

PLANT SYSTEMS

3/4.7.6 CONTROL ROOM EMERGENCY VENTILATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.6.1 Two independent control room emergency ventilation systems shall be OPERABLE.

APPLICABILITY: ALL MODES.

ACTION:

MODES 1, 2, 3, and 4:

With one control room emergency ventilation system inoperable, restore the inoperable system to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

With both control room emergency ventilation systems inoperable [where inoperability is due solely to failure to maintain the control room at a positive pressure of $\geq 1/8$ inch WG relative to outside atmosphere or to adjacent spaces, but able to maintain the control room at a positive pressure of $\geq 1/16$ inch WG relative to outside atmosphere and adjacent spaces], restore at least one system to operable status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

MODES 5 and 6:

- a. With one control room emergency ventilation system inoperable, restore the inoperable system to OPERABLE status within 7 days or initiate and maintain operation of the remaining OPERABLE control room emergency ventilation system in the recirculation mode of operation.
- b. With both control room emergency ventilation systems inoperable, suspend all operations involving CORE ALTERATIONS or positive reactivity changes.
- c. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.7.6.1 Each control room emergency ventilation system shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by initiating flow through the HEPA filter and charcoal adsorber train and verifying that the train operates for at least 10 hours with the