

Carolina Power & Light Company  
PO Box 10429  
Southport, NC 28461

Roy A. Anderson  
Vice President  
Brunswick Nuclear Plant  
910 457-2137

JUL 11 1994

SERIAL: BSEP 94-0208

U. S. Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2  
DOCKET NOS. 50-325 & 50-324/LICENSE NOS. DPR-71 & DPR-62  
COMPLETION OF REQUESTED ACTIONS - NRC BULLETIN 88-04

Gentlemen:

This letter satisfies Requested Action 5 of NRC Bulletin 88-04 "Potential Safety-Related Pump Loss" for the Brunswick Nuclear Plant (BNP) which requested licensees to provide a written response to NRC describing the actions taken regarding completion of any long-term resolution actions identified as a result of the Bulletin.

On August 5, 1988 (Serial NLS-88-182), Carolina Power & Light Company (CP&L) submitted a response to NRC Bulletin 88-04 which addressed the actions requested by the Bulletin. In that letter, CP&L stated that "in order to best ensure that the applicable safety-related pumps are operated in the minimum flow mode for the least possible duration, applicable operating and test procedures will be revised incorporating precautionary statements to limit minimum flow operation to the least possible duration."

The appropriate BNP operating and test procedures were revised as indicated to incorporate these precautionary statements in response to the Bulletin. Carolina Power & Light Company has reviewed the requested actions of NRC Bulletin 88-04 and believes that submittal of this information completes the requested actions and satisfies the reporting requirements of the Bulletin for the BNP.


140000

9407140151 940711  
PDR ADOCK 05000324  
PDR

1537  
1/1

Please refer any questions regarding this submittal to Mr. R. P. Lopriore at  
(910) 457-2212.


Sincerely,

  
Roy A. Anderson

JCP/jcp (BNP94028.wpf)

Enclosure

Roy A. Anderson, having been first duly sworn, did depose and say that the information contained herein is true and correct to the best of his information, knowledge and belief; and the sources of his information are officers, employees, and agents of Carolina Power & Light Company.

  
Notary (Seal)

My commission expires: *August 12, 1996*

cc: Mr. S. D. Ebnetter, Regional Administrator, Region II  
Mr. P. D. Milano, NRR Senior Project Manager - Brunswick Units 1 and 2  
Mr. R. L. Prevatte, Brunswick NRC Senior Resident Inspector

Enclosure  
List of Regulatory Commitments

The following table identifies those actions committed to by Carolina Power & Light Company in this document. Any other actions discussed in the submittal represent intended or planned actions by Carolina Power & Light Company. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the Manager-Regulatory Affairs at the Brunswick Nuclear Plant of any questions regarding this document or any associated regulatory commitments.

Commitment	Committed date or outage
1. None	