



Donald C. Shelton
Vice President - Nuclear
Davis-Besse

300 Madison Avenue
Toledo, OH 43652-0001
(419) 249-2300

Docket Number 50-346

License Number NPF-3

Serial Number 1904

March 1, 1991

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: License Amendment Application to Revise Technical
Specification 4.7.7 (Snubbers Surveillance Requirements) and
Bases 3/4.7.7 (Snubbers)

Gentlemen:

Enclosed is an application for an amendment to the Davis-Besse Nuclear Power Station (DBNPS), Unit Number 1 Operating License Number NPF-3, Appendix A, Technical Specifications (TS) to reflect the change attached. The proposed changes involve TS 4.7.7 (Snubbers Surveillance Requirements) and TS Bases 3/4.7.7 (Snubbers).

This request proposes that TS 3/4.7.7 be revised in accordance with the guidance of Nuclear Regulatory Commission (NRC) Generic Letter (GL) 90-09, Alternative Requirements for Snubber Visual Inspection Intervals and Corrective Actions, dated December 11, 1990 (Toledo Edison letter Log Number 3376). The snubber visual inspection interval schedule of TS 4.7.7.1b would be replaced with the schedule recommended by NRC GL 90-09. Other revisions to the TS and Bases have been proposed to provide consistency between the current DBNPS TS and the revised visual inspection interval schedule. Toledo Edison requests that this amendment be issued by the NRC by August 1, 1991, for use during the DBNPS seventh refueling outage.

9103080253 910301
PDR ADOCK 05000346
P PDR

Operating Companies:
Cleveland Electric Illuminating
Toledo Edison


070072

A001
111

Docket Number 50-346
License Number NPF-3
Serial Number 1904
Page 2

If you have any questions regarding this amendment request, please contact
Mr. R. W. Schrauder, Manager - Nuclear Licensing, at (419) 249-2366.

Very truly yours,



MHL/mmb

enclosure

cc: P. M. Byron, DB-1 NRC Senior Resident Inspector
A. B. Davis, Regional Administrator, NRC Region III
D. C. Di Ianni, DB-1 NRC Senior Project Manager
General J. Williams, Chief of Staff, Ohio Adjutant General's Office
State of Ohio
Utility Radiological Safety Board