

ATTACHMENT 2

Technical Specification Proposed Changes

Table 3.7-4a

Pg. 3/4 7-39

Pg. 3/4 7-40

TABLE 3.7-4a

SAFETY RELATED HYDRAULIC SNUBBERS\*

| <u>SNUBBER NO.</u>   | <u>SYSTEM SNUBBER INSTALLED<br/>ON, LOCATION AND ELEVATION</u>                                | <u>ACCESSIBLE OR<br/>INACCESSIBLE<br/>(A or I)</u> | <u>HIGH RADIATION<br/>ZONE DURING SHUTDOWN**<br/>(Yes or No)</u> | <u>ESPECIALLY DIFFICULT<br/>TO REMOVE<br/>(Yes or No)</u> |
|----------------------|-----------------------------------------------------------------------------------------------|----------------------------------------------------|------------------------------------------------------------------|-----------------------------------------------------------|
| 2MS-R99#             | Ctmt. Bldg., El. 150'-7-1/2"<br>and El. 148'-7-1/2", N.W. Quad                                | I                                                  | Yes                                                              | No                                                        |
| 2MS-R100             | Ctmt. Bldg., El. 156'-6"<br>N.E. Quad                                                         | I                                                  | Yes                                                              | Yes                                                       |
| 2MS-R612             | Ctmt. Bldg., El. 166'-11-5/8"<br>N.E. Quad                                                    | I                                                  | Yes                                                              | Yes                                                       |
| 2MS-R614#            | Ctmt. Bldg., El. 158'-0"<br>N.E. Quad                                                         | I                                                  | Yes                                                              | No                                                        |
| <del>2MS-R538#</del> | <del>Turb. Bldg., El. 162'-11-11/16"</del><br><del>Col. Lines T15 &amp; T16 TC &amp; TD</del> | <del>A</del>                                       | <del>No</del>                                                    | <del>No</del>                                             |
| <del>2MS-R540</del>  | <del>Turb. Bldg., El. 157'-5-3/4"</del><br><del>Col. Lines T16 &amp; T17 TC &amp; TD</del>    | <del>A</del>                                       | <del>No</del>                                                    | <del>Yes</del>                                            |
| <del>2MS-R542#</del> | <del>Turb. Bldg., El. 157'-5-1/16"</del><br><del>Col. Lines T15 &amp; T16 TC &amp; TD</del>   | <del>A</del>                                       | <del>No</del>                                                    | <del>Yes</del>                                            |
| 2MS-R530#            | Aux. Bldg., El. 177'-1" and<br>El. 182'-1", Col. Lines TA & A<br>T15 & T16                    | A                                                  | No                                                               | No                                                        |
| 2MS-R528#            | Aux. Bldg., El. 156'-7-3/8"<br>Col. Lines TA & A, 31 & 34                                     | A                                                  | No                                                               | Yes                                                       |
| 2MS-R529             | Aux. Bldg., El. 156'-7-3/8"<br>Col. Lines TA & A, 31 & 34                                     | A                                                  | No                                                               | Yes                                                       |
| <del>2MS-R546#</del> | <del>Turb. Bldg., El. 172'-0"</del><br><del>Col. Lines T16 &amp; T17 TD &amp; TE</del>        | <del>A</del>                                       | <del>No</del>                                                    | <del>No</del>                                             |
| <del>2MS-R548#</del> | <del>Turb. Bldg., El. 162'-11-9/16"</del><br><del>Col. Lines T16 &amp; T17 TD &amp; TE</del>  | <del>A</del>                                       | <del>No</del>                                                    | <del>No</del>                                             |

delete

TABLE 3.7-4a

SAFETY RELATED HYDRAULIC SNUBBERS\*

| <u>SNUBBER NO.</u>   | <u>SYSTEM SNUBBER INSTALLED<br/>ON, LOCATION AND ELEVATION</u>                            | <u>ACCESSIBLE OR<br/>INACCESSIBLE<br/>(A or I)</u> | <u>HIGH RADIATION<br/>ZONE DURING SHUTDOWN**<br/>(Yes or No)</u> | <u>ESPECIALLY DIFFICULT<br/>TO REMOVE<br/>(Yes or No)</u> |
|----------------------|-------------------------------------------------------------------------------------------|----------------------------------------------------|------------------------------------------------------------------|-----------------------------------------------------------|
| <del>2MS-R551#</del> | <del>Turb. Bldg., El. 157'-6"<br/>Col. Lines T16 &amp; T17 TD &amp; TE</del>              | <del>A</del>                                       | <del>No</del>                                                    | <del>No</del>                                             |
| <del>2MS-R553#</del> | <del>Turb. Bldg., El. 157'-5-5/16"<br/>Col. Lines T15 &amp; T16 TD &amp; TE</del>         | <del>A</del>                                       | <del>No</del>                                                    | <del>Yes</del>                                            |
| 2MS-R534             | Aux. Turb. Bldg., El. 179'-7-3/16"<br>Col. Lines T15 & T16 TA & TA                        | A                                                  | No                                                               | Yes                                                       |
| 2MS-R532#            | Aux. Bldg., El. 155'-7-3/8"<br>Col. Lines TA & A 31 & 34                                  | A                                                  | No                                                               | Yes                                                       |
| 2MS-R533             | Aux. Bldg., El. 155'-7-3/8"<br>Col. Lines TA & A 31 & 34                                  | A                                                  | No                                                               | Yes                                                       |
| <del>2MS-R560#</del> | <del>Turb. Bldg., El. 182'-6" and<br/>185'-6", Col. Lines T16 &amp; T17 TA &amp; TB</del> | <del>A</del>                                       | <del>No</del>                                                    | <del>No</del>                                             |
| 2MS-R517             | Aux. Bldg., El. 130'-2"<br>Col. Lines C & D 34 & 36                                       | A                                                  | No                                                               | Yes                                                       |
| 2MS-R516#            | Aux. Bldg., El. 130'-2"<br>Col. Lines C & D 34 & 36                                       | A                                                  | No                                                               | Yes                                                       |
| 2MS-R503#            | Aux. Bldg., El. 130'-2"<br>Col. Lines C & D 31 & 34                                       | A                                                  | No                                                               | Yes                                                       |
| 2MS-R505             | Aux. Bldg., El. 130'-2"<br>Col. Lines C & D 31 & 34                                       | A                                                  | No                                                               | Yes                                                       |
| 2MS-R510             | Aux. Bldg., El. 130'-2"<br>Col. Lines C & D 31 & 34                                       | A                                                  | No                                                               | Yes                                                       |
| 2MS-R522             | Aux. Bldg., El. 147'-0-11/16"<br>Col. Lines A & B 31 & 34                                 | A                                                  | No                                                               | Yes                                                       |

delete