

R. A. Anderson Vice President & Station Director Nuclear Operations

February 28, 1991 BECo Ltr. #91-24

U.S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555

> License No. DPR-35 Docket No. 50-293

Dear Sir:

The enclosed table, "Number of Personne" and Man-Rem by Work and Job Function 1990", is subtilled in accredance with the equirements of the Pilgrim Nuclear Power Station (1.5.), Section 6.9.A.3, and as recommended by U.S. NRC Regulatory Guida 1.16.

The total dose measured by Self Indicating Dosimetry (SID) was 209.882 man-rem. SID measurements are used for tracking dose assigned to job functions. As required by T.S. 6.9.A.3 greater than 80% of the total whole body dose received from external sources (as accounted for via Radiation Work Permits assigned to specific major work functions.

Please do not hesitate to contact me directly if you have any questions.

Anderson

IE56

WJM/bal

301151

Enclosure: Number of Personnel and Man-Rem by Work and Job Function 1990

Ar. Thomas Martin Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Rd. King of Prussia, PA 19406

Senior Resident Inspector - Pilgrim Station

Standard BECo Distribution

9103080305 910228 PDR ADOCK 05000293 R PDR