



LER NO. 82-67/3L  
DOCKET NO. 50-317  
LICENSE NO. DPR 53  
EVENT DATE 11-09-82  
REPORT DATE 12-09-82  
ATTACHMENT

EVENT DESCRIPTION AND CORRECTIVE ACTIONS (CONT'D)

While in Mode 3 at 1445, Control Room operators noticed that #12B Safety Injection Tank (SIT) wide range and narrow range levels indicated 185". This is below the Technical Specification 3.5.1.b limit of 187". No level annunciation was present. Operators began filling the SIT until an indicated level of 189" was reached, when the SIT high level alarm annunciated. Refilling of the SIT was stopped and the level transmitter was declared inoperable and removed from service for calibration. During the recalibration it was determined that level indication was actually low by at least 10". Consequently at the time of the event, #12B SIT level was probably higher than the Technical Specification limit of 199". The level transmitter was recalibrated and level was restored within the Technical Specification limits at 1800, terminating the event. All redundant SITs remained operable during the event. Similar events: none.