

**LICENSEE EVENT REPORT**

**CONTROL BLOCK:**

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	J	S	G	S	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

**CON'T**

REPORT  
SOURCE

REPORT SOURCE 01 12 05 00 03 11 17 11 11 19 82 81 12 08 82 9

**EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)**

02 At 1715 hours, November 19, 1982, while running No. 23 Auxiliary Feedwater Pump in  
03 order to verify operability, the Auxiliary Feedwater Storage Tank (AFST) dropped below  
04 the technical specification minimum volume of 200,000 gallons. Action Statement  
05 2.7.1.3.a was entered, and AFST filling was commenced.

06

07 | Page

08 \_\_\_\_\_

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE	
7	8	S	F	A	B	Z	Z	Z	Z	Z	Z	Z	Z				
		9	10	11	12	13	14						15	16			
17		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
LEAK REPORT NUMBER		8	2	1	3	9	0	3	L	0							
		21	22	23	24	26	27	28	29	30	31						
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
H	F	Z	Z	Z	0	0	0	0	Y	N	N	Z	9	9	9	9	
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of the occurrence was personnel error. The operator did not open demineral-  
1 1 ized water make-up valve 2DR6 far enough to maintain the minimum volume. The AFST  
1 2 volume was restored to greater than 200,000 gallons, and at 1730 hours, November 19,  
1 3 1982, Action Statement 3.7.1.3.a was terminated. The operator involved was counselled  
1 4 as to the importance of proper operation of the AFST and the significance of the  
7 8 minimum required volume.

1 5		FACILITY STATUS	% POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION
		C	0 0 1	NA	A	Operational Event

7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50						
ACTIVITY CONTENT RELEASED OF RELEASE													AMOUNT OF ACTIVITY (35)																	LOCATION OF RELEASE (36)																			

1	6	Z	(33)	Z	(34)	NA	
7	8	9		10	11		44

						NA	
							80

PERSONNEL EXPOSURES			
NUMBER	TYPE	DESCRIPTION	(39)
1 7	o o o (37)	z (38)	NA

7	8	9	11	12	13	80
			PERSONNEL INJURIES			
			NUMBER	DESCRIPTION	(41)	

1 H 9 10 11 12 NA 80

		LOSS OF OR DAMAGE TO FACILITY		
		TYPE	DESCRIPTION	(43)
1	9	2	(42) NA	

7 8 9 10  
PUBLICITY  
ISSUED DESCRIPTION (45)  
8212220424 821208  
PDR ADOCK 05000311  
C 828  
NFO USE ONLY

7 8 9 10 NA S PDR 68 69 80

NAME OF PREPARER F. Dickey

PHONE: (609) 935-6000 Ext 3229