

APPENDIX A  
NOTICE OF VIOLATION

GPU Nuclear Corporation  
Three Mile Island Unit 1

Docket No. 50-289  
License No. DPR-50

As a result of the inspection conducted on October 12, 1982, through October 28, 1982, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 47 FR 9987 (March 9, 1982), the following violation was identified.

10 CFR 20.201(b) requires a licensee to conduct surveys, as defined in Part 20.201(a), to comply with the regulations in Part 20 and, which are reasonable under the circumstances to evaluate the extent of radiation hazards that are present.

Contrary to the above, on October 14, 1982, no survey was conducted to comply with the regulations in Part 20 or, as reasonable under the circumstances, to evaluate the extent of radiation hazard that a bag of trash in a restricted area presented. Specifically, a bag of trash, which was stored in the "B" Once Through Steam Generator lower tent area in excess of 24 hours, was found at a radiation level greater than 300 mR/hr. Neither the most recent radiation survey nor the radiation work permit for this area identified a source of radiation in the area greater than 80 mR/hr.

This is a Severity Level IV Violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, GPU Nuclear Corporation is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation. Where good cause is shown, consideration will be given to extending your response time.

OFFICIAL RECORD COPY