

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C B E P 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 - 0 3 2 5 7 1 1 2 3 8 2 8 1 2 1 7 8 2 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During plant operation, performance of the monthly operability test of swinging fire
0 3 doors, PT-35.18.2, revealed that both inner doors of the two personnel secondary
0 4 containment personnel airlocks located on the 50' elevation of the Reactor Building
0 5 were inoperable, as the doors would not self close with their respective door closers.
0 6 This event did not affect the health and safety of the public.
0 7
0 8 Technical Specifications 3.6.5.1, 3.7.8, 6.9.1.9b
7 8 9 30

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
S D 11 E 12 B 13 P E N E T R 14 A 15 Z 16
7 8 9 10 11 12 13 18 19 20

17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 2 1 4 3 0 3 L 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 18 X 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 A 25 X 9 9 9 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Excessive inleakage past each inner door's respective outer doors' seals prevented
1 1 the inner doors from self closing. The outer doors were sealed in accordance with
1 2 acceptable methods and each inner door, Sonic Bar Model No. (L) AR8000L, was adjusted
1 3 and tested satisfactorily as per the PT. Plant Engineering has been requested to
1 4 evaluate the use of these doors in this particular application.
7 8 9 80

1 5 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
E 28 0 6 9 29 NA B 31 Periodic Test
7 8 9 10 12 13 44 45 46 80

1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
Z 33 Z 34 NA NA
7 8 9 10 11 44 45 80

1 7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
0 0 0 37 Z 38 NA
7 8 9 10 11 12 13 80

1 8 PERSONNEL INJURIES NUMBER TYPE DESCRIPTION
0 0 0 40 NA
7 8 9 10 11 12 80

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
Z 42 NA
7 8 9 10 80

2 0 PUBLICITY ISSUED DESCRIPTION
N 44
7 8 9 10 80

8212220504 821217
PDR ADOCK 05000325
S PDR

NRC USE ONLY

NAME OF PREPARER

M. J. Pastva, Jr.

PHONE:

919-457-9521