

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket 50-508

December 21, 1982
G03-82-1313

Mr. G. W. Knighton, Chief
Licensing Branch No. 3
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: NUCLEAR PROJECT 3
FIGURES FOR ACCEPTANCE REVIEW QUESTIONS

Reference: a) Telecon between A. Vietti (NRC) and
K. Cook (Supply System), November 23,
1982.
b) Letter #G03-82-1085, G. D. Bouchey to
J. D. Kerrigan, dated October 22, 1982.

During the referenced telephone conversation the Supply System was requested to resubmit certain figures provided as part of our responses to NRC Acceptance Review Questions in reference b).

The figures for our response to Question #241.1 have been incorporated into the FSAR in Amendment 1. Thus the reviewer for this question should have these figures available now in good quality copy. The applicable FSAR figure numbers are: 2.5-110, 112, 113, 114, 115, 116, 118.

Attached you will find 11"x17" copies of the figures for our responses to Questions 241.2, 241.3 and 241.6, as requested. Also attached is a corrected copy of our response to Question 241.10, showing clearly the form of equation (1) and the definition of Rd.

Boo!

~~Boo!~~
~~Boo!~~
~~Boo!~~

Mr. G. W. Knighton


Page 2

December 21, 1982

NUCLEAR PROJECT 3 FIGURES FOR ACCEPTANCE REVIEW QUESTIONS

Should you require further information or clarification the Supply System point of contact for this matter is Mr. K. W. Cook, Licensing Project Manager (206/482-4428, ext. 5436).

Sincerely,



G. D. Bouchey, Manager
Nuclear Safety and Regulatory Programs

GDB/jn

cc: D. J. Chin - Ebasco NYO
J. A. Adams - NESCO
D. Smithpeter - BPA
A. Vietti - NRC
Ebasco - Elma
WNP-3 Files - Richland

Question No.

247.10
(3.8.4.4)

Describe in detail the procedure you used for calculating the subgrade stiffness that was used in MSC/NASTRAN for the analysis of the Category I Tank Enclosure Structure, and provide the values of the geotechnical parameters for staff review. Also provide the foundation loading results and factors of safety with respect to sliding and overturning of this structure for SSE conditions and reference results to Subsection 2.5.4.

Response

The subgrade stiffness for the analysis of the Category I Tank Enclosure Structure was calculated using

$$(1) \quad K_s = \frac{2.16G}{R_d (1-\mu) \sqrt{A}}$$

where: K_s = Modulus of subgrade reaction

G = 330 Ksi from Figure 2.5-121

μ = 0.40 from Table 2.5-16


A = Area but to a maximum of $10m^2$

R_d = reduction factor which varies from 5 to 20 to convert from laboratory data to field data.

Equation (1) was obtained from "Dynamics of Bases and Foundations" by D. D. Barker, McGraw Hill, 1962.

Substituting the indicated values into Equation (1) and using the maximum reduction factor for conservatism, a value for K_s of 500 #/in^3 was determined and used in the static analysis for the Tank Enclosure Structure.

The factors of safety against sliding and overturning for the Tank Enclosure Structure and respectively, 1.6 and 1.5 (see Subsection 3.7.2.14) for SSE condition. The maximum bearing pressure (also due to SSE) is $6.0K/ft^2$. The bearing capacity of weathered sandstone, on which the tank enclosure structure is founded, is $50K/ft^2$ (factor of safety is 8.3).



EXPLANATION


- Contour, elevation top of weathered sandstone, in feet (Prior to construction)*
- Boring location showing elevation top of weathered sandstone, in feet

NOTE: This contour map is interpreted from presently available geologic boring data and topographic maps.

* At completion of construction, elevation of plant island is +390



ATTACHMENT I
(NRC QUESTION 241.6)
PLANT LOCATION CONTOUR MAP
TOP OF WEATHERED SANDSTONE



EXPLANATION


- Contour, elevation top of weathered sandstone, in feet (Prior to construction)*
- Boring location showing elevation top of weathered sandstone, in feet

NOTE: This contour map is interpreted from presently available geologic boring data and topographic maps.



* At completion of construction, elevation of plant island is +390

ATTACHMENT I
(NRC QUESTION 241.6)
PLANT LOCATION CONTOUR MAP
TOP OF WEATHERED SANDSTONE

ATTACHMENT 1
 (NRC QUESTION 241.6)
 PLANT LOCATION CONTOUR MAP
 TOP OF WEATHERED SANDSTONE




EXPLANATION

-  Contour, elevation top of weathered sandstone, in feet (Prior to construction)*
-  Boring location showing elevation top of weathered sandstone, in feet

* At completion of construction, elevation of plant island is +390

NOTE: This contour map is interpreted from presently available geologic boring data and topographic maps.

ATTACHMENT I
 (NRC QUESTION 241.6)
 PLANT LOCATION CONTOUR MAP
 TOP OF WEATHERED SANDSTONE



EXPLANATION

Contour, elevation top of weathered sandstone, in feet (Prior to construction)*

Boring location showing elevation top of weathered sandstone, in feet

* At completion of construction, elevation of plant island is +390

NOTE: This contour map is interpreted from presently available geologic boring data and topographic maps.

CATEGORY I STRUCTURE	FOUNDATION DIMENSIONS (AS-BUILT)	FOUNDATION ELEVATIONS (MSL)	DESCRIPTION OF FOUNDATION BASE AND DEPTH TO FRESH SANDSTONE	FOUNDATION LOADING		ALLOWABLE BEARING CAPACITY		FACTOR OF SAFETY	
				Static K/Ft ²	Dynamic K/Ft ²	Static K/Ft ²	Dynamic K/Ft ²	Static	Dynamic
Condensate/Refueling Water Tank Foundation	175'-0 x 66'-0	Top El 390.00'	5'-0 Thick Mat on Weathered Sandstone 40' to Fresh Sandstone	2.5	6.0	50.0	50.0	20.0	8.3
Dry Cooling Tower & Control Bldg.	85'-0 x 272'-0	Top El 390.00'	4'-0 Thick Mat on Weathered Sandstone 35' to Fresh Sandstone	2.1	4.6	50.0	50.0	23.8	10.9
Shield Building, Containment, Int. Structure, Fuel Handling Bldg. Reactor Aux Bldg on common mat	298'-0 x 310'-0	Top El 335.00'	9'-0 Thick Mat Located in Fresh Sandstone	13.6	17.7	85.0	85.0	6.3	4.8


CATEGORY I STRUCTURE	FOUNDATION DIMENSIONS (AS-BUILT)	FOUNDATION ELEVATIONS (MSL)	DESCRIPTION OF FOUNDATION BASE AND DEPTH TO FRESH SANDSTONE	FOUNDATION LOADING		ALLOWABLE BEARING CAPACITY		FACTOR OF SAFETY	
				Static	Dynamic	Static	Dynamic	Static	Dynamic
				K/Ft ²	K/Ft ²	K/Ft ²	K/Ft ²		
Condensate/Refueling Water Tank Foundation	175'-0 x 66'-0	Top El 390.00'	5'-0 Thick Mat on Weathered Sandstone 40' to Fresh Sandstone	2.5	6.0	50.0	50.0	20.0	8.3
Dry Cooling Tower & Control Bldg.	85'-0 x 272'-0	Top El 390.00'	4'-0 Thick Mat on Weathered Sandstone 35' to Fresh Sandstone	2.1	4.6	50.0	50.0	23.8	10.9
Shield Building, Containment, Int. Structure, Fuel Handling Bldg. Reactor Aux Bldg on common mat	298'-0 x 310'-0	Top El 335.00'	9'-0 Thick Mat Located in Fresh Sandstone	13.6	17.7	85.0	85.0	6.3	4.8

CATEGORY I STRUCTURE	FOUNDATION DIMENSIONS (AS-BUILT)	FOUNDATION ELEVATIONS (MSL)	DESCRIPTION OF FOUNDATION BASE AND DEPTH TO FRESH SANDSTONE	FOUNDATION LOADING		ALLOWABLE BEARING CAPACITY		FACTOR OF SAFETY	
				Static K/Pc ²	Dynamic K/Pc ²	Static K/Pc ²	Dynamic K/Pc ²	Static	Dynamic
Condensate/Refueling Water Tank Foundation	175'-0" x 66'-0"	Top El 390.00'	5'-0" Thick Mat on Weathered Sandstone 40' to Fresh Sandstone	2.5	6.0	50.0	50.0	20.0	8.3
Dry Cooling Tower & Control Bldg.	85'-0" x 272'-0"	Top El 390.00'	4'-0" Thick Mat on Weathered Sandstone 35' to Fresh Sandstone	2.1	4.6	50.0	50.0	23.8	10.9
Shield Building, Containment, Int. Structure, Fuel Handling Bldg. Reactor Aux Bldg on common mat	298'-0" x 310'-0"	Top El 335.00'	9'-0" Thick Mat Located in Fresh Sandstone	13.6	17.7	85.0	85.0	6.3	4.8


CATEGORY I STRUCTURE	FOUNDATION DIMENSIONS (AS-BUILT)	FOUNDATION ELEVATIONS (MSL)	DESCRIPTION OF FOUNDATION BASE AND DEPTH TO FRESH SANDSTONE	FOUNDATION LOADING		ALLOWABLE BEARING CAPACITY		FACTOR OF SAFETY	
				Static	Dynamic	Static	Dynamic	Static	Dynamic
				K/Ft ²	K/Ft ²	K/Ft ²	K/Ft ²		
Condensate/Refueling Water Tank Foundation	175'-0 x 66'-0	Top El 390.00'	5'-0 Thick Mat on Weathered Sandstone 40' to Fresh Sandstone	2.5	6.0	50.0	50.0	20.0	8.3
Dry Cooling Tower & Control Bldg.	85'-0 x 272'-0	Top El 390.00'	4'-0 Thick Mat on Weathered Sandstone 35' to Fresh Sandstone	2.1	4.6	50.0	50.0	23.8	10.9
Shield Building, Containment, Int. Structure, Fuel Handling Bldg. Reactor Aux Bldg on common mat	298'-0 x 310'-0	Top El 335.00'	9'-0 Thick Mat Located in Fresh Sandstone	13.6	17.7	85.0	85.0	6.3	4.8

CATEGORY I STRUCTURE	FOUNDATION DIMENSIONS (AS-BUILT)	FOUNDATION ELEVATIONS (MSL)	DESCRIPTION OF FOUNDATION BASE AND DEPTH TO FRESH SANDSTONE	FOUNDATION LOADING		ALLOWABLE BEARING CAPACITY		FACTOR OF SAFETY	
				Static	Dynamic	Static	Dynamic	Static	Dynamic
				K/Ft ²	K/Ft ²	K/Ft ²	K/Ft ²		
Condensate/Refueling Water Tank Foundation	175'-0 x 66'-0	Top El 390.00'	5'-0 Thick Mat on weathered Sandstone 40' to Fresh Sandstone	2.5	6.0	50.0	50.0	20.0	8.3
Dry Cooling Tower & Control Bldg.	85'-0 x 272'-0	Top El 390.00'	4'-0 Thick Mat on weathered Sandstone 35' to Fresh Sandstone	2.1	4.6	50.0	50.0	23.8	10.9
Shield Building, Containment, Int. Structure, Fuel Handling Bldg. Reactor Aux Bldg on common mat	298'-0 x 310'-0	Top El 335.00'	9'-0 Thick Mat Located in Fresh Sandstone	13.6	17.7	85.0	85.0	6.3	4.8



SEPTEMBER 1978			OCTOBER 1978			NOVEMBER 1978			DECEMBER 1978			JANUARY 1979			FEBRUARY 1979			MARCH 1979		
10	20		10	20	30	10	20	30	10	20	30	10	20	30	10	20		10	20	30



LARGE DEFLECTIONS COINCIDE WITH SURFACE ICE EXPANSION DURING FREEZING



APRIL 1979			MAY 1979			JUNE 1979			JULY 1979		
10	20	30	10	20	30	10	20	30	10	20	30




PLAN VIEW

MEASUREMENTS DISCONTINUED DUE TO PERMANENT CONSTRUCTION

LEGEND:


CRACK	PIN SET NUMBER	LINE LEGEND
A	3-1	-----
A	3-2	-----
A	3-3	-----
B	3-4	-----
B	3-5	-----
C	3-6	-----
C	3-7	-----
C	3-8	-----
D	3-9	-----
E	3-10	-----
F	3-11	-----

LEGEND FOR NRC QUESTION 241.2




ATTACHMENT II
(NRC QUESTION 241.2)
CRACK MONITORING
UNIT NO. 3


SEPTEMBER 1978		OCTOBER 1978			NOVEMBER 1978		DECEMBER 1978			JANUARY 1979			FEBRUARY 1979		MARCH 1979	
10	20	10	20	30	10	20	10	20	30	10	20	30	10	20	10	20




LARGE DEFLECTIONS CORRELATE WITH SURFACE ICE EXPANSION DURING FREEZING





SEPTEMBER 1978		OCTOBER 1978			NOVEMBER 1978		DECEMBER 1978			JANUARY 1979			FEBRUARY 1979		MARCH 1979	
15	20	10	20	30	10	20	10	20	30	10	20	30	10	20	10	20



LARGE DEFLECTIONS CORRECTED WITH SURFACE ICE EXPANSION DURING FREEZING



APRIL 1979		MAY 1979		JUNE 1979		JULY 1979	
10	20	10	20	10	20	10	20



PLAN VIEW


MEASUREMENTS DISCONTINUED DUE TO PERMANENT CONSTRUCTION

LEGEND:

CRACK	PIN SET NUMBER	LINE LEGEND
A	3-1	————
A	3-2	-----
A	3-3	-----
B	3-4	-----
B	3-5	-----
C	3-6	-----
F	3-7	-----
	3-8	-----
D	3-9	-----
E	3-10	-----
F	3-11	-----



FLUCTUATION CAUSED BY BAR WALL CONSTRUCTION ACTIVITIES (PINS ARE NOT PROTECTED FROM FOOT TRAFFIC)



LEGEND FOR NRC QUESTION 241.2



ATTACHMENT II
(NRC QUESTION 241.2)
CRACK MONITORING
UNIT NO. 3



SEPTEMBER 1978		OCTOBER 1978			NOVEMBER 1978		DECEMBER 1978			JANUARY 1979			FEBRUARY 1979		MARCH 1979		
15	20	10	20	30	10	20	10	20	30	10	20	30	10	20	10	20	30






LEGEND:



CRACK	PIN SET NUMBER	LINE LEGEND
A	3-1	————
A	3-2	-----
A	3-3	-----
B	3-4	————
B	3-5	-----
C	3-6	————
C	3-7	-----
C	3-8	-----
D	3-9	————
E	3-10	————
F	3-11	————



ATTACHMENT II
(NRC QUESTION 241.2)
CRACK MONITORING
UNIT NO. 3

SEPTEMBER 1978	OCTOBER 1978	NOVEMBER 1978	DECEMBER 1978	JANUARY 1979	FEBRUARY 1979	MARCH 1979
10 20	10 20 30	10 20	10 20 30	10 20 30	10 20	10 20 30






PLAN VIEW


MEASUREMENTS DISCONTINUED DUE TO PERMANENT CONSTRUCTION

LEGEND:

CRACK	PIN SET NUMBER	LINE LEGEND
A	3-1	————
A	3-2	————
A	3-3	————
B	3-4	————
B	3-5	————
C	3-6	————
C	3-7	————
C	3-8	————
D	3-9	————
E	3-10	————
F	3-11	————



ATTACHMENT II
(NRC QUESTION 241.2)
CRACK MONITORING
UNIT NO. 3



SAFETY FENCE

SURVEY LINES OF SIGHT FENCE (TYPICAL)

SURVEY LINES OF SIGHT

SHIELD WALL


CRACK MONITORING PINS (TYPICAL)

MONUMENTS


CRANE PAD

INSTRUMENTATION TRAILER


UNIT 3
1" = 20'




NOTES:
 1) TELLUROMETER READINGS CANNOT BE TAKEN IN DENSE
 FOG OR HEAVY RAINS - SCHEDULE WILL VARY ACCORDING
 TO WEATHER CONDITIONS.




ATTACHMENT I
 (NRC QUESTION 241.2)
 INFORMATION DRAWING
 INSTRUMENTATION LOCATIONS
 (WORKMAN SAFETY RELATED)




UNIT 3
 1" = 20'



NOTES:
 1) TELLUROMETER READINGS CANNOT BE TAKEN IN DENSE
 FOG OR HEAVY RAINS. SCHEDULE WILL VARY ACCORDING
 TO WEATHER CONDITIONS.



ATTACHMENT I
 (NRC QUESTION 241.2)
 INFORMATION DRAWING
 INSTRUMENTATION LOCATIONS
 (WORKMAN SAFETY RELATED)



SAFETY FENCE

SURVEY LINES OF SIGHT FENCE (TYPICAL)

SURVEY LINES OF SIGHT


SHIELD WALL

CRACK MONITORING PINS (TYPICAL)

MONUMENTS

INSTRUMENTATION TRAILER


UNIT 3
1" = 20'




NOTES:

1) TELLURIMETER READINGS CANNOT BE TAKEN IN DENSE FOG OR HEAVY RAINS. SCHEDULE WILL VARY ACCORDING TO WEATHER CONDITIONS.


LEGEND FOR NRC QUESTION 241.2



ATTACHMENT I
(NRC QUESTION 241.2)
INFORMATION DRAWING
INSTRUMENTATION LOCATIONS
(WORKMAN SAFETY RELATED)




UNIT 3
 1" = 20'




NOTES:
 1. TELLUROMETER READINGS CANNOT BE TAKEN IN DENSE
 FOG OR HEAVY RAIN. SCHEDULE WILL VARY ACCORDING
 TO WEATHER CONDITIONS.


LEGEND FOR NRC QUESTION 241.2



ATTACHMENT I
 (NRC QUESTION 241.2)
 INFORMATION DRAWING
 INSTRUMENTATION LOCATIONS
 (WORKMAN SAFETY RELATED)




UNIT 3
 1" = 20'



NOTES:
 1) TELLUROMETER READINGS CANNOT BE TAKEN IN CASE
 OF OR HEAVY RAINS. SCHEDULE WILL VARY ACCORDING
 TO WEATHER CONDITIONS.

LEGEND FOR NRC QUESTION 241.2



ATTACHMENT I
 (NRC QUESTION 241.2)
 INFORMATION DRAWING
 INSTRUMENTATION LOCATIONS
 (WORKMAN SAFETY RELATED)