



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

THE CLEVELAND ELECTRIC ILLUMINATING COMPANY, ET AL.

DOCKET NO. 50-440

PERRY NUCLEAR POWER PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 64  
License No. NPF-58

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by The Cleveland Electric Illuminating Company, Centerior Service Company, Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company, and Toledo Edison Company (the licensees) dated March 12, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-58 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 64 are hereby incorporated into this license. The Cleveland Electric Illuminating Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented not later than 90 days after issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Jon B. Hopkins, Senior Project Manager  
Project Directorate III-3  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of issuance: July 18, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 64

FACILITY OPERATING LICENSE NO. NPF-58

DOCKET NO. 50-440

Replace the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by Amendment number and contains vertical lines indicating the area of change.

Remove

3/4 3-63

Insert

3/4 3-63

TABLE 3.3.7.1-1 (Continued)

RADIATION MONITORING INSTRUMENTATION

ACTION

ACTION 70 - With the required monitor inoperable, obtain and analyze at least one grab sample of the monitored parameter at least once per 24 hours. In addition, with the Unit 1 Vent noble gas monitor inoperable, restore the inoperable noble gas monitor to OPERABLE status within 24 hours or place the inoperable noble gas monitor in the tripped condition.

ACTION 71 - With the required monitor inoperable, release via this pathway may continue provided grab samples are taken at least once per 8 hours and these samples are analyzed for gross activity within 24 hours.

ACTION 72 - With the required monitor inoperable, assure a portable continuous noble gas monitor or the Control Room Area Radiation Monitor is OPERABLE in the control room within 24 hours, and restore the inoperable monitor to OPERABLE status within 7 days.

Otherwise, within 1 hour, either:

- a. Initiate and maintain operation of at least one of the control room emergency recirculation subsystems in the emergency recirculation mode of operation, or
- b. In OPERATIONAL CONDITIONS 1, 2 or 3, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. In OPERATIONAL CONDITIONS 4, 5 or \*\*\*, suspend CORE ALTERATIONS, handling of irradiated fuel in the Fuel Handling Building and the primary containment, and operations with a potential for draining the reactor vessel.

ACTION 73 - With the number of channels OPERABLE less than required by Minimum Channels OPERABLE requirement, release via this pathway may continue for up to 30 days provided:

- a. The offgas system is not bypassed, and
- b. The offgas post-treatment monitor is OPERABLE, and
- c. Grab samples are taken at least once per 8 hours and analyzed within the following 4 hours;

Otherwise, be in at least HOT SHUTDOWN within 12 hours.

ACTION 74 - DELETED

ACTION 75 - With the required monitor inoperable, perform area surveys of the monitored area with portable monitoring instrumentation at least once per 24 hours.